

# Instructions for Type-C Tester with Full Colour Display

-Version: **TC66/TC66C(2020.6.5)**


## CONTENT

1. Technical Parameters: .....	1
2. Panel Introduction.....	2
3. Operation Introduction:.....	2
3.1 Main Page as Picture 3-1.....	2
3.2 Offline Recording Page as Picture 3-2.....	3
3.3Quick Charge Recognition Page as Picture 3-3.....	3
3.4 Quick Charge Protocol Detection Page as Picture 3-4.....	3
3.5 Trigger Page as Picture 3-5-1 .....	4
3.5.1 Trigger Operation:.....	4
3.5.2 PD trigger Operation.....	4
3.6 System Setting Page as Picture 3-6-1 and 3-6-2.....	4
3.7 System Information Page as Picture 3-7.....	5
3.8 Simple Measurement Page as Picture 3-8.....	5
3.9 Abnormal Status Solution .....	5
4. PC Software Installation Instruction.....	6
4.1 Software Installation.....	6
4.2 Software Operation .....	6
4.3 Firmware Update .....	7
4.4 Software Update .....	7
5. Android APP Instruction .....	7
5.1 Software Installation.....	7
5.2 Software Operation .....	8
5.3 Software Update .....	8
6. iPhone APP Instruction (Only supports TC66C) .....	8
6.1Software Update .....	9
7.Others .....	9
Appendix 1: Explanation of terms .....	1
Appendix 2: Basic operating knowledge.....	1
Appendix 3: Knowledge points .....	2

Dear Customer,

Thank you for purchasing this Full Color Type-C Tester from Hangzhou Ruideng Technologies Co., Ltd. Prior to using this product, we recommend that you briefly familiarize yourself with these instructions to ensure the correct operation and proper usage of the device. We also advise that you keep these instructions in a safe place for future reference as needed. TC66 only supports USB communication while TC66C supports both USB and Bluetooth communication. (Please pay attention to the red font in this manual)


Please be sure to turn off the hardware PD switch or software PD switch when taking charging measurement, and turn them on when using trigger function and fast charge protocol detection.



## 1. Technical Parameters:

Model: TC66/TC66-C	Display screen: 0.96 Inch color IPS display
Voltage measurement range:0.0050-30.0000V	Voltage measurement resolution:0.0001V(0.1mV)
Current measurement range: 0-5.00000A	Current measurement resolution: 0.00001A(0.01mA)
Supply voltage: 3.5-24V	Screen Resolution: 160*80
Capacity accumulation range: 0-99999mAh	Voltage measurement accuracy: $\pm(0.05\%+20\text{digits at } 23^\circ\text{C})$
Energy accumulation range: 0-99999mWh 999.99Wh	Current measurement accuracy: $\pm(0.1\%+30\text{ digits, at } 23^\circ\text{C})$
Load impedance range: 1Ω-9999.9Ω	Power measurement range:0-150W
Temperature measurement range: 0°C~45°C/32°F~113°F	Refresh rate: 2Hz
Working temperature range: 0~45°C/32°F~113°F	Auto screen off time: 0-9mins
Dimensions: 49mmx22mmx8mm	Product weight: about 8g (with package 22g)
Quick charge recognition mode: QC2.0、QC3.0、Apple 2.4A/2.1A/ 1A/0.5A、Android DCP、Samsung	

## 2. Panel Introduction



A: button K1, short press to navigate to previous page/ change values or enter sub-menu, having long press function at some page.

B: button K2, short press to navigate to next page, long press to enter or exit menu.

C: **PWR** power supply switch button. **When in ON position, this device draws system power from USB type-C male port; and there is about 20mA when there is no load connected when you connect the female port, you can put the PWR switch to OFF position, it will draw system power from micro USB port, you can test from 0V when using micro USB port, if the voltage is not 0, please turn off the PWR switch first.**

D:PD Switch, place the switch on "OFF" for measuring a device in charging, PD function OFF, and place the switch to "ON" for decoy triggering operation, PD function ON.

E: Micro-USB port, use for isolated power supply or connecting with PC software.

## 3. Operation Introduction:

Please connect TC66(C) to power charger first before connecting the load. There are eight pages by default. After power on, it resumes the active page before the last power off. Short press K1 or K2 to navigate previous /next page. Long press K2 to enter or exit sub-menu.

*(Note: this instruction corresponds to the V1.14 version of firmware. There may be differences between different firmware version, Please refer to chapter 4.3 for firmware update)*

### 3.1 Main Page as Picture 3-1

F: Voltage measurement value

G: Current measurement value

H: Capacity accumulation measurement value

I: Energy accumulation measurement value


J: Temperature measurement value

K: Data group number

L: Load impedance value

M: Power measurement value

N: Current flow direction



At this page, press and hold K1 to clear the current data group value. Press and hold K2 to


switch between data group, When data group 1 is selected, the current capacity and energy will be saved after power off. They will continue accumulating the next time the tester is powered on. When the data group 0 is selected, the current value of mAh and mWh will be temporarily saved at power off. When the device is powered on again, these values will be recalled and display in blinking. When the accumulated mAh exceeds 1 mAh, the previous data will be cleared and accumulation will restart.

### 3.2 Offline Recording Page as Picture 3-2

- O: Recording state icon
- P: Recording data reset
- Q: Data recording interval time
- R: Recording time
- S: Percentage of used record space

At this page, press and hold K2 button to enter menu, there is a small triangle points to the option to be operated. After enter the menu, short press K2 to choose among (O) (P) and (Q), and press K1 to the activate the specified menu function. Red REC is to stop recording, green REC is recording.

PERIOD is the recording interval time, adjusting range between 1 to 60s, it can record 24mins to 24 hours, CE is to clear offline storage data. After clearing recording data, you can change the recording interval time, recording interval time cannot be changed after starting recording. After power off, the recording will be automatically suspended. Press and hold K2 to exist setting. Press K2 to enter quick charge recognition interface.



### 3.3 Quick Charge Recognition Page as Picture 3-3

- T: D +
- U: D -
- V: Current fast charging mode display

At this time the device supports the QC2.0, QC3.0, Apple 2.4A/2.1A/1A/0.5A, Android DCP, Samsung.(Note: the D+ D- voltage and the fast charge protocol detected are for reference only)

Press K2 to enter quick charge protocol detection Interface.



### 3.4 Quick Charge Protocol Detection Page as Picture 3-4

At this page, press and hold K2 button, it will show warning “DANGEROUS”. Then press K1, and detection will begin. After detection, the supported protocol is shown in green and the unsupported protocol is shown in red. The Current protocols supporting automatic detection include



QC2.0, QC3.0, Huawei FCP, Huawei SCP, Samsung AFC and PD. (Please look forward to more never protocol detection. **This operation will make the USB-C port output high voltage, please unplug the load when using this this function**)

Press K2 to enter trigger interface.

### 3.5 Trigger Page as Picture 3-5-1

#### 3.5.1 Trigger Operation:

At this page, press and hold K2 button to enter trigger menu, then Press K2 to scroll down for more selection. Once choice is made, press K1 to enter sub-menu. At sub-menu, press K1 or K2 to begin trigger or adjust voltage. Press K2 to return to last menu. Except for Huawei SCP and PPS, the tester will keep the quick charging state after exiting trigger mode and it requires re-plugin of the tester to restore to the 5V state. The current protocols supporting for trigger are QC2.0, QC3.0, HUWEI FCP, Huawei SCP PD2.0, PPS and SUMSUNG AFC. (**This operation will make the type-c port output high voltage, please unplug the load when using this this function**)



(3-5-1)

#### 3.5.2 PD trigger Operation

W: Current PD mode

X: Actual output Voltage now

Y: PPS Voltage step value (cannot be chosen under fixed Voltage)

Z: White options mean supported PD Voltage. Green option means current trigger Voltage.

The PD trigger effect is similar to picture3-5-2, press K1 and re-plug interface according to the tips, then press K1/K2 to switch PD Voltage. Press and hold K1 to switch Voltage step value under PPS mode. Press K1/K2 to increase/decrease the Voltage. Press and hold K2 to exit trigger mode. Because single-sided CC cable is commonly used, when connecting PD device with Type-C cable, try flip the tester if it does not work.



At this page, Press and hold K2 button to enter setting menu, short press K2 to select function option. After selected, press K1 to change that function's data value. Press and hold K2 button to save settings and return to previous menu.

- Delay off screen time can be set 1-9 minutes or lighting, 0 means never off.
- There are 10 levels screen brightness;
- Temperature unit can adjust between  $^{\circ}\text{C}$  and  $^{\circ}\text{F}$ ;
- There is 180-degree rotation for screen;
- When the CC pull-down is turned on, the screen will light up by default. If you need to measure PD charging, please turn off the CC drop down;
- Restore factory defaults only restore setting, not clear data group data and offline data.

For CC pull-down:PD stipulate that Type-C interface has no output by default. When there is a drop down on the CC line (pin in the Type-C interface), PD charger thinks that the load is connected and then starts the 5V output. Therefore, it is normal for the tester to plug directly into the PD charger and not light when there is no load. If CC drop down is enabled in the setting of TC66, when you plug TC66, it will automatically brighten the screen after it is set as enabled, but it may affect the normal charging process. If protocol detection and trigger are to be exercised, CC drop down must be enabled, and the back end shall not be connected with any load. If it is set to be off, the charging of PD charger will not brighten the screen, and the charging process will not be affected. Please first plug the tester into the charger and then insert the load.

Press K2 to enter system information interface.

### 3.7 System Information Page as Picture 3-7


AJ: Products series number

AK: Firmware revision number

AL: Boot times

AM: This time running time

Press K2 button to simple measurement interface.



### 3.8 Simple Measurement Page as Picture 3-8

This page only show voltage, current, power and current flow direction



### 3.9 Abnormal Status Solution

You can press and hold K2 button and power on TC66 under abnormal status to restore factory settings, or you can press and hold K1 and power on TC66 to enter the boot mode, and use PC software to update the firmware.

## 4. PC Software Installation Instruction

Software installation environment requirements: WIN7 and above system, computer with networks. **PC software can only communicate with TC66/TC66C by USB port.**

This software is developed by Hangzhou RuiDeng technology co., LTD., without virus. If the anti-virus software remind, please allow all its functions, otherwise it will affect the normal operation of the software. Download link:

<http://www.mediafire.com/folder/pqn0bytqpy7n/TC66>.

### 4.1 Software Installation


名称	压缩前	压缩后	类型	修改日期
.. (上级目录)			文件夹	
driver			文件夹	2019-12-04 16:14
Language			文件夹	2019-12-04 10:43
temp			文件夹	2019-12-04 10:48
NET_Framework_4.6.exe	1.4 MB	1.3 MB	应用程序	2019-12-03 17:14
RuiDengUSBMeter.exe	2.6 MB	2.4 MB	应用程序	2019-12-04 15:26

4.1.1. Download the file and open it. RunNET\_Framework\_4.6 to install .net.

4.1.2 After the installation, double-click the RuiDengUSBMeter to open software. Do not edit or delete other files.

4.1.3 For the first time to use, select Driver Installation menu to install driver first.


4.1.4. After installation, Connect the tester micro-USB port to computer, the computer will automatically install driver, then unplug and plug it again, the prompt on upper left corner indicates that the device has been inserted, then click the “Connect” to use.



### 4.2 Software Operation

Connect the tester with computer by micro-USB cable, when show tester plugged, then press “Connect”, then the software will show real-time voltage, current and other data information. The right curve chart can be double-clicked to adapt to the size of the window, and the scroll wheel will zoom in and out. Rotating the scroll wheel between the X-axis and Y-axis, the chart will have different scale effects. Right click on the chart to clear data, and export a table or picture. Click offline data and may take a few moment, offline data will enter the table.

When offline data is displayed, real-time curve record will be suspended. Below are the recorded values of the two data groups and the voltage of D+D-.



#### 4.3 Firmware Update

When there is a new firmware, the tester will remind you to update the firmware. Please follow the following steps to update the firmware

- 4.3.1. Clean up memory and turn off unnecessary software (or restart your computer).
- 4.3.2. Restart the software, close all updates prompt.
- 4.3.3. Disconnect tester from computer. Press and hold K1 first before connecting tester micro-USB to computer, waiting for displaying device inserted, turn off pop-up firmware update prompt (don't click "connect" at this time).
- 4.3.4. Click on the firmware update, and then click update now.

#### 4.4 Software Update

When there is new PC software, it will remind you to update, and you need to download and install the new software by yourself. The software version corresponding to the current manual is V1.0.0.5.

### 5. Android APP Instruction


Support Android 5.0 and above, and Bluetooth 4.0 above, **and only support TC66C version**

The Android application has been uploaded to the Google play, you can search "TC66C" in Google play. Domestic customers who cannot use Google play can also download the file with the extension APK and install it on the phone. You can get download on <http://www.mediafire.com/folder/pqn0ybytqpy7n/TC66>.

#### 5.1 Software Installation

Because TC66C adopted BLE Bluetooth module, when android 6.0 and above system connect BLE, it needs location permission. So please agree with this permission when install APP. And BLE can't be connected by system Bluetooth, you need to open APP to search and connect. There may be incompatibilities problems because there are too many phone types, if you really need this function, please download first and check whether you can use the APP

before buying.



## 5.2 Software Operation


After connection, then click ENTER to enter operation page as right picture. Click SHARE export all recording data as EXCEL file. (More functions will be updated later, please look forward to it.)

## 5.3 Software Update

After open APP, check for new versions automatically, when there is a new version, the software will automatically prompt update, this manual corresponds to the android software version for V1.1.1.

# 6. iPhone APP Instruction (Only supports TC66C)

APP can work on IOS 8.0 or above system, and only support TC66C version. You can search "TC66C" to download it at APP store.



There may be incompatibilities problems because there are too many phone types, if you really need this function, please download first and check whether you can use the APP before buying.

### **6.1Software Update**

When there is a new version, the software will automatically prompt update, or you can download the latest version at IOS APP STORE, The software version corresponding to the current manual is V1.2.0.

## **7.Others**

If you have product hardware and software technical problems, please contact our email 1749808860@qq.com.

# Appendix 1: Explanation of terms

**Fast charging:** fast charging, mostly refers to the charging process with charging current greater than 2A or charging power greater than 10W.

**Fast charging protocol detection:** detect which fast charging protocols the charger supports.

**Fast charge protocol/fast charge mode identification:** Identify what fast charge is currently in progress.

**Decoy/trigger:** Simulate the fast charge protocol to enable the charger to output high voltage/large current.

**Fast charge simulation:** simulate the protocol that the charger does not support, and improve the compatibility of the charger.

**Common part of the fast charge protocol:**

Qualcomm: QC2.0, QC3.0, QC4+

MediaTek: PE2.0, PE3.0

Huawei: FCP SCP

OPPO: VOOC, Super VOOC

OnePlus: DASH, Warp

USB Type-C: PD2.0, PD3.0, PPS

mAh, mWh: namely milliampere hour, milliwatt hour, milliampere hour is the unit of capacity

For a battery,  $\text{mAh} \times \text{voltage} = \text{mWh}$

# Appendix 2: Basic operating knowledge

## 1. Capacity measurement of power bank

**Preparation:** power bank to be tested, USB tester, HD35 electronic load or mobile phone, charger.

**Data to be checked:** the capacity &energy value of the power bank (mAh Wh), the voltage and current value of the power bank when output.

Fully charge the power bank first, then adjust the tester to a non-zero data group, then clear the current data set, and use the power bank to charge the mobile phone or use HD35 electronic load to discharge until the power bank automatically shuts down, use the charger to power the tester, and then record the test data:mAh and mWh on the meter.

**Method 1:** Compare the tester's display of mWh divided by 0.9 and the power bank's Wh. If the difference is small, it means power bank has the right Wh value (the most accurate method).

**Method 2:** If the mobile phone is 5V charging, the tester displays mAh multiplied by 1.5, if the mobile phone is 9V charging, the tester displays mAh multiplied by 2.7. If the difference is small, it means power bank has the right capacity( suitable for power bank with no Wh power

bank)

Since many mobile power battery now have over 10000 mAh, if you simply rely on charging your mobile phone to measure the capacity of the power bank. You need to charge the phone many times, so it takes even a week to measure a mobile power source. In order to quickly release the energy of power bank, you can use constant voltage and constant current load to discharge:

Take the new Mi Power Bank 2 as an example, it can support 5V2A Output,  $38.5\text{Wh}/(5\text{V}\cdot 2\text{A})=3.85$ . It takes about 4 hours to discharge the power of the power bank. If you use trigger function of HD35 electric load, you can use 9V/18W fast discharge,  $38.5\text{Wh}/(9\text{V}\cdot 2\text{A})=2.13\text{h}$ . It takes a little more than two hours to discharge the power bank, and quickly identify whether the mobile power supply has a false capacity value (high power during discharge, the conversion rate will decrease, and the actual measured capacity will be smaller).

## Appendix 3: Knowledge points

The standard Type-C equipment normally has no voltage output, because some Type-C ports are sometimes the power supply end and sometimes the power reception end. For example, the power bank with the Type-C interface can not only charge the mobile phone, but also use the charger to charge the power bank. Or Mac Book, you can use the charger to charge the mac book and the mac book can also charge the iPhone.

TC66 is equivalent to a load when the PD switch is turned on, so it can be lit when plugged into the charger. There is only one CC signal line inside the double-headed Type-C line. If it is not lit, the tester terminal terminal needs to be turned 180 degrees.

It is necessary to turn off the PD switch when measuring the charging current of the mobile phone, otherwise it may affect the communication. The PD switch must be turned on when measuring fast charging protocol and using trigger function

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Any changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

NOTE: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications.

However, there is no guarantee that interference will not occur in a particular installation.

If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

The device has been evaluated to meet general RF exposure requirement. The device can be used in portable exposure condition without restriction