

Appendix B

WIFI 6E

Device Under Test Properties

Model	Dimensions [mm]	IMEI
ME74	220.0 x 80.0 x 45.0	SN:DED4CA124322000041

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	TILT, 0.00	U-NII-5	WLAN, 10755-AAC	6025.000, 15	4.91	5.61	36.2

Hardware Setup


Phantom	TSL	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) – 2168	HSL6.5GHz	EX3DV4 – SN7858, 2024-01-09	DAE4ip Sn1846, 2023-11-29

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	119.0 x 119.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	8.5 x 8.5	3.4 x 3.4 x 1.4
Sensor Surface [mm]	3.0	1.4
Graded Grid	N/A	Yes
Grading Ratio	N/A	1.4
MAIA	Y	Y
Surface Detection	Unknown method	VMS + 6p
Scan Method	Measured	Measured

Measurement Results

	Area Scan	Zoom Scan
Date	2024-08-01, 21:47	2024-08-01, 21:20
psSAR1g [W/kg]	0.018	0.118
psSAR10g [W/kg]	0.008	0.022
psAPD (1.0cm2, sq) [W/m2]		1.18
psAPD (4.0cm2, sq) [W/m2]		0.500
Power Drift [dB]	0.0	0.08
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	No correction	No correction



Device Under Test Properties

Model	Dimensions [mm]	IMEI
ME74	220.0 x 80.0 x 45.0	SN:DED4CA124322000041

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE LEFT, 10.00	U-NII-5	WLAN, 10755-AAC	6025.000, 15	4.91	5.61	36.2

Hardware Setup


Phantom	TSL	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) – 2168	HSL6.5GHz	EX3DV4 – SN7858, 2024-01-09	DAE4ip Sn1846, 2023-11-29

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	102.0 x 119.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	8.5 x 8.5	3.4 x 3.4 x 1.4
Sensor Surface [mm]	3.0	1.4
Graded Grid	N/A	Yes
Grading Ratio	N/A	1.4
MAIA	Y	Y
Surface Detection	All points	All points
Scan Method	Measured	Measured

Measurement Results

	Area Scan	Zoom Scan
Date	2024-08-01, 22:43	2024-08-01, 22:47
psSAR1g [W/kg]	0.141	0.140
psSAR10g [W/kg]	0.051	0.042
psAPD (1.0cm2, sq) [W/m2]		1.40
psAPD (4.0cm2, sq) [W/m2]		0.959
Power Drift [dB]	0.00	0.00
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	No correction	No correction



Device Under Test Properties

Model	Dimensions [mm]	IMEI
ME74	220.0 x 80.0 x 45.0	SN:DED4CA124322000041

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE LEFT, 0.00	U-NII-5	WLAN, 10755-AAC	6025.000, 15	4.91	5.61	36.2

Hardware Setup


Phantom	TSL	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) – 2168	HSL6.5GHz	EX3DV4 – SN7858, 2024-01-09	DAE4ip Sn1846, 2023-11-29

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	68.0 x 102.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	8.5 x 8.5	3.4 x 3.4 x 1.4
Sensor Surface [mm]	3.0	1.4
Graded Grid	N/A	Yes
Grading Ratio	N/A	1.4
MAIA	Y	N/A
Surface Detection	All points	All points
Scan Method	Measured	Measured

Measurement Results

	Area Scan	Zoom Scan
Date	2024-08-02, 03:51	2024-08-02, 03:56
psSAR1g [W/kg]	0.463	0.431
psSAR10g [W/kg]	0.147	0.117
psAPD (1.0cm2, sq) [W/m2]		4.31
psAPD (4.0cm2, sq) [W/m2]		2.67
Power Drift [dB]	0.07	-0.03
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	No correction	No correction



Device Under Test Properties

Model	Dimensions [mm]	IMEI
ME74	220.0 x 80.0 x 45.0	SN:DED4CA124322000041

Exposure Conditions

Phantom Section	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor
5G	EDGE LEFT, 2.00	U-NII-8	WLAN, 10755-AAC	6985.0, 207	1.0

Hardware Setup

Phantom	Medium	Probe, Calibration Date	DAE, Calibration Date
mmWave – 1121	Air –	EUmmWV4 – SN9499_F1–55GHz, 2023–11–29	DAE4ip Sn1847, 2024–01–04

Scans Setup

Scan Type	5G Scan
Grid Extents [mm]	60.0 x 60.0
Grid Steps [lambda]	0.0625 x 0.0625
Sensor Surface [mm]	2.0
MAIA	Y

Measurement Results

Scan Type	5G Scan
Date	2024–08–02, 10:48
Avg. Area [cm²]	4.00
psPDn+ [W/m²]	1.60
psPDtot+ [W/m²]	2.13
psPDmod+ [W/m²]	2.29
E _{max} [V/m]	33.4
Power Drift [dB]	–0.01

