

# FCC 47 CFR PART 15 SUBPART C INDUSTRY CANADA RSS-210 ISSUE 8

# **CERTIFICATION TEST REPORT**

**FOR** 

**Wireless Pump** 

MODEL NUMBER: 6050B4150, 6060E4100

FCC ID: 2AAFY6050B4150 IC: 11144A-605B4150


**REPORT NUMBER: 10005005A** 

ISSUE DATE: September 23, 2013

Prepared for
Fluid Handling LLC
8200 N Austin Ave
Morton Grove, IL 60053

Prepared by

UL LLC 333 Pfingsten Rd. Northbrook, IL 60062 TEL: (847) 272-8800



# **Revision History**

	Issue		
Rev.	Date	Revisions	Revised By
	9/23/13	Initial Issue	M.Ferrer

# TABLE OF CONTENTS

<b>1.</b> A	ATTESTATION OF TEST RESULTS	4
2. 7	FEST METHODOLOGY	5
3. I	FACILITIES AND ACCREDITATION	5
4. (	CALIBRATION AND UNCERTAINTY	5
4.1.	. MEASURING INSTRUMENT CALIBRATION	5
4.2.	SAMPLE CALCULATION	5
4.3.	. MEASUREMENT UNCERTAINTY	5
5.5.	DESCRIPTION OF TEST SETUP	7
6. 7	FEST AND MEASUREMENT EQUIPMENT	9
7. 1	FEST RESULTS	10
7	7.1.1. 99%, 20dB BANDWIDTH	10
7.2.	1 11 12 11 11 12 21 11 22 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 2 1 1 1 1 2 1 1 1 1 2 1 1 1 1 2 1 1 1 1 2 1 1 1 1 2 1 1 1 1 1 2 1	
	7.2.1. HARMONICS AND SPURIOUS EMISSIONS ABOVE 1GHz	
7	7.2.2. WORST-CASE BELOW 1 GHz	17
<b>8.</b> A	AC MAINS LINE CONDUCTED EMISSIONS	19
0 6	SETUD DUOTOS	24

DATE: September 23, 2013

IC: 11144A-6050B4150

# 1. ATTESTATION OF TEST RESULTS

**COMPANY NAME:** Fluid Handling

8200 N Austin

Morton Grove, IL 60053

**EUT DESCRIPTION:** Wireless Pump

**MODEL:** 6050B4150, 6050E4100

SERIAL NUMBER: 6

**DATE TESTED:** September 3, 2013 – September 13, 2013

#### APPLICABLE STANDARDS

STANDARD TEST RESULTS

CFR 47 Part 15 Subpart C Part 15.249

Pass

INDUSTRY CANADA RSS-210 Issue 8 Annex A2.9 Pass

INDUSTRY CANADA RSS-GEN Issue 3 Pass

UL Verification Services Inc. tested the above equipment in accordance with the requirements set forth in the above standards. All indications of Pass/Fail in this report are opinions expressed by UL Verification Services Inc. based on interpretations and/or observations of test results. Measurement Uncertainties were not taken into account and are published for informational purposes only. The test results show that the equipment tested is capable of demonstrating compliance with the requirements as documented in this report.

**Note:** The results documented in this report apply only to the tested sample, under the conditions and modes of operation as described herein. This document may not be altered or revised in any way unless done so by UL Verification Services Inc. and all revisions are duly noted in the revisions section. Any alteration of this document not carried out byUL Verification Services Inc. will constitute fraud and shall nullify the document. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, any agency of the Federal Government, or any agency of any government.

Approved & Released For UL CCS By:

Tested By:

BART MUCHA
WiSE STAFF ENGINEER
UL Verification Services Inc.

MICHAEL FERRER WiSE Project Lead

UL Verification Services Inc.

FORM NO: CCSUP4701G

# 2. TEST METHODOLOGY

The tests documented in this report were performed in accordance with ANSI C63.4-2003, FCC CFR 47 Part 15, RSS-GEN Issue 3, and RSS-210 Issue 8.

# 3. FACILITIES AND ACCREDITATION

The test sites and measurement facilities used to collect data are located at 333 Pfingsten Road, Northbrook, IL 60062, USA.

UL NBK is accredited by NVLAP, Laboratory Code 100414-0.

# 4. CALIBRATION AND UNCERTAINTY

#### 4.1. MEASURING INSTRUMENT CALIBRATION

The measuring equipment utilized to perform the tests documented in this report has been calibrated in accordance with the manufacturer's recommendations, and is traceable to recognized national standards.

# 4.2. SAMPLE CALCULATION

Where relevant, the following sample calculation is provided:

Field Strength (dBuV/m) = Measured Voltage (dBuV) + Antenna Factor (dB/m) + Cable Loss (dB) – Preamp Gain (dB) 36.5 dBuV + 18.7 dB/m + 0.6 dB – 26.9 dB = 28.9 dBuV/m

## 4.3. MEASUREMENT UNCERTAINTY

Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the apparatus:

Test	Range	Equipment	Uncertainty k=2
Radiated Emissions	30-200MHz	Bicon 10m Horz	4.27dB
Radiated Emissions	30-200MHz	Bicon 10m Vert	4.28dB
Radiated Emissions	200-1000MHz	LogP 10m Horz	3.33dB
Radiated Emissions	200-1000MHz	LogP 10m Vert	3.39dB
Radiated Emissions	1-6GHz	Horn	5.02dB
Radiated Emissions	6-18GHz	Horn	5.34dB
Radiated Emissions	18-26GHz	Horn	6.60dB
Conducted Ant Port	30MHz-26GHz	Spectrum Analyzer	2.94
RF Power	dB	Power Meter	0.45dB

Uncertainty figures are valid to a confidence level of 95%.

# 5. EQUIPMENT UNDER TEST

# 5.1. DESCRIPTION OF EUT

The EUT is an 915MHz transceiver that is AC powered

The radio module is manufactured by Fluid Handling
The model #'s are the same electrically and are relabeled for the different manufacturer

# 5.2. MAXIMUM OUTPUT E-FIELD STRENGTH

The transmitter has a maximum output peak E-field as follows:

Frequency Range	Mode	Output PK E-field Strength
(MHz)		(dBuV/m)
915	TX	87.59

# 5.3. DESCRIPTION OF AVAILABLE ANTENNAS

The radio utilizes a microstip antenna, with a maximum gain of 0.3 dBi.

#### 5.4. WORST-CASE CONFIGURATION AND MODE

The EUT was set in worst axis as found in preliminary testing.

# 5.5. DESCRIPTION OF TEST SETUP

# **SUPPORT EQUIPMENT**

EUT – Pump Operates at 120VAC 60Hz


## **I/O CABLES**

AC Cable

# **TEST SETUP**

The EUT is programmed for continuous TX mode.

# **SETUP DIAGRAM FOR TESTS**



# **6. TEST AND MEASUREMENT EQUIPMENT**

The following test and measurement equipment was utilized for the tests documented in this report:

Test Equipment List							
Description	Manufacturer	Model	Asset	Cal Date	Cal Due		
EMI Test Receiver	Rohde & Schwarz	ESU	EMC4323	20121227	20131231		
Bicon Antenna	Chase	VBA6106A	EMC4078	20130213	20140228		
Log-P Antenna	Chase	UPA6109	EMC4258	20121015	20131030		
Spectrum Analyzer	Rhode & Schwarz	FSEK	EMC4182	20121226	20131231		
Antenna Array	UL	BOMS	EMC4276	20111227	20131231		
Spectrum Analyzer	Agilient	N9030A	EMC4360	20121226	20131226		
Near Field Antenna	EMCO	-	-	-	-		
EMI Test Receiver	Rohde & Schwarz	ESCI	EMC4328	20121230	20131230		
LISN	Solar	8602-50-TS-50-N	EMC4052	20130115	20140116		
LISN	Solar	8602-50-TS-50-N	EMC4064	20130115	20140116		

# 7. TEST RESULTS

# 7.1.1. 99%, 20dB BANDWIDTH

# **LIMITS**

None; for reporting purposes only.


# **TEST PROCEDURE**


The transmitter output is connected to the spectrum analyzer. The RBW is set to 1% to 3% of the 99 % bandwidth. The VBW is set to 3 times the RBW. The sweep time is coupled. The spectrum analyzer internal 99% bandwidth function is utilized.

# **RESULTS**

Channel	Frequency
	(kHz)
99%	112.44
20dB	88.15

# 99% BANDWIDTH





## 7.2. RADIATED EMISSIONS

#### **TEST PROCEDURE**

ANSI C63.4

## **LIMIT**

IC RSS-210, A2.9 FCC 15.249

Operation within the bands 902–928 MHz, 2400–2483.5 MHz, 5725–5875 MHZ, and 24.0–24.25 GHz.

(a) Except as provided in paragraph (b) of this section, the field strength of emissions from intentional radiators operated within these frequency bands shall comply with the following:

## Limit is 3m

Fundamental frequency	Field strength of fundamental (millivolts/ meter)	Field strength of harmonics (microvolts/ meter)
902–928 MHz	50	500
2400–2483.5 MHz	50	500
5725–5875 MHz	50	500
24.0–24.25 GHz	250	2500

(d) Emissions radiated outside of the specified frequency bands, except for harmonics, shall be attenuated by at least 50 dB below the level of the fundamental or to the general radiated emission limits in § 15.209, whichever is the lesser attenuation.

FORM NO: CCSUP4701G


Frequency (MHz)	Field strength (microvolts/meter)	Measure- ment dis- tance (meters)
0.009-0.490	2400/F(kHz)	300
0.490-1.705	24000/F(kHz)	30
1.705-30.0	30	30
30-88	100 **	3
88-216	150 **	3
216-960	200 **	3
Above 960	500	3

<sup>\*\*</sup> Except as provided in paragraph (g), fundamental emissions from intentional radiators operating under this section shall not be located in the frequency bands 54–72 MHz, 76–88 MHz, 174–216 MHz or 470–806 MHz. However, operation within these frequency bands is permitted under other sections of this part, e.g., §§15.231 and 15.241.

# **RESULTS**


Fluid Handlii	ng										
ACT4 Pump											
Tx Sample #6	5										
120Vac60Hz											
	Meter		UPA6109 SN1060 EMC4258	3 meter with LogP	Corrected Reading	CFR 47 Part 15					
Test	Reading		3M	Emissions	dB(uVolts/	Class B 3m	Margin	Azimuth	Height		
Frequency	(dBuV)	Detector	(dB/m)	Ca (dB)	meter)	(dBuV/m)	(dB)	[Degs]	[cm]	Polarity	Notes
914.865385	54.49	QP	23.1	10	87.59	94	-6.41	23	158	Horz	
914.865385	47.92	QP	23.1	10	81.02	94	-12.98	130	102	Vert	
914.865385	50.18	QP	23.1	10	83.28	94	-10.72	99	121	Vert	:
914.865385	48.81	QP	23.1	10	81.91	94	-12.09	326	104	Horz	
914.865385	51.61	QP	23.1	10	84.71	94	-9.29	345	102	Horz	
914.865385	52	QP	23.1	10	85.1	94	-8.9	0	103	Horz	:
Notes:											
1 - Y-Axis											
2 - X-Axis											
3 - Z-Axis											
QP - Quasi-P	eak detect	tor									

# 7.2.1. HARMONICS AND SPURIOUS EMISSIONS ABOVE 1GHz



# 7.2.2. WORST-CASE BELOW 1 GHz

# **SPURIOUS EMISSIONS 30 TO 1000 MHz**



DATE: September 23, 2013 IC: 11144A-6050B4150

Manufacturer:Fluid Handling Model#ACT4 Pump Mode:Tx Sample #6 Voltage:120Vac60Hz RED:Horizontal, GREEN:Vertical

Trace Markers Test No. Frequency [MHz]	Meter :	Fransducer Factor [dB]	Gain/Loss Factor [dB]		d Limit:1 dB(uVolts/		2	3	4
Bicon Horizont	a 30 - 200MHz						 _		
1 30.6797	31.47dBuV PK	17.6	-30.1	18.97	_	-	39.08	29.55	-
	Height:400 Ho:	rz	Margin [dB]		-	-	-20.11	-10.58	-
2 197.3663	31.82dBuV PK	16	-28.8	19.02	_	-	43.52	33.07	-
	Height:99 Hor:	Z	Margin [dB]		_	-	-24.5	-14.05	_
Bicon Vertical	30 - 200MHz						_		
3 66.1069	51.86dBuV PK	6.2	-30	28.06	_	-	39.08	29.55	_
	Height:249 Ve	rt	Margin [dB]		_	-	-11.02	-1.49	_
4 85.6472	45.76dBuV PK	8.2	-29.9	24.06	_	-	39.08	29.55	-
	Height:249 Ve	rt	Margin [dB]		-	-	-15.02	-5.49	-

LIMIT 3: FCC Part 15 Class A 10m LIMIT 4: FCC Part 15 Class B 10m

Manufacturer:Fluid Handling Model#ACT4 Pump Mode:Tx Sample #6 Voltage:120Vac60Hz RED:Horizontal, GREEN:Vertical

Radiated Emission Data

Test Frequency [MHz]	Meter Reading	Transducer Factor [dB]	Gain/Loss Factor [dB]	Corrected ReadingdB	Limit:1 (uVolts/mete	2	3	4	5
Bicon Hori	izonta 30 - 20	========= OMHz							
66.0423	46.7dBuV QP	6.2	-30	22.9	_	-	39.08	29.55	_
Azimuth: 3	354 Height:25	2 Vert	Margin	(dB):	-	-	-16.18	-6.65	-
85.7674	41.29dBuV QP	8.3	-29.9	19.69	_	_	39.08	29.55	_
Azimuth: 1	14 Height:14	7 Vert	Margin	(dB):	_	_	-19.39	-9.86	_

LIMIT 3: FCC Part 15 Class A 10m LIMIT 4: FCC Part 15 Class B 10m

PK - Peak detector QP - Quasi-Peak detector

# 8. AC MAINS LINE CONDUCTED EMISSIONS

# **LIMITS**

§15.207 (a) IC RSS-GEN, Section 7.2.2

Frequency of emission	Conducted Limit (dBμV)					
(MHz)	Quasi-peak	Average				
0.15 to 0.50	66 to 56*	56 to 46*				
0.50 to 5	56	46				
5 to 30 60 50						
* Decreases with the logarithm of the frequency.						

#### **TEST PROCEDURE**

**ANSI C63.4** 

# **RESULTS**

No non-compliance noted:

# CC ID: 2AAFY605B4150 IC: 11144A-6050B4150

# **6 WORST EMISSIONS**

Manufacturer:Fluid Handling Model#Pump Mode:TX Valtage:120V 60Hz

Voltage:120V 60Hz Red:Line Green:Neutral

Trace Mar Tes No. Freque	t Meter ency Reading	Factor [dB]		Reading	g (dB(uVol	ts))	2	3	4
	====								
Line - L1 1 .18026	.15 - 1MHz 42.25dBuV		12.2	54.55	-	-	64.47	54.47	-
2 .23918	36dBuV PK	.1	Margin [dB]	47.4	<u> </u>	-	-9.92 62.12		_
3 .30267	31.98dBuV	PK .1	Margin [dB]	42.98	-	-	60.17		-
4 .36149	29.56dBuV	PK .1	Margin [dB]	40.46	_	-	58.69		-
Line - L2	.15 - 1MHz		Margin [dB]		- 	-		-8.23	_
5 .1793	41.45dBuV	PK .1	12.3 Margin [dB]	53.85	-	-	64.52 -10.67	54.52 67	-
6 .24003	35.69dBuV	PK .1	11.3	47.09	-	-	62.1	52.1 -5.01	-
7 .30034	32.11dBuV	PK .1	Margin [dB] 10.9	43.11	-	-	60.23		_
8 .36085	27.3dBuV F	PK .1	Margin [dB]	38.2	_	_	-17.12 58.71	-7.12 48.71	_
	CISPR 22/11 Group		Margin [dB]		-	-		-10.51	-
Frequency [MHz]	k Data Meter Tr	[dB] [dB	tor Readin	ıg (dB (uVc			3	4	5
=====									
.17996	.15 - 1MHz 40.25dBuV QP .			-	-	64.49		-	-
.23975	35.28dBuV QP .	Margin ( 1 11.3	(dB): 46.68	_	_	-11.94 62.1	-1.94 52.1	_	_
20174	20 240-11 00	Margin (		-	-		-5.42	_	-
.30174	30.3dBuV QP .	1 10.9 Margin (	41.3 (dB):	_	-	60.19 -18.89	50.19 -8.89	_	_
.36101	27.37dBuV QP .	1 10.8 Margin (	38.27	_	- -	58.71 -20.44	48.71 -10.44	_	-
	.15 - 1MHz	_							
.17989	39.79dBuV QP .	1 12.2 Margin (	52.09	_	_	64.49 -12.4	54.49 -2.4	_	_
.24007	34.24dBuV QP .		45.64	-	-	62.09	52.09	-	-
.30038	29.37dBuV QP .	Margin ( 1 10.9	(dB): 40.37	-	-	-16.45 60.23	-6.45 50.23	-	_
. 50050	29.3/abuv QP .	Margin (		-	-		-9.86	-	_
.36035	24.66dBuV QP .		35.56	_	-	58.72		_	-
		Margin (	(ab):	-	_	-23.16	-13.16	-	_

NOTE: "+" - Indicates an emission level in excess of the applicable limit (s).

QP - Quasi-Peak detector

DATE: September 23, 2013

DATE: September 23, 2013 IC: 11144A-6050B4150

Manufacturer:Fluid Handling Model#Pump Mode:TX Voltage:120V 60Hz Red:Line Green:Neutral


Average Da Test Frequency [MHz]	Meter	Transdı Facto [dB]	or Factor	s Correct Reading			2	3	4	5
Line - L1	.15 - 1MHz									
.17996	20.56dBuV A	Av .1	12.2	32.86	-	-	64.49	54.49	-	-
			Margin (dB):		-	-	-31.63	-21.63	-	_
.23975	17.17dBuV A	Av .1	11.3	28.57	_	-	62.1	52.1	-	-
			Margin (dB):		-	-	-33.53	-23.53	-	_
.30174	15.25dBuV A	Av .1	10.9	26.25	-	-	60.19	50.19	-	-
			Margin (dB):		-	-	-33.94	-23.94	-	-
.36101	15.19dBuV A	Av .1	10.8	26.09	-	-	58.71	48.71	-	-
			Margin (dB):		-	-	-32.62	-22.62	-	-
Line - L2	.15 - 1MHz									
.17989	20.72dBuV A	Av .1	12.2	33.02	-	-	64.49	54.49	-	-
			Margin (dB):		-	-	-31.47		-	-
.24007	18.17dBuV A	Av .1	11.3	29.57	-	-	62.09	52.09	-	-
			Margin (dB):		-	-	-32.52	-22.52	-	-
.30038	17.45dBuV A	Av .1	10.9	28.45	-	-	60.23	50.23	-	-
			Margin (dB):		-	-	-31.78	-21.78	-	-
.36035	17.14dBuV A	Av .1	10.8	28.04	-	-	58.72		-	-
			Margin (dB):		-	-	-30.68	-20.68	-	-

NOTE: "+" - Indicates an emission level in excess of the applicable limit (s).

Av - average detection

LIMIT 3: CISPR 22/11 Group 1 Class B QP LIMIT 4: CISPR 22/11 Group 1 Class B AV

# **LINE 1 RESULTS**



DATE: September 23, 2013

IC: 11144A-6050B4150

# **LINE 2 RESULTS**

