

RF Test Report

Project Number: 5251870 Offer Number: SUW-202411007378
Report Number: 5251870EMC03 Revision Level: 1
Client: Orpyx Medical Technologies Inc.

Equipment Under Test: Orpyx® Sensory Insoles

Model Number: SI000010

HVIN: SI000011 and SI000012

FCC ID: 2AAH8-SI000011 and 2AAH8-SI000012

IC: 10789A-SI000011 and 10789A-SI000012

Applicable Standards: FCC Part 15 Subpart C, § 15.247

RSS-247, Issue 3, August 2023

RSS-GEN, Issue 5, February 2021, Amendment 2

ANSI C63.10:2013

Report issued on: 11 June 2025

Test Result: Compliant



FOR THE SCOPE OF ACCREDITATION UNDER CERTIFICATE NUMBER: 3212.01

This report must not be used by the client to claim product certification, approval, or endorsement by A2LA, NIST, or any agency of the Federal Government.

Prepared by:

Martin Taylor, RF/EMC Project Engineer

Reviewed by:

Sean Vick, Advanced EMC Engineer

Remarks: This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. And for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 30 days only.

Table of Contents

1	SUMMARY OF TEST RESULTS	4
1.1	MODIFICATIONS REQUIRED FOR COMPLIANCE	4
2	GENERAL INFORMATION	5
2.1	CLIENT INFORMATION	5
2.2	TEST LABORATORY	5
2.3	GENERAL INFORMATION OF EUT	5
2.4	OPERATING MODES AND CONDITIONS	6
2.5	EUT CONNECTION BLOCK DIAGRAM – CONDUCTED MEASUREMENTS	6
2.6	EUT CONNECTION BLOCK DIAGRAM – RADIATED MEASUREMENTS	6
2.7	SYSTEM CONFIGURATIONS	6
3	BANDWIDTH	7
3.1	TEST RESULT	7
3.2	TEST METHODS	7
3.3	TEST SITE	7
3.4	TEST EQUIPMENT	8
3.5	TEST DATA - LEFT INSOLE	9
3.6	TEST DATA - RIGHT INSOLE	11
4	OUTPUT POWER	13
4.1	TEST RESULT	13
4.2	TEST METHOD	13
4.3	TEST SITE	13
4.4	TEST EQUIPMENT	14
4.5	TEST DATA – LEFT INSOLE	15
4.6	TEST DATA – RIGHT INSOLE	16
5	POWER SPECTRAL DENSITY	17
5.1	TEST RESULT	17
5.2	TEST METHOD	17
5.3	TEST SITE	17
5.4	TEST EQUIPMENT	18
5.5	TEST DATA – LEFT INSOLE	19
5.6	TEST DATA – RIGHT INSOLE	20
6	CONDUCTED SPURIOUS EMISSIONS / BAND EDGE	21
6.1	TEST RESULT	21
6.2	TEST METHOD	21
6.3	TEST SITE	21
6.4	TEST EQUIPMENT	22
6.5	TEST DATA – LEFT INSOLE	23
6.6	TEST DATA – RIGHT INSOLE	25
7	EMISSIONS IN RESTRICTED FREQUENCY BANDS	27
7.1	TEST RESULT	27
7.2	TEST METHOD	27
7.3	TEST SITE	27
7.4	TEST EQUIPMENT	28
7.5	TEST DATA – LEFT INSOLE	30
7.6	TEST DATA – RIGHT INSOLE	45
8	BAND EDGE EMISSIONS IN RESTRICTED FREQUENCY BANDS	56



8.1	TEST RESULT.....	56
8.2	TEST METHOD.....	56
8.3	TEST SITE	56
8.4	TEST EQUIPMENT	57
8.5	TEST DATA – LEFT INSOLE.....	58
8.6	TEST DATA – RIGHT INSOLE.....	60
9	MEASUREMENT UNCERTAINTY.....	62
10	REVISION HISTORY.....	63

1 Summary of Test Results

Test Description	Test Specification		Test Result
Bandwidth	15.247(a)(2)	RSS-247 S5.2 (a) RSS-GEN S6.7	Compliant
Output Power	15.247(b)(3)	RSS-247 S5.4 (d)	Compliant
Power Spectral Density	15.247(e)	RSS-247 S5.2 (b)	Compliant
Conducted Spurious Emissions / Band Edge	15.247(d)	RSS-247 S5.5	Compliant
Emissions in Restricted Frequency Bands	15.247(d) 15.205, 15.209	RSS-247 S5.5 RSS-GEN S8.9, S8.10	Compliant
Band Edge Emissions in Restricted Frequency Bands	15.205, 15.209	RSS-GEN S8.9, S8.10	Compliant
AC Powerline Conducted Emissions	15.207	RSS-GEN S8.8	N/A ⁽¹⁾
Antenna Requirement	15.203	RSS-GEN S6.8	Compliant ⁽²⁾

(1) The device does not connect to the AC Mains.

(2) The device uses a chip antenna which cannot be replaced by the end user.

1.1 Modifications Required for Compliance

None.

2 General Information

2.1 Client Information

Company Name: Orpyx Medical Technologies Inc.
Address: Suite 205, 1240 20th Avenue SE
City, State, Zip, Country: Calgary, Alberta T2G 1M8 Canada

2.2 Test Laboratory

Name: SGS North America, Inc.
Address: 620 Old Peachtree Road NW, Suite 100
City, State, Zip, Country: Suwanee, GA 30024, USA

Accrediting Body: A2LA
Type of lab: Testing Laboratory
Certificate Number: 3212.01
CAB ID: US0186

2.3 General Information of EUT

Equipment Under Test: Orpyx® Sensory Insoles
Model Number: SI000010 (both left and right insoles)
 HVIN: SI000011 (right insole)
 SI000012 (left insole)
Serial Numbers: 2222-5017 & 2222-4021 (left & right Conducted Samples)
 2222-5012 & 2222-5003 (left & right Radiated Samples)
FCC ID: 2AAH8-SI000011 (right insole)
 2AAH8-SI000012 (left insole)
IC: 10789A-SI000011 (right insole)
 10789A-SI000012 (left insole)

Frequency Range: 2402 – 2480 MHz
Data Modes: Bluetooth Low Energy (BLE) – GFSK – 1Mbps & 2Mbps
Antenna Type/Gain*: Chip Antenna (4.5dBi gain)

Rated Voltage: 3.7Vdc Internal Battery
Test Voltage: 3.7Vdc Internal Battery

Sample Received Date: 17 December 2024
Dates of testing: 24 - 26 December 2024 and 5 - 10 June 2025


*Data was not measured by SGS laboratory and therefore SGS is not responsible for accuracy. Data obtained via customer, specification sheet, previous filing or other.

2.4 Operating Modes and Conditions


The Orpyx® Sensory Insoles were powered by internal non-rechargeable batteries. The client provided a laptop with a software application called BLE Manager. First a normal BLE connection was established between the EUT and the laptop, and then the BLE Manager application was used to initiate transmitter test modes, which allowed the BLE radio to be configured as follows:

- 1) selecting low, middle and high BLE channels;
- 2) selecting the data rates as used in normal operation, but with high duty cycle;
- 3) setting the power level. [The maximum power setting of +8dBm was used for all tests.]

2.5 EUT Connection Block Diagram – Conducted Measurements



2.6 EUT Connection Block Diagram – Radiated Measurements



2.7 System Configurations

Device Reference	Manufacturer	Description	Model Number	Serial Number
A & B	Orpyx Medical Technologies Inc.	Orpyx® Sensory Insoles (EUT) (left & right)	SI000010	2222-5017 & 2222-4021 2222-5012 & 2222-5003
C	Lenovo	Laptop PC	E15	PF-2T7FZG

3 Bandwidth

3.1 Test Result

Test Description	Test Specification		Test Result
DTS Bandwidth (6dB)	15.247(a)(2)	RSS-247 S5.2 (a)	Compliant
Occupied Bandwidth (99%)	2.1049	RSS-GEN S6.7	Reported

3.2 Test Methods

The DTS 6dB bandwidth measurements were performed using the procedure from ANSI C63.10 clause 11.8.1, and the 99% occupied bandwidth measurements were performed using the procedure from ANSI C63.10 clause 6.9.3. These procedures are referenced in KDB 558074 D01 15.247 Meas Guidance v05r02.

Limit

The minimum 6dB bandwidth shall be at least 500 kHz.

3.3 Test Site

SGS EMC Laboratory, Suwanee, GA

Left Insole

Environmental Conditions

Temperature: 24.13 °C
Relative Humidity: 49.5 %
Atmospheric Pressure: 98.34 kPa

Right Insole

Environmental Conditions

Temperature: 23.39 °C
Relative Humidity: 19.8 %
Atmospheric Pressure: 99.35 kPa

3.4 Test Equipment

Left Insole

Test End Date: 6-Jun-2025

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	3-Apr-2025	3-Apr-2026
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	4-Mar-2025	4-Mar-2026

Right Insole

Test End Date: 24-Dec-2024

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	20-Mar-2024	20-Mar-2025
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	3-Jan-2024	3-Jan-2025

Software Profile:

TSTPASS Version: 2.0 (2024.12.23_11.05.24)


3.5 Test Data - Left Insole

3.5.1 Test Data – DTS Bandwidth (6dB)


Mode	TX Type	Frequency (MHz)	ANT	6dB Bandwidth (MHz)		Verdict
				Result	Limit	
1M	SISO	2402	1	0.699	≥ 0.5	Pass
		2440	1	0.716	≥ 0.5	Pass
		2480	1	0.710	≥ 0.5	Pass
2M	SISO	2402	1	1.176	≥ 0.5	Pass
		2440	1	1.170	≥ 0.5	Pass
		2480	1	1.169	≥ 0.5	Pass

Representative Plot(s)

1M_MCH_2440MHz_Ant1_NTNV



2M_MCH_2440MHz_Ant1_NTNV




3.5.2 Test Data – 99% Occupied Bandwidth


Mode	TX Type	Frequency (MHz)	ANT	99% Occupied Bandwidth (MHz)		Verdict
				Result	Limit	
1M	SISO	2402	1	1.055	/	Pass
		2440	1	1.067	/	Pass
		2480	1	1.064	/	Pass
2M	SISO	2402	1	2.025	/	Pass
		2440	1	2.066	/	Pass
		2480	1	2.062	/	Pass

Representative Plot(s)

1M MCH 2440MHz Ant1 NTV



2M MCH 2440MHz Ant1 NTV




3.6 Test Data - Right Insole

3.6.1 Test Data – DTS Bandwidth (6dB)


Mode	TX Type	Frequency (MHz)	ANT	6dB Bandwidth (MHz)		Verdict
				Result	Limit	
1M	SISO	2402	1	0.708	≥ 0.5	Pass
		2440	1	0.712	≥ 0.5	Pass
		2480	1	0.717	≥ 0.5	Pass
2M	SISO	2402	1	1.144	≥ 0.5	Pass
		2440	1	1.155	≥ 0.5	Pass
		2480	1	1.163	≥ 0.5	Pass

Representative Plot(s)

1M HCH 2480MHz_Ant1_NTNV



2M LCH 2402MHz_Ant1_NTNV




3.6.2 Test Data – 99% Occupied Bandwidth


Mode	TX Type	Frequency (MHz)	ANT	99% Occupied Bandwidth (MHz)		Verdict
				Result	Limit	
1M	SISO	2402	1	1.052	/	Pass
		2440	1	1.061	/	Pass
		2480	1	1.069	/	Pass
2M	SISO	2402	1	2.031	/	Pass
		2440	1	2.070	/	Pass
		2480	1	2.054	/	Pass

Representative Plot(s)

1M HCH 2480MHz Ant1 NTN



2M LCH 2402MHz Ant1 NTN



4 Output Power

4.1 Test Result

Test Description	Test Specification		Test Result
Fundamental Emission Output Power	15.247(b)(3)	RSS-247 S5.4 (d)	Compliant

4.2 Test Method

Fundamental maximum peak conducted output power measurements were performed using the method described in ANSI C63.10:2013 clause 11.9.1.1. This procedure is referenced in KDB 558074 D01 15.247 Meas Guidance v05r02.

Limit

For systems using digital modulation in the 902-928 MHz, 2400-2483.5 MHz, and 5725-5850 MHz bands: 1 Watt. For using antennas with greater than 6dBi of gain, the limit is reduced in dB by the amount the gain exceeds 6dBi (e.g. for a 7.4dBi antenna, the limit is reduced from 30dBm to 28.6dBm). Also, the e.i.r.p. shall not exceed 4 Watts (36 dBm) based on RSS-247 S5.4 (d).

4.3 Test Site

SGS EMC Laboratory, Suwanee, GA

Left Insole

Environmental Conditions

Temperature: 24.13 °C
Relative Humidity: 49.5 %
Atmospheric Pressure: 98.34 kPa

Right Insole

Environmental Conditions

Temperature: 23.39 °C
Relative Humidity: 19.8 %
Atmospheric Pressure: 99.35 kPa

4.4 Test Equipment

Left Insole

Test End Date: 6-Jun-2025

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	3-Apr-2025	3-Apr-2026
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	4-Mar-2025	4-Mar-2026

Right Insole

Test End Date: 24-Dec-2024

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	20-Mar-2024	20-Mar-2025
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	3-Jan-2024	3-Jan-2025

Software Profile:

TSTPASS Version: 2.0 (2024.12.23_11.05.24)


4.5 Test Data – Left Insole

Mode	TX Type	Frequency (MHz)	Maximum Peak Conducted Output Power (dBm)		Verdict
			ANT1	Limit	
1M	SISO	2402	5.83	<=30	Pass
		2440	5.65	<=30	Pass
		2480	5.71	<=30	Pass
2M	SISO	2402	5.87	<=30	Pass
		2440	5.62	<=30	Pass
		2480	5.69	<=30	Pass


Note1: Antenna Gain: Ant1: 4.50dBi;

Representative Plot(s)

1M_MCH_2440MHz_Ant1_NTNV



2M_MCH_2440MHz_Ant1_NTNV




4.6 Test Data – Right Insole

Mode	TX Type	Frequency (MHz)	Maximum Peak Conducted Output Power (dBm)		Verdict
			ANT1	Limit	
1M	SISO	2402	3.53	<=30	Pass
		2440	3.34	<=30	Pass
		2480	3.58	<=30	Pass
2M	SISO	2402	3.52	<=30	Pass
		2440	3.33	<=30	Pass
		2480	3.61	<=30	Pass


Note1: Antenna Gain: Ant1: 4.50dBi;

Representative Plot(s)

1M HCH 2480MHz Ant1 NTN



2M LCH 2402MHz Ant1 NTN



5 Power Spectral Density

5.1 Test Result

Test Description	Test Specification		Test Result
Power Spectral Density	15.247(e)	RSS-247 S5.2 (b)	Compliant

5.2 Test Method

Peak power spectral density measurements were performed using the procedures from ANSI C63.10: 2013 clause 11.10.2. These procedures are referenced in KDB 558074 D01 15.247 Meas Guidance v05r02.

Limit

The maximum limit is 8 dBm / 3 kHz.

5.3 Test Site

SGS EMC Laboratory, Suwanee, GA

Left Insole

Environmental Conditions

Temperature: 24.13 °C
Relative Humidity: 49.5 %
Atmospheric Pressure: 98.34 kPa

Right Insole

Environmental Conditions

Temperature: 23.39 °C
Relative Humidity: 19.8 %
Atmospheric Pressure: 99.35 kPa

5.4 Test Equipment

Left Insole

Test End Date: 6-Jun-2025

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	3-Apr-2025	3-Apr-2026
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	4-Mar-2025	4-Mar-2026

Right Insole

Test End Date: 24-Dec-2024

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	20-Mar-2024	20-Mar-2025
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	3-Jan-2024	3-Jan-2025

Software Profile:

TSTPASS Version: 2.0 (2024.12.23_11.05.24)


5.5 Test Data – Left Insole

Mode	TX Type	Frequency (MHz)	Maximum PSD (dBm/3kHz)		Verdict
			ANT1	Limit	
1M	SISO	2402	-8.55	<=8	Pass
		2440	-7.24	<=8	Pass
		2480	-7.32	<=8	Pass
2M	SISO	2402	-11.02	<=8	Pass
		2440	-10.27	<=8	Pass
		2480	-10.05	<=8	Pass


Note1: Antenna Gain: Ant1: 4.50dBi;

Representative Plot(s)

1M_MCH_2440MHz_Ant1_NTNV



2M_MCH_2440MHz_Ant1_NTNV




5.6 Test Data – Right Insole

Mode	TX Type	Frequency (MHz)	Maximum PSD (dBm/3kHz)		Verdict
			ANT1	Limit	
1M	SISO	2402	-9.09	<=8	Pass
		2440	-10.23	<=8	Pass
		2480	-10.04	<=8	Pass
2M	SISO	2402	-12.41	<=8	Pass
		2440	-12.72	<=8	Pass
		2480	-12.38	<=8	Pass


Note1: Antenna Gain: Ant1: 4.50dBi;

Representative Plot(s)

1M_HCH_2480MHz_Ant1_NTNV



2M_LCH_2402MHz_Ant1_NTNV



6 Conducted Spurious Emissions / Band Edge

6.1 Test Result

Test Description	Test Specification		Test Result
Conducted Spurious and Band Edge Emissions	15.247(d)	RSS-247 S5.5	Compliant

6.2 Test Method

Conducted band edge and spurious band emissions in non-restricted frequency bands were measured using the method defined in ANSI C63.10 clause 11.11. This procedure is referenced in KDB 558074 D01 15.247 Meas Guidance v05r02.

Limit

Because the maximum peak conducted output power was used to determine compliance with the output power limits, the limit in any 100 kHz band outside of the authorized band is 20 dB below the maximum in-band peak level.

6.3 Test Site

SGS EMC Laboratory, Suwanee, GA

Left Insole

Environmental Conditions

Temperature: 24.13 °C
Relative Humidity: 49.5 %
Atmospheric Pressure: 98.34 kPa

Right Insole

Environmental Conditions

Temperature: 23.39 °C
Relative Humidity: 19.8 %
Atmospheric Pressure: 99.35 kPa

6.4 Test Equipment

Left Insole

Test End Date: 6-Jun-2025

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	3-Apr-2025	3-Apr-2026
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	4-Mar-2025	4-Mar-2026

Right Insole

Test End Date: 24-Dec-2024

Tester: SGM

Equipment	Manufacturer	Model	Asset Number	Cal Date	Cal Due Date
RF CABLE SMA TO SMA, 0.01-40GHZ	TELEDYNE STORM MICROWAVE	084-0505-059	20108	20-Mar-2024	20-Mar-2025
TSTPASS SWITCHBOX	TSTPASS	SB2	23009	8-Apr-2024	8-Apr-2025
SIGNAL ANALYZER (TS8997)	ROHDE & SCHWARZ	FSV30	B085749	3-Jan-2024	3-Jan-2025


Software Profile:

TSTPASS Version: 2.0 (2024.12.23_11.05.24)


6.5 Test Data – Left Insole

6.5.1 DTS Band Edge


BLE 1M - Lower band edge




BLE 1M - Upper band edge



BLE 2M - Lower band edge




BLE 2M - Upper band edge




6.6 Test Data – Right Insole

6.6.1 DTS Band Edge


BLE 1M - Lower band edge



BLE 1M - Upper band edge



BLE 2M - Lower band edge



BLE 2M - Upper band edge

