

Date: 2025-07-13

01_NFC_ASK_Back_0mm

Communication System: CW; Frequency: 13.600 MHz; Duty Cycle: 1:1

Medium: HSL_13.0MHz_250713 Medium parameters used: $f=13.600$ MHz; $\sigma=0.728$ S/m; $\epsilon_r=54.5$

Ambient Temperature: 23.3°C; Liquid Temperature: 22.7°C

DASY6 Configuration:

- Probe: EX3DV4 - SN7706; ConvF(16.06, 16.97, 16.03); Calibrated: 2025-05-22
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1691; Calibrated: 2025-06-04
- Phantom: ELI V8.0 (20deg probe tilt); Serial: 2151; Section: Flat
- Measurement Software: 16.2.4.2524
- UID: CW, 0--

Area Scan (120.0 mm x 210.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.023 W/kg; SAR (10g) = 0.015 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 4.3 mm x 4.3 mm x 1.4 mm

Power Drift = 0.01 dB

SAR (1g) = 0.028 W/kg; SAR (10g) = 0.010 W/kg

Smallest distance from peaks to all points 3 dB below = 5.2 mm

Ratio of SAR at M2 to SAR at M1 = 60.0 %

