




Model: [REDACTED]
Single Station Multicriteria Smoke Alarm



WARNING

Please see user manual for important information on maintenance and battery life (B19380 Rev1). Constant use at high or low temperature or high humidity may reduce battery life. Use only batteries specified, the use of other batteries may have a detrimental effect on alarm operation. Maintenance: Clean Alarm monthly by gently vacuuming the openings in the exterior of the Alarm.

Standby: No Beep or flash
Low Battery: 1 beep + 1 yellow flash every 48 sec
Alarm: 3 long beeps, repeating with flashing red LED
End Of Life: 3 beeps with 3 yellow flashes
Alarm Silence: 1 red flash every 8 secs
Sensitivity: = 1.82% - 2.92% OBS/ft
Conforms to: ANSI/UL 217 8th ed
Certified to: ULC-S531 3rd ed.
For Servicing, return to:

EN FRANÇAIS

SL

E234156

SL-P

W3181-01

2351

© 2023 LUNA PRODS

10011987 X11 RF

MODULE SMHT01

TX ID: 080014E

SN:

15B40E-0800014E

WESTCOTT®

