

RADIOFREQUENCY RADIATION EXPOSURE EVALUATION: MOBILE DEVICES

REPORT NUMBER: M2004026-4

TEST STANDARD: 47 CFR PART 2.1091

CLIENT: RUBICON GLOBAL PTY. LTD

DEVICE: FERIT NODE - P400

FERIT SOLAR NODE - P400

MODEL: VAR2 - 81338; VAR4 - 81343

DATE OF ISSUE: 18 AUGUST 2020

EMC Technologies Pty Ltd reports apply only to the specific samples tested under stated test conditions. It is the manufacturer's responsibility to assure that additional production units of this model are manufactured with identical electrical and mechanical components. EMC Technologies Pty Ltd shall have no liability for any deductions, inferences or generalisations drawn by the client or others from EMC Technologies Pty Ltd issued reports. This report shall not be used to claim, constitute or imply product endorsement by EMC Technologies Pty Ltd.



Accreditation No.5292

Accredited for compliance with ISO/IEC 17020 – Inspection. NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports.

This document shall not be reproduced except in full.

REVISION TABLE

Version	Sec/Para Changed	Change Made	Date
1		Initial issue of document	18/08/2020

CONTENTS

1	Introduction.....	5
1.1	Laboratory Overview.....	5
1.2	Test Laboratory/Accreditations	5
2	Device Details	5
3	Limits for Maximum Permissible Exposure (MPE), §1.1310.....	6
4	Uncertainty	6
5	Assumptions in this Assessment	6
6	Evaluation Result.....	7
7	Conclusion.....	7

RADIOFREQUENCY RADIATION EXPOSURE EVALUATION

Device: FERIT NODE - P400; FERIT SOLAR NODE - P400
Model Number: 81338, 81343
Serial Number: N/A

Manufacturer: Rubicon Global Pty. Ltd.

Tested for: Rubicon Global Pty. Ltd
Address: 1 Cato Street, Hawthorn East, 3123
Phone Number: +61 3 9832 3031
Contact: Paul Spooner
Email: Paul.spooner@rubiconwater.com


Standards: **47 CFR Part 2.1091**
"Radiofrequency radiation exposure evaluation: mobile devices"
47 CFR 1.1310
"Radiofrequency radiation exposure limits"
KDB 447498 D01 General RF Exposure Guidance v06
"RF exposure procedures and equipment authorization policies for mobile and portable devices".

Result: Based on an assessment of the documentation provided the FERIT NODE - P400 and FERIT SOLAR NODE – P400, models 81338, 81343, comply with the RF exposure requirements of 47 CFR Part 2.1091, however an exclusion zone of 21 cm in front of the radiating elements applies, elsewhere the exposure level was below the MPE limits.. Refer to Report M2004026-4 for full details

Assessment Date: 9th June 2020

Issue Date: 18 August 2020

Assessment Engineer: 
Peter Jakubiec

Authorised Signatory: 
Chris Zombolas
Managing Director

Issued by: EMC Technologies Pty. Ltd.,
176 Harrick Road, Keilor Park, VIC, 3042, Australia.

Phone: +61 3 9365 1000

E-mail: emc-general@emctech.com.au

Web: www.emctech.com.au



Accreditation No.5292

This document shall not be reproduced except in full.

1 INTRODUCTION

This report is intended to demonstrate compliance of the FERIT NODE - P400 (Model 81338) and FERIT SOLAR NODE - P400, (Model 81343) with the RF exposure requirements of 47 CFR Part 2.1091. Evaluation was performed in accordance with FCC KDB 447498 D01.

The product sample was provided by the Client. The conclusion herein is based on the information provided by the client.

1.1 Laboratory Overview

EMC Technologies Pty. Ltd. is an independently owned Australian company that is NATA accredited to ISO 17025 for both testing and calibration to 17025 and ISO 17020 for Inspection. – **Accreditation Number 5292.**

1.2 Test Laboratory/Accreditations

Measurements were performed at EMC Technologies' laboratory in Keilor Park, Victoria Australia.

Table 1-1: Accreditations for Conformity Assessment

Country/Region	Body	
Australia/New Zealand	NATA	Accreditation Number: 5292
Europe	European Union	Notified Body Number: 0819
USA	FCC	Designation Number: AU0001 (Melb)
Canada	ISED Canada	Company Number: 3569B(Melb)
Japan	VCCI	Company Number: 785
Taiwan	BSMI	Lab Code SL2-IN-E-5001R

2 DEVICE DETAILS

(Information supplied by the Client)

FERIT NODE – P400 Telemetry node that can burst sensor data over a 900MHz network Multiple IO and comms (RS485/I2C)

FERIT NODE – LORA is Telemetry node that can burst sensor data over a LoRa network Multiple IO and comms (RS485/I2C)

Manufacturer: Rubicon Global Pty. Ltd.
Test Sample(s): Ferit Node – P400; Ferit Solar Node – P400
Model Number(s): 81338, 81343
Serial Number: Prototype

Both Ferit Node – P400 (Model no. 81338) and Ferit Solar Node – P400 (Model no. 81342) have the same combination of Transmitters installed in them. Each variant model has the following transmitters installed (Transmit parameters were provided by the customer and are shown below):

Transmit parameters were provided by the customer and are shown below:

Table 2-1: Transmitter Parameters

Wireless Interface 1:	MDLC Microhard P400
Supported Frequencies:	915MHz
RF Output Power level:	30 dBm
Antenna Type Main & Div.(Rx)	Monopole Omni-directional.
Max. Antenna Gain:	5dBi

Wireless Interface 2:	Bluetooth Transceiver Nrf52840
Supported Frequencies:	2402MHz to 2480MHz
RF Output Power level:	0 dBm
Antenna Type Main & Div.(Rx)	PCB 2.4GHz-Inverted F Antenna
Max. Antenna Gain:	3dBi

3 LIMITS FOR MAXIMUM PERMISSIBLE EXPOSURE (MPE), § 1.1310

Table 3-1: Occupational and General Public MPE Limits

Frequency range (MHz)	Electric field strength (V/m)	Magnetic field strength (A/m)	Power density (mW/cm ²)	Averaging time (minutes)
(A) Limits for Occupational/Controlled Exposure				
0.3-3.0	614	1.63	*100	6
3.0-30	1842/f	4.89/f	*900/f ²	6
30-300	61.4	0.163	1.0	6
300-1,500	-	-	f/300	6
1,500-100,000	-	-	5	6
(B) Limits for General Population/Uncontrolled Exposure				
0.3-1.34	614	1.63	*100	30
1.34-30	824/f	2.19/f	*180/f ²	30
30-300	27.5	0.073	0.2	30
300-1,500	-	-	f/1500	30
1,500-100,000	-	-	1.0	30

Where f = Frequency in MHz, * = Plane-wave power density

4 UNCERTAINTY

EMC Technologies has evaluated the tools and methods used to perform Radiated Electromagnetic Field predictions. The estimated measurement uncertainties for the calculation shown within this report are as follows:

Electromagnetic Modelling;

30 MHz to 100GHz ±2.8 dB

The above expanded uncertainties are based on standard uncertainties multiplied by a coverage factor of k=2, providing a level of confidence of approximately 95%.

5 ASSUMPTIONS IN THIS ASSESSMENT

This assessment does not include accumulated RF fields from nearby sites/antennas or possible radio signal reflections or attenuation due to buildings or the general environment.

Antenna Parameters and power settings were supplied by the customer.

A 100% duty cycle is assumed.

The aperture of the radiating element assumed to be a point source in free space and far field conditions.

Power tolerance added to the nominal output power.

6 EVALUATION RESULT

The MPE was evaluated at 21 cm to show compliance with the power density listed in table 2,

The following formula was used to calculate the power density at 21 cm

$$S = \frac{P * G}{4\pi R^2}$$

$$S = \frac{EIRP}{4\pi R^2}$$

Where

(S): Power density (mW/cm^2)

(P): Output power at antenna terminal (mW)

(G): Gain (ratio)

(R): Minimum test separation distance (21 cm)

Table 6-1: Evaluation Result

Technology	Frequency (MHz)	Power	Gain	Duty Cycle	EIRP	EIRP	Flux Density at 21 cm	Flux Density limit	Percentage of the limit
		<i>dBm</i>	<i>dBi</i>	%	<i>dBm</i>	<i>mW</i>	<i>mW/cm²</i>	<i>mW/cm²</i>	%
Bluetooth	2480	0	3	100%	3.00	2.0	0.0004	1.00	0.04%
P400	915	30	5	100%	35.00	3162.28	0.5709	0.61	93.59%
Total percentage of the limit at 21 cm (Worst Case)									93.63%

7 CONCLUSION

Based on an assessment of the documentation provided the FERIT NODE - P400 (Model 81338) and FERIT SOLAR NODE – P400 (Model 81343) comply with the RF exposure requirements of 47 CFR Part 2.1091. An exclusion zone of 21 cm in front of the radiating elements applies, elsewhere the exposure level was below the MPE limits.