

Xiamen Milesight IoT Co., Ltd.

Add:Building C09, Software Park Phase III, Xiamen 361024, Fujian, China

Tel: 0592-5023060

Fax: 0592-5023065

Email: tongzl@milesight.com

DECLARATION OF SIMILARITY

Date: 2025-3-25

To:
FEDERAL COMMUNICATIONS COMMISSION
Authorization and Evaluation Division
7435 Oakland Mills Road
Columbia, MD 21046

Dear Sir or Madam:

We, Xiamen Milesight IoT Co., Ltd., hereby declare that the product: Smart Fan Coil Thermostat, model: NN304-915M, NN303-915M, WT304, WT303, NN303, NN304 is electrically identical with the model: WT304-915M, WT303-915M which was tested by Bay Area Compliance Laboratories Corp.(Xiamen) with the same electromagnetic emissions and electromagnetic compatibility characteristics.

A description of the differences between the tested model and those that are declared similar are as follows:

The models have same software.

WT304 and WT303 series the main difference is the difference in the number of sub-board relays.

The WT303 has 5 relay interfaces, while the WT304 series has 3 relay interfaces and 2 more 0-10V analog output interfaces.

	Model	Difference
WT304 series	WT304-915M, NN304-915M, WT304, NN304	Model difference
WT303 series	WT303-915M, NN303-915M, WT303, NN303	Model difference

Please contact me should there be need for any additional clarification or information.

Best Regards,

Signature:



Printed Name: Zhenlong Tong

Title: Manager