



NOTIFIER
by Honeywell

SWIFT

MODEL NO.: FWD-200P

SIGNALING



S911



FIRE ALARM

LISTED EQUIPMENT

SMOKE-AUTOMATIC FIRE

DETECTOR HEAD FOR USE

WITH AN S911 UL LISTED

WIRELESS DATA

ISSUE NO. 2-10-1997

PLC ID: AUBSWIFT154010

IC: 673X-SWIFT PHOTO

NOMINAL SENSITIVITY:

0.5 - 2.43 %/FT.

MAX. INSTALL. OPERATING TEMP. 120° F (48.9° C)

PHOTOELECTRIC DETECTION PRINCIPLE

WARNING: REPLACE BATTERIES WITH

PANASONIC CR123A OR DURACELL DL123A

BATTERIES. USE OF ANOTHER BATTERY

MAY PRESENT RISK OF FIRE OR EXPLOSION.

THIS DEVICE COMPLIES WITH PART 15 OF THE

FCC RULES. OPERATION IS SUBJECT TO THE

FOLLOWING TWO CONDITIONS: (1) THIS DEVICE

MAY NOT CAUSE HARMFUL INTERFERENCE, AND

(2) THIS DEVICE MUST ACCEPT ANY INTERFERENCE

RECEIVED INCLUDING INTERFERENCE THAT MAY

CAUSE UNDESIRABLE OPERATION.

SEE 156-4065 FOR INSTALLATION,

MAINTENANCE, AND DETECTOR RATINGS.

REMOVE BATTERIES FROM DEVICE PRIOR TO

SHIPPING.

RETURN TO: NOTIFIER

NORTHFORD, CT USA

PAT: WWW.FIREPAT.NET

COUNTRY OF ORIGIN: MEXICO N04-5216-050