

APPENDIX F: DOWNLINK LTE CA RF CONDUCTED POWERS

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX F: Page 1 of 14

1.2 LTE Downlink Only Carrier Aggregation Test Selection and Setup

SAR test exclusion for LTE downlink Carrier Aggregation is determined by power measurements according to the number component carriers (CCs) supported by the product implementation. For those configurations required by April 2018 TCBC Workshop Notes, conducted power measurements with LTE Carrier Aggregation (CA) (downlink only) active are made in accordance to KDB Publication 941225 D05Av01r02. The RRC connection is only handled by one cell, the primary component carrier (PCC) for downlink and uplink communications. After making a data connection to the PCC, the UE device adds secondary component carrier(s) (SCC) on the downlink only. All uplink communications and acknowledgements remain identical to specifications when downlink carrier aggregation is inactive on the PCC. Additional conducted output powers are measured with the downlink carrier aggregation active for the configuration with highest measured maximum conducted power with downlink carrier aggregation inactive measured among the channel bandwidth, modulation, and RB combinations in each frequency band.

This device supports LAA with downlink carrier aggregation only. It uses carrier aggregation in the downlink to combine LTE in the unlicensed spectrum (i.e. LTE Band 46) with LTE in the licensed band (served as PCC). All uplink communications and acknowledgements on the PCC remain identical to specifications when downlink carrier aggregation is inactive.

Per FCC KDB Publication 941225 D05Av01r02, no SAR measurements are required for carrier aggregation configurations when the maximum average output power with downlink only carrier aggregation active is not more than 0.25 dB higher than the average output power with downlink only carrier aggregation inactive. All bands required for SAR testing per FCC KDB procedures were considered. Based on the measured maximum powers below, no additional SAR tests were required for DLCA SAR configurations.

General PCC and SCC configuration selection procedure

- PCC uplink channel, channel bandwidth, modulation and RB configurations were selected based on section C)3)b)iii) of KDB 941225 D05 V01r02. The downlink PCC channel was paired with the selected PCC uplink channel according to normal configurations without carrier aggregation.
- To maximize aggregated bandwidth, highest channel bandwidth available for that CA combination was selected for SCC. For inter-band CA, the SCC downlink channels were selected near the middle of their transmission bands. For contiguous intra-band CA, the downlink channel spacing between the component carriers was set to multiple of 300 kHz less than the nominal channel spacing defined in section 5.4.1A of 3GPP TS 36.521. For non-contiguous intra-band CA, the downlink channel spacing between the component carriers was set to be larger than the nominal channel spacing and provided maximum separation between the component carriers.
- All selected PCC and SCC(s) remained fully within the uplink/downlink transmission band of the respective component carrier.




Figure 1
DL CA Power Measurement Setup

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX F: Page 3 of 14




Figure 2
DL CA with DL 4x4 MIMO Power Measurement Setup

1.3 Downlink Carrier Aggregation RF Conducted Powers

1.3.1 LTE Band 71 as PCC

Table 1
Output Powers – Ant 4

Combination	PCC Band	PCC BW [MHz]	PCC Channel	PCC				PCC (UL) RB	PCC UL RB Offset	PCC (DL) Channel	PCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC Channel	SCC (DL) Freq. [MHz]	L1 Tx Power with DL CA Enabled (dBm)	L1 Single Carrier Tx Power (dBm)
				Modulation	PCC UL RB	PCC UL RB Offset	SCC Band																		
CA 4A-4A-71A	LTE B71	15	133297	680.5	16QAM	1	0	66761	634.5	LTE B4	20	2175	2132.5	LTE B4	10	2250	2190	-	-	-	-	-	-	22.48	22.50
CA 2A-4A-71A	LTE B71	15	133297	680.5	16QAM	1	0	66761	634.5	LTE B2	20	900	1990	LTE B4	20	2175	2132.5	-	-	-	-	-	-	22.46	22.50
CA 2A-2A-66A-71A	LTE B71	15	133297	680.5	16QAM	1	0	66761	634.5	LTE B2	20	900	1990	LTE B2	20	700	1940	LTE B66	20	66786	2145	22.50	22.50	22.50	22.50
CA 2A-66A-66A-71A	LTE B71	15	133297	680.5	16QAM	1	0	66761	634.5	LTE B2	20	900	1990	LTE B66	20	66786	2145	LTE B66	20	67236	2190	22.47	22.50	22.46	22.50
CA 2A-66C-71A	LTE B71	15	133297	680.5	16QAM	1	0	66761	634.5	LTE B2	20	900	1990	LTE B66	20	66786	2145	LTE B66	20	66984	2164.8	22.46	22.50	22.46	22.50

1.3.2 LTE Band 12 as PCC

Table 2
Output Powers – Ant 4

Combination	PCC Band	PCC BW [MHz]	PCC (UL) Ch.	PCC				SCC 1				SCC 2				SCC 3				SCC 4				Power			
				PCC (UL) Freq. [MHz]	Mod.	PCC UL RB	PCC UL RB Offset	PCC (DL) Channel	PCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	LTE Tx Power with CA Enabled (dBm)	LTE Single Carrier Tx Power (dBm)
CA 2A-12A (1)	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	-	-	-	-	-	-	-	-	-	-	-	-	20.89	20.90
CA 4A-12A (1)	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B4	20	2175	2132.5	-	-	-	-	-	-	-	-	-	-	-	-	20.87	20.90
CA 4A-12A (2)	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B4	20	2175	2132.5	-	-	-	-	-	-	-	-	-	-	-	-	20.88	20.90
CA 12A-25A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B25	20	6365	1902.5	-	-	-	-	-	-	-	-	-	-	-	-	20.84	20.90
CA 12A-66A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B66	20	66966	5037.5	-	-	-	-	-	-	-	-	-	-	-	-	20.85	20.90
CA 12A-66A (1)	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B66	20	66786	2145	-	-	-	-	-	-	-	-	-	-	-	-	20.90	20.90
CA 12A-66A (2)	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B66	20	66786	2145	-	-	-	-	-	-	-	-	-	-	-	-	20.90	20.90
CA 2C-12A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B2	20	702	1940.2	-	-	-	-	-	-	-	-	20.71	20.90
CA 2A-2A-12B	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B12	10	6107	738.7	LTE B2	20	900	1990	LTE B2	20	700	1940	-	-	-	-	20.62	20.90
CA 4A-4A-12B	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B12	10	6107	738.7	LTE B4	20	2175	2132.5	LTE B4	10	2250	2190	-	-	-	-	20.70	20.90
CA 2A-2A-12A-12B	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B2	20	700	1940	LTE B4	20	2175	2132.5	-	-	-	-	20.73	20.90
CA 2A-4A-4A-12A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B4	20	2175	2132.5	LTE B4	10	2250	2190	-	-	-	-	20.61	20.90
CA 2A-4A-12B	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B12	10	6107	738.7	LTE B2	20	900	1990	LTE B4	20	2175	2132.5	-	-	-	-	20.67	20.90
CA 2A-12A-66C	LTE B12	5	23035	701.5	16QAM	0	12	6035	731.5	LTE B2	20	900	1990	LTE B66	20	66966	5037.5	LTE B66	20	66984	2164.8	-	-	-	-	20.86	20.90
CA 4A-4A-12A-30A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B4	20	2175	2132.5	LTE B4	10	2250	2190	LTE B30	10	8620	2355	-	-	-	-	20.63	20.90
CA 2A-4A-12A-30A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B4	20	2175	2132.5	LTE B7	20	3100	2695	-	-	-	-	20.64	20.90
CA 12A-12A-30A	LTE B12	5	23035	701.5	16QAM	0	12	6035	731.5	LTE B2	20	900	1990	LTE B4	20	2175	2132.5	LTE B30	10	8620	2355	-	-	-	-	20.63	20.90
CA 2A-7A-12A-66A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B7	20	3100	2695	LTE B66	20	66786	2145	-	-	-	-	20.63	20.90
CA 2A-2A-12A-66A-66A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B2	20	700	1940	LTE B66	20	66786	2145	LTE B66	20	67236	2190	20.89	20.90
CA 2A-2A-12A-30A-66A	LTE B12	5	23035	701.5	16QAM	0	12	6035	731.5	LTE B2	20	900	1990	LTE B2	20	700	1940	LTE B30	10	8620	2355	LTE B66	20	66786	2145	20.63	20.90
CA 2A-12A-30A-66A-66A	LTE B12	5	23035	701.5	16QAM	1	12	6035	731.5	LTE B2	20	900	1990	LTE B30	10	8620	2355	LTE B66	20	66786	2145	LTE B66	20	67236	2190	20.84	20.90

FCC ID: BCGA2324



SAR EVALUATION REPORT

Reviewed by:
Quality Manager

Test Dates:
07/27/2020 – 08/18/2020

DUT Type:
Tablet Device

APPENDIX F:
Page 4 of 14

Table 7
Output Powers - Ant 2a

Table 8
Output Powers - Ant 4

Table 9
Output Powers - Ant 1a

02/15/2019

LTE Band 7 as PCC

Table 10
Output Powers - Ant 2A

[illegible]

LTE Band 41 as PCC

Table 11
Output Powers - Ant 2A

[illegible]

LTE Band 48 as PCC

Table 12
Output Powers - Ant 4

Combination		PCC										SCC 1				SCC 2				SCC 3				SCC 4				SCC 5				Power		
		PCC Band	PCC BW [MHz]	PCC (DL) Freq. [MHz]	PCC (UL) Freq. [MHz]	Mod.	PCC ICA #	PCC RB Offset	PCC (DL) Channel	PCC (UL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	SCC Band	SCC BW [MHz]	SCC (DL) Channel	SCC (DL) Freq. [MHz]	LTE Tx Power [dBm]	LTE Single Carrier Tx Power [dBm]		
CA SA-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560	18.40	18.40
CA SA-A4A-A4A	LTE-B40	20	5340	3560	LTE-B36	20	5340	3560	LTE-B36	20	5340	3560																						

1.4 DL CA with DL 4x4 MIMO RF Conduction Powers

This device supports downlink 4x4 MIMO operations for some LTE bands. Uplink transmission is limited to a single output stream. When carrier aggregation was applicable, the general test selection and setup procedures described in Section 0 were applied.

Per May 2017 TCB Workshop Notes, SAR for 4x4 DL MIMO was not needed since the maximum average output power in 4x4 DL MIMO mode was not more than 0.25 dB higher than the maximum output power with 4x4 DL MIMO inactive. Additionally, SAR for 4x4 MIMO Downlink Carrier Aggregation was not needed since the maximum average output power in 4x4 MIMO Downlink Carrier Aggregation mode was not more than 0.25 dB higher than the maximum output power with 4x4 MIMO Downlink and downlink carrier aggregation inactive.

FCC ID: BCGA2324	 PCTEST Proud to be part of  element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device	APPENDIX F: Page 7 of 14	

1.4.1

LTE 4x4 MIMO DL Standalone Powers

Table 13
Output Powers - Ant 2a

LTE Band	Bandwidth [MHz]	Channel	Frequency [MHz]	Modulation	RB Size	RB Offset	4x4 DL MIMO Tx. Power [dBm]	Single Antenna Tx. Power [dBm]	Maximum Allowed Power [dBm]
66	10	132622	1775	64QAM	1	0	15.30	15.27	15.3
7	15	21100	2535	16QAM	1	74	14.59	14.60	14.6
41	20	40185	2549.5	16QAM	50	0	16.51	16.57	16.6

Table 14
Output Powers - Ant 4

LTE Band	Bandwidth [MHz]	Channel	Frequency [MHz]	Modulation	RB Size	RB Offset	4x4 DL MIMO Tx. Power [dBm]	Single Antenna Tx. Power [dBm]	Maximum Allowed Power [dBm]
25	5	26665	1912.5	16QAM	1	0	16.00	16.00	16.0

Table 15
Output Powers - Ant 1a

LTE Band	Bandwidth [MHz]	Channel	Frequency [MHz]	Modulation	RB Size	RB Offset	4x4 DL MIMO Tx. Power [dBm]	Single Antenna Tx. Power [dBm]	Maximum Allowed Power [dBm]
30	5	27710	2310	16QAM	1	0	14.43	14.47	14.5

1.4.2

LTE Band 71 as PCC

Table 16
Output Powers – Ant 4

Combination	PCC Band	PCC										SCC 1				SCC 2				SCC 3				Power			
		PCC BW [MHz]	PCC (UL) Ch.	PCC (UL) Freq. [MHz]	Mod.	PCC UL RB	PCC UL RB Offset	PCC (DL) Ch.	PCC (DL) Freq. [MHz]	DL Ant. Config.	SCC Band	SCC BW [MHz]	SCC (DL) Ch.	SCC (DL) Freq. [MHz]	DL Ant. Config.	SCC Band	SCC BW [MHz]	SCC (DL) Ch.	SCC (DL) Freq. [MHz]	DL Ant. Config.	SCC Band	SCC BW [MHz]	SCC (DL) Ch.	SCC (DL) Freq. [MHz]	DL Ant. Config.	LTE Tx Power with DL CA Enabled (dBm)	LTE Single Carrier Tx Power (dBm)
CA [4A]-[4A]-71A	LTE B71	15	133297	680.5	16QAM	1	0	68761	634.5	2x2	LTE B4	20	2175	2132.5	4x4	LTE B4	10	2350	2150	4x4	-	-	-	-	-	22.18	22.50
CA [2A]-[4A]-71A	LTE B71	15	133297	680.5	16QAM	1	0	68761	634.5	2x2	LTE B2	20	900	1960	4x4	LTE B4	20	2175	2132.5	4x4	-	-	-	-	-	22.15	22.50
CA [2A]-[2A]-[6A]-71A	LTE B71	15	133297	680.5	16QAM	1	0	68761	634.5	2x2	LTE B2	20	900	1960	4x4	LTE B2	20	700	1940	4x4	LTE B66	20	66786	2145	4x4	22.10	22.50
CA [2A]-[6A]-[6A]-71A	LTE B71	15	133297	680.5	16QAM	1	0	68761	634.5	2x2	LTE B2	20	900	1960	4x4	LTE B66	20	66786	2145	4x4	LTE B66	20	67236	2190	4x4	22.07	22.50
CA [2A]-[6C]-71A	LTE B71	15	133297	680.5	16QAM	1	0	68761	634.5	2x2	LTE B2	20	900	1960	4x4	LTE B66	20	66786	2145	4x4	LTE B66	20	66984	2164.8	4x4	22.11	22.50

FCC ID: BCGA2324



SAR EVALUATION REPORT

Reviewed by:
Quality Manager

Test Dates:

07/27/2020 – 08/18/2020

DUT Type:

Tablet Device

APPENDIX F:
Page 8 of 14

LTE Band 48 as PCC

Table 27
Output Powers - Ant 4

Combination	PCB Brand	PCB BW [MHz]	PCB (Z) [mm]	PCB (R) [mm]	PC1				SC1				SC2				SC3				SC4				SC5				Power			
					Mid	PC1 UL [dBm]	PC1 UL [Ch]	PC1 (R) [mm]	UL Ant. Config.	SC1 BW [MHz]	SC1 (Z) [mm]	SC1 (R) [mm]	UL Ant. Config.	SC2 BW [MHz]	SC2 (Z) [Ch]	SC2 (R) [mm]	UL Ant. Config.	SC3 BW [MHz]	SC3 (Z) [Ch]	SC3 (R) [mm]	UL Ant. Config.	SC4 BW [MHz]	SC4 (Z) [Ch]	SC4 (R) [mm]	UL Ant. Config.	SC5 BW [MHz]	SC5 (Z) [Ch]	SC5 (R) [mm]	UL Ant. Config.	UL Tx with CA Enabled (dBm)	UL Single Carrier (dBm)	
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	-	-	-	-	-	-	-	16.45	16.50	
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.50	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20	53340	1560	QPSK	50	25	53340	1560	24	1	LTE B4B	20	53340	1560	24	1	LTE B4B	20	53340	1560	444	1	LTE B4B	20	53340	1560	444	-	-	16.51	16.50
CA (2A+4B+4B)	LTE B4B	20</																														

1.5 Downlink Carrier Aggregation with Uplink Carrier Aggregation enabled

This device supports uplink carrier aggregation (ULCA) with additional Carrier Aggregation configurations active in the downlink. Power measurements were performed with ULCA active and additional CA configurations active in the downlink for the configuration per Fall 2017 TCB Workshop Notes.

Per FCC Guidance, additional SAR measurements for these configurations were not required since their maximum output power was not more than 0.25 dB higher than the maximum output power for with only ULCA active.

1.5.1 DL Carrier Aggregation RF Conducted Powers

1.5.1.1 LTE Band 41

Table 28
Output Powers – Ant 2A

[illegible]

1.5.2 DL Carrier Aggregation with DL 4x4 MIMO RF Conducted Powers

Note: 4x4 DL MIMO is only operating in the downlink. Uplink transmission is limited to a single output stream for each component carrier of ULCA.

1.5.2.1 LTE Band 41

Table 29
Output Powers – Ant 2A

Combination	PCB Band	PCB MW [MHz]	PCC					Di. Ant. Config.	S/C Band	SCL 1					Di. Ant. Config.	SCL 2					Di. Ant. Config.	SCL 3					Di. Ant. Config.	SCL 4					Di. Ant. Config.	U.S. CA Power with Tx/Rx (dBm)	Power (dBm)	U.S. CA Power (dBm)		
			PCB L1/L2	PCB (U) Freq. [MHz]	Mod.	PCB L1/RB Offset	PCC (DL) Freq. [MHz]			PCC (DL) Ch.	SCL 1 (U) Freq. [MHz]	Mod	SCL 1 (U) #RB	SCL 1 RB Offset		SCL 2 (DL) Ch.	SCL 2 (DL) Freq. [MHz]	SCL 2 (DL) Ant. Config.	SCL 2 (DL) Ch.	SCL 2 (DL) Freq. [MHz]		SCL 2 (DL) Ant. Config.	SCL 3 (U) Freq. [MHz]	SCL 3 (U) Ch.	SCL 3 (DL) Freq. [MHz]	SCL 3 (DL) Ch.		SCL 4 (U) Freq. [MHz]	SCL 4 (U) Ch.	SCL 4 (DL) Freq. [MHz]	SCL 4 (DL) Ch.							
CA #1 (414.141)	LTE B41	20	40183	2560.5	QPSK	1	99	40183	2560.5	644	LTE B41	20	40183	2560.5	QPSK	1	0	40183	2560.5	644	LTE B41	20	41840	2680.5	644	LTE B41	20	41840	2680.5	644	-	-	-	-	-	-	18.88	18.88
CA #8 (8)	LTE B41	20	40183	2560.5	QPSK	1	99	40183	2560.5	644	LTE B41	20	40183	2560.5	QPSK	1	0	40183	2560.5	644	LTE B41	20	41840	2680.5	644	LTE B41	20	41840	2680.5	644	-	-	-	-	-	-	18.88	18.88
CA #16 (16)	LTE B41	20	40183	2560.5	QPSK	1	99	40183	2560.5	644	LTE B41	20	40183	2560.5	QPSK	1	0	40183	2560.5	644	LTE B41	20	41840	2680.5	644	LTE B41	20	41840	2680.5	644	-	-	-	-	-	-	18.88	18.88
CA #41 (41)	LTE B41	20	40183	2560.5	QPSK	1	99	40183	2560.5	644	LTE B41	20	40183	2560.5	QPSK	1	0	40183	2560.5	644	LTE B41	20	41840	2680.5	644	LTE B41	20	41840	2680.5	644	-	-	-	-	-	-	18.88	18.88
CA #41C (41C)	LTE B41	20	40183	2560.5	QPSK	1	99	40183	2560.5	644	LTE B41	20	40183	2560.5	QPSK	1	0	40183	2560.5	644	LTE B41	20	41840	2680.5	644	LTE B41	20	41840	2680.5	644	-	-	-	-	-	-	18.88	18.88

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device	APPENDIX F: Page 13 of 14	

1.5.2.2 LTE Band 7

Table 30
Output Powers - Ant 2A

Combination	PCC										SCC 1										Power	
	PCC Band	PCC BW [MHz]	PCC (UL) Ch.	PCC (UL) Freq. [MHz]	Mod.	PCC UL# RB	PCC UL RB Offset	PCC (DL) Ch.	PCC (DL) Freq. [MHz]	DL Ant. Config.	SCC Band	SCC BW [MHz]	SCC (UL) Ch.	SCC (UL) Freq. [MHz]	Mod.	SCC UL# RB	SCC UL RB Offset	SCC (DL) Ch.	SCC (DL) Freq. [MHz]	DL Ant. Config.	ULCA Tx.Power with DL CA Enabled	ULCA Tx Power (dBm)
CA [7C]	LTE B7	20	20850	2510	QPSK	100	0	2850	2630	4x4	LTE B7	20	21048	2529.8	QPSK	100	0	3048	2649.8	4x4	14.34	14.40

FCC ID: BCGA2324	 PCTEST Proud to be part of  element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX F: Page 14 of 14

APPENDIX G: POWER REDUCTION VERIFICATION

FCC ID: BCGA2324	 Proud to be part of  element	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX G Page 1 of 2

The device supports manufacturer's proprietary power reduction mechanism called "Detect Mode" for the Main Cellular Antenna. Details of this mechanism can be found in the Operational Description. When the device is being used "on-body" or "held in hand" by the user, the device will detect motion and reduce the power of the main antenna. Per the manufacturer, the mechanism is agnostic to different cellular air interfaces. Detect Mode operation was verified for two test cases, on-body and held in hand, for each supported cellular band. The power reduction verification results are below.

1.1 Main Antenna Power Reduction Verification Summary

**Table G-1
Main Antenna Power Reduction Verification**

Mode/Band	Antenna	Maximum Scenario Maximum Allowed Target Power [dBm]	Reduced Scenario Maximum Allowed Target Power [dBm]	Conducted Power [dBm]			
				Maximum	Test Case 1	Test Case 2	Verdict
GPRS 850 (2 Tx)	Antenna 4	31.25 (± 0.75)	27.45 (± 0.75)	30.71	28.11	28.08	PASS
	Antenna 3B	30.25 (± 0.75)	24.05 (± 0.75)	29.99	24.32	24.29	PASS
	Antenna 4	29.25 (± 0.75)	22.25 (± 0.75)	28.03	22.11	22.15	PASS
GPRS 1900 (2 Tx)	Antenna 2A	28.25 (± 0.75)	20.45 (± 0.75)	28.81	20.93	20.92	PASS
	Antenna 1A	26.25 (± 0.75)	21.25 (± 0.75)	29.32	21.25	21.23	PASS
	Antenna 3A	28.25 (± 0.75)	19.65 (± 0.75)	27.98	19.90	19.92	PASS
WCDMA B5	Antenna 4	25.00 (± 0.5)	20.60 (± 0.5)	24.51	20.75	20.73	PASS
	Antenna 3B	24.25 (± 0.5)	17.60 (± 0.5)	23.97	17.59	17.58	PASS
	Antenna 4	24.25 (± 0.5)	15.00 (± 0.5)	23.92	14.65	14.64	PASS
WCDMA B4	Antenna 2A	23.50 (± 0.5)	13.90 (± 1)	23.14	13.12	13.11	PASS
	Antenna 1A	24.00 (± 0.5)	14.60 (± 0.5)	23.97	14.61	14.59	PASS
	Antenna 3A	23.25 (± 0.5)	13.00 (± 1)	22.98	13.00	13.01	PASS
WCDMA B2	Antenna 4	24.25 (± 0.5)	15.80 (± 0.5)	23.94	15.48	15.49	PASS
	Antenna 2A	23.50 (± 0.5)	13.80 (± 1)	23.51	13.11	13.09	PASS
	Antenna 1A	24.00 (± 0.5)	13.80 (± 1)	23.78	13.21	13.25	PASS
LTE Band 71	Antenna 3A	23.25 (± 0.5)	13.20 (± 1)	23.34	13.05	13.07	PASS
	Antenna 4	25.00 (± 0.5)	22.00 (± 0.5)	25.01	22.03	22.01	PASS
	Antenna 3B	24.25 (± 0.5)	18.60 (± 0.5)	24.13	18.57	18.56	PASS
LTE Band 12	Antenna 4	25.00 (± 0.5)	20.40 (± 0.5)	24.98	20.33	20.31	PASS
	Antenna 3B	24.25 (± 0.5)	18.40 (± 0.5)	24.12	18.13	18.14	PASS
	Antenna 4	25.00 (± 0.5)	20.40 (± 0.5)	24.76	20.11	20.09	PASS
LTE Band 17	Antenna 3B	24.25 (± 0.5)	18.40 (± 0.5)	24.23	18.08	18.06	PASS
	Antenna 4	25.00 (± 0.5)	20.60 (± 0.5)	25.13	20.53	20.61	PASS
	Antenna 3B	24.25 (± 0.5)	18.70 (± 0.5)	23.99	18.43	18.41	PASS
LTE Band 13	Antenna 4	25.00 (± 0.5)	20.60 (± 0.5)	24.87	20.22	20.24	PASS
	Antenna 3B	24.25 (± 0.5)	18.70 (± 0.5)	24.66	19.01	19.03	PASS
	Antenna 4	25.00 (± 0.5)	20.60 (± 0.5)	25.31	21.03	21.02	PASS
LTE Band 26	Antenna 3B	24.25 (± 0.5)	17.40 (± 0.5)	24.36	17.17	17.18	PASS
	Antenna 4	25.00 (± 0.5)	20.60 (± 0.5)	24.99	21.05	21.06	PASS
	Antenna 3B	24.25 (± 0.5)	17.40 (± 0.5)	24.27	16.88	16.97	PASS
LTE Band 4	Antenna 4	24.25 (± 0.5)	13.40 (± 1)	23.98	14.11	14.10	PASS
	Antenna 2A	23.50 (± 0.5)	14.80 (± 0.5)	23.33	15.00	15.01	PASS
	Antenna 1A	24.00 (± 0.5)	13.80 (± 1)	23.91	13.02	13.03	PASS
LTE Band 66	Antenna 3A	23.25 (± 0.5)	13.10 (± 1)	23.57	13.91	13.90	PASS
	Antenna 4	24.25 (± 0.5)	13.40 (± 1)	23.97	14.32	14.31	PASS
	Antenna 2A	23.50 (± 0.5)	14.80 (± 0.5)	23.71	15.13	15.12	PASS
LTE Band 2	Antenna 1A	24.00 (± 0.5)	13.00 (± 1)	24.08	14.77	14.78	PASS
	Antenna 3A	23.25 (± 0.5)	13.10 (± 1)	23.57	13.93	13.92	PASS
	Antenna 4	24.25 (± 0.5)	15.50 (± 0.5)	24.17	15.31	15.30	PASS
LTE Band 25	Antenna 2A	23.50 (± 0.5)	13.40 (± 1)	23.68	13.79	13.77	PASS
	Antenna 1A	24.00 (± 0.5)	13.60 (± 1)	24.91	14.02	14.03	PASS
	Antenna 3A	23.25 (± 0.5)	13.60 (± 1)	22.97	13.11	13.12	PASS
LTE Band 30	Antenna 4	24.25 (± 0.5)	15.50 (± 0.5)	24.57	15.78	15.77	PASS
	Antenna 2A	23.50 (± 0.5)	13.40 (± 1)	23.31	13.24	13.23	PASS
	Antenna 1A	24.00 (± 0.5)	13.60 (± 1)	23.77	12.78	12.77	PASS
LTE Band 7	Antenna 3A	23.25 (± 0.5)	13.60 (± 1)	23.55	13.56	13.55	PASS
	Antenna 4	22.20 (± 0.5)	12.70 (± 1)	22.12	12.73	12.74	PASS
	Antenna 2A	22.60 (± 0.5)	12.50 (± 1)	22.76	12.65	12.63	PASS
LTE Band 38	Antenna 1A	22.00 (± 0.5)	13.80 (± 1)	21.73	13.11	13.12	PASS
	Antenna 3A	23.00 (± 0.5)	12.70 (± 1)	22.73	12.17	12.16	PASS
	Antenna 4	24.50 (± 0.5)	12.70 (± 1)	24.22	12.31	12.34	PASS
LTE Band 41 (PC3)	Antenna 3B	23.25 (± 0.5)	13.60 (± 1)	22.96	14.22	14.23	PASS
	Antenna 1A	23.75 (± 0.5)	12.90 (± 1)	24.12	12.79	12.77	PASS
	Antenna 3A	23.00 (± 0.5)	11.00 (± 1)	22.97	10.37	10.38	PASS
LTE Band 41 (PC2)	Antenna 4	24.50 (± 0.5)	15.10 (± 0.5)	24.37	15.16	15.15	PASS
	Antenna 2A	23.50 (± 0.5)	15.10 (± 0.5)	23.33	16.01	16.00	PASS
	Antenna 1A	23.75 (± 0.5)	14.50 (± 0.5)	23.52	14.23	14.24	PASS
LTE Band 48	Antenna 3A	23.00 (± 0.5)	13.20 (± 1)	22.91	14.01	14.00	PASS
	Antenna 4	24.00 (± 0.5)	15.10 (± 0.5)	24.12	15.02	15.03	PASS
	Antenna 2A	23.50 (± 0.5)	15.10 (± 0.5)	23.71	16.10	16.08	PASS
LTE B7 Intra-Band ULCA	Antenna 1A	23.75 (± 0.5)	14.50 (± 0.5)	23.95	14.33	14.34	PASS
	Antenna 3A	23.00 (± 0.5)	13.20 (± 1)	22.67	13.71	13.70	PASS
	Antenna 4	26.00 (± 0.5)	15.10 (± 0.5)	25.71	14.93	14.92	PASS
LTE B38 ULCA	Antenna 2A	26.75 (± 0.5)	16.10 (± 0.5)	27.02	15.11	15.12	PASS
	Antenna 1A	26.50 (± 0.5)	14.50 (± 0.5)	26.33	14.07	14.06	PASS
	Antenna 3A	26.00 (± 0.5)	13.20 (± 1)	26.06	13.25	13.21	PASS
LTE B41 (PC2) ULCA	Antenna 4	24.75 (± 0.5)	16.00 (± 0.5)	25.12	15.77	15.78	PASS
	Antenna 3B	23.25 (± 0.5)	15.70 (± 0.5)	22.95	15.69	15.67	PASS
	Antenna 4	23.75 (± 1)	20.10 (± 1)	23.11	20.33	20.31	PASS
LTE B41 (PC3) Intra-Band ULCA	Antenna 3B	22.75 (± 1)	16.90 (± 1)	22.14	16.25	16.24	PASS
	Antenna 4	23.25 (± 1)	12.70 (± 1)	23.09	12.01	12.03	PASS
	Antenna 2A	22.25 (± 1)	13.60 (± 1)	22.52	13.03	13.01	PASS
LTE B41 (PC2) ULCA	Antenna 1A	22.75 (± 1)	12.90 (± 1)	22.09	12.57	12.56	PASS
	Antenna 3A	22.00 (± 1)	11.00 (± 1)	22.14	11.13	11.11	PASS
	Antenna 4	23.25 (± 1)	14.60 (± 1)	22.74	14.16	14.15	PASS
LTE B41 (PC2) ULCA	Antenna 2A	22.25 (± 1)	15.60 (± 1)	22.36	15.74	15.73	PASS
	Antenna 1A	22.75 (± 1)	14.00 (± 1)	22.01	13.81	13.82	PASS
	Antenna 3A	22.00 (± 1)	13.20 (± 1)	21.36	13.11	13.15	PASS
LTE B41 (PC2) ULCA	Antenna 4	23.25 (± 1)	14.60 (± 1)	22.61	13.78	13.77	PASS
	Antenna 2A	22.25 (± 1)	15.60 (± 1)	21.69	16.33	16.32	PASS
	Antenna 1A	22.75 (± 1)	14.00 (± 1)	21.95	14.38	14.40	PASS
LTE B41 (PC2) ULCA	Antenna 3A	22.00 (± 1)	13.20 (± 1)	21.98	14.11	14.10	PASS
	Antenna 4	24.75 (± 1)	14.60 (± 1)	24.12	14.39	14.45	PASS
	Antenna 2A	24.25 (± 1)	15.60 (± 1)	23.97	15.73	15.71	PASS
	Antenna 1A	24.75 (± 1)	14.00 (± 1)	24.11	14.45	14.44	PASS
	Antenna 3A	24.00 (± 1)	13.20 (± 1)	24.36	13.36	13.38	PASS

Test Case 1: Device Held in Hand

Test Case 2: Device Resting on Lap

Test Cases represent typical scenarios in which the device power would be reduced. In these scenarios detect mode has been verified to identify typical on-body use-cases including when thin objects, such as a magazine or newspaper, are placed between the body and the device. In the absence of detect mode output, the device defaults to the most conservative power.

FCC ID: BCGA2324	 PCTEST Proud to be part of  element	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX G Page 2 of 2

APPENDIX H: IEEE 802.11AX RU SAR EXCLUSION

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 1 of 24

1.1 IEEE 802.11ax RU SAR Exclusion

To make the most efficient use of the additional available subcarriers (data tones), IEEE 802.11ax can utilize Orthogonal Frequency-Division Multiple Access (OFDMA) which divides the existing 802.11 channels into smaller subchannels called Resource Units (RUs). Possible RU sizes are: 26T, 52T, 106T, 242T, 484T, 996T.

Per FCC Guidance, 802.11ax was considered a higher order 802.11 mode when compared to a/b/g/n/ac to apply KDB Publication 248227 D01v02r02 for OFDM mode selection. Therefore, SAR tests were not required for 802.11ax based on the maximum allowed output powers of OFDM modes and the reported SAR values. Per FCC Guidance, maximum conducted powers were performed for each RU size to demonstrate that the output powers would not be higher than the other OFDM 802.11 modes.

1.2 IEEE 802.11ax RU Target Powers

1.2.1 Maximum 802.11ax RU Time-Averaged WLAN Output Power

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Antenna 3A	20 MHz Bandwidth	1	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		2	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		3	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		4	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		5	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		6	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		7	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		8	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		9	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		10	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		11	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		12	11.00	9.50	11.00	9.50	11.00	9.50	11.00	9.50
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) - Antenna 3A	20 MHz Bandwidth	1	12.50	11.00	12.50	11.00	12.50	11.00	12.50	11.00
		2	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		3	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		4	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		5	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		6	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		7	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		8	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		9	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		10	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		11	12.50	11.00	12.50	11.00	12.50	11.00	12.50	11.00
		12	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Antenna 1A	20 MHz Bandwidth	1	13.00	11.50	13.00	11.50	13.00	11.50	13.00	11.50
		2	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		3	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		4	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		5	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		6	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		7	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		8	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		9	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		10	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		11	13.50	12.00	13.50	12.00	13.50	12.00	13.50	12.00
		12	11.00	9.50	11.00	9.50	11.00	9.50	11.00	9.50
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 2 of 24

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) - Antenna 1A	20 MHz Bandwidth	1	12.50	11.00	12.50	11.00	12.50	11.00	12.50	11.00
		2	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		3	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		4	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		5	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		6	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		7	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		8	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		9	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		10	13.75	12.25	13.75	12.25	13.75	12.25	13.75	12.25
		11	12.50	11.00	12.50	11.00	12.50	11.00	12.50	11.00
		12	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Ant 2A	20 MHz Bandwidth	36	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00				
		40	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00				
		44	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00				
		48	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00				
		52	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25				
		56	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25				
		60	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25				
		64	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25				
		100	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		104	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		108	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		112	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		116	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		120	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		124	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		128	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		132	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		136	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		140	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		144	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25				
		149	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75				
		153	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75				
		157	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75				
		161	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75				
		165	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75				
	40 MHz Bandwidth	38	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00
		46	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00
		54	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25
		62	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25
		102	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		110	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		118	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		126	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		134	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		142	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		151	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75
		159	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75
	80 MHz Bandwidth	42	10.00	8.50	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00	10.50	9.00
		58	9.50	8.00	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25	9.75	8.25
		106	9.50	8.00	10.50	9.00	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		122	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		138	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25	10.75	9.25
		155	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75	11.25	9.75

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 3 of 24

Reduced 802.11ax RU Time-Averaged WLAN Output Power

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 3A/3B active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Antenna 3A	20 MHz Bandwidth	1	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		2	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		3	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		4	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		5	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		6	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		7	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		8	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		9	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		10	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		11	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		12	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 3A/3B active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) - Antenna 3A	20 MHz Bandwidth	1	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		2	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		3	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		4	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		5	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		6	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		7	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		8	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		9	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		10	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		11	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		12	6.00	4.50	6.00	4.50	6.00	4.50	6.00	4.50
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 1A active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Antenna 1A	20 MHz Bandwidth	1	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		2	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		3	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		4	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		5	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		6	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		7	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		8	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		9	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		10	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		11	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		12	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 8 of 24

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 1A active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) - Antenna 1A	20 MHz Bandwidth	1	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		2	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		3	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		4	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		5	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		6	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		7	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		8	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		9	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		10	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		11	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		12	6.75	5.25	6.75	5.25	6.75	5.25	6.75	5.25
		13	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 2A active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Ant 2A	20 MHz Bandwidth	36	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		40	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		44	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		48	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		52	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		56	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		60	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		64	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		100	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		104	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		108	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		112	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		116	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		120	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		124	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		128	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		132	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		136	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		140	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		144	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		149	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		153	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		157	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		161	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		165	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
	40 MHz Bandwidth	38	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		46	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		54	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		62	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		102	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		110	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		118	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		126	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		134	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		142	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
	80 MHz Bandwidth	151	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75		
		159	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75		
		42	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00
		58	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25
		106	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		122	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		138	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		155	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 9 of 24

Below table is applicable in the following conditions:

-Simultaneous conditions with Licensed Bands Antenna 2A active

-Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones		26T		52T		106T		242T		484T		996T		
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal		
Modulated Average - 2 Tx Chain (dBm) CDD - Ant 2A	20 MHz Bandwidth	36	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		40	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		44	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		48	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		52	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		56	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		60	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		64	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		100	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		104	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		108	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		112	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		116	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		120	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		124	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		128	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		132	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		136	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		140	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		144	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		149	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		153	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		157	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		161	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		165	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
	40 MHz Bandwidth	38	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		46	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		54	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		62	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		102	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		110	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		118	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		126	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		134	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		142	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		151	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75		
		159	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75		
	80 MHz Bandwidth	42	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00
		58	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25
		106	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		122	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		138	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		155	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 10 of 24

Below table is applicable in the following conditions:

-Simultaneous conditions with Licensed Bands Antenna 2A active

-Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) SDM - Ant 2A	20 MHz Bandwidth	36	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		40	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		44	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		48	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		52	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		56	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		60	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		64	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		100	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		104	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		108	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		112	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		116	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		120	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		124	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		128	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		132	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		136	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		140	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		144	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25				
		149	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		153	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		157	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		161	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
		165	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75				
	40 MHz Bandwidth	38	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		46	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		54	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		62	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		102	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		110	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		118	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		126	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		134	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
		142	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25		
	80 MHz Bandwidth	151	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75		
		159	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75		
		42	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00
		58	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25
		106	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		122	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		138	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25	3.75	2.25
		155	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75	4.25	2.75

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 11 of 24

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 2A active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - Ant 2B	20 MHz Bandwidth	36	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		40	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		44	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		48	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		52	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		56	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		60	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		64	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		100	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		104	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		108	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		112	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		116	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		120	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		124	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		128	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
	40 MHz Bandwidth	132	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		136	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		140	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		144	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		148	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		152	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		156	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		160	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		164	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		168	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		172	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		176	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		180	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		184	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		188	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
	80 MHz Bandwidth	192	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		196	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		200	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		204	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		208	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		212	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		216	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		220	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		224	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		228	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		232	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		236	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		240	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		244	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		248	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		

Below table is applicable in the following conditions:

- Simultaneous conditions with Licensed Bands Antenna 2A active
- Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) CDD - Ant 2B	20 MHz Bandwidth	36	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		40	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		44	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		48	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		52	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		56	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		60	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		64	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		100	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		104	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		108	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		112	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		116	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		120	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		124	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
	40 MHz Bandwidth	128	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		132	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		136	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		140	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		144	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		148	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		152	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		156	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		160	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		164	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		168	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		172	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		176	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		180	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		184	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
	80 MHz Bandwidth	188	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		192	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		196	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		200	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		204	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		208	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		212	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		216	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		220	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		224	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		228	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		232	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		236	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		240	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		244	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 12 of 24

Below table is applicable in the following conditions:

-Simultaneous conditions with Licensed Bands Antenna 2A active

-Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) SDM - Ant 2B	20 MHz Bandwidth	36	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		40	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		44	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		48	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00				
		52	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		56	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		60	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		64	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		100	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		104	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		108	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		112	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		116	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		120	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		124	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		128	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		132	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		136	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		140	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		144	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		149	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		153	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		157	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		161	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		165	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
	40 MHz Bandwidth	38	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		46	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00		
		54	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		62	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		102	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		110	0.00	-1.50	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		118	0.00	-1.50	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		126	0.00	-1.50	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		134	0.00	-1.50	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		142	0.00	-1.50	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		151	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		159	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
	80 MHz Bandwidth	42	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00	3.50	2.00
		58	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00
		106	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		122	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		138	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		155	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 13 of 24

Below table is applicable in the following conditions:

-Simultaneous conditions with Licensed Bands Antenna 1A active

-Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - Single Tx Chain (dBm) - 18	20 MHz Bandwidth	36	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		40	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		44	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		48	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		52	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		56	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		60	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		64	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		100	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		104	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		108	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		112	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		116	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		120	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		124	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		128	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		132	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		136	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		140	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		144	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		148	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		152	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		156	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		160	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		164	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		168	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
	40 MHz Bandwidth	38	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		46	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		54	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		62	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		102	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		110	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		118	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		126	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		134	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		142	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
	80 MHz Bandwidth	150	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		158	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		42	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00
		58	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25
		106	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		122	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		138	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		155	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 14 of 24

Below table is applicable in the following conditions:

-Simultaneous conditions with Licensed Bands Antenna 1A active

-Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) CDD - Ant 1B	20 MHz Bandwidth	36	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		40	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		44	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		48	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		52	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		56	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		60	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		64	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		100	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		104	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		108	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		112	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		116	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		120	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		124	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		128	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		132	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		136	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		140	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		144	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		149	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		153	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		157	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		161	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		165	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
	40 MHz Bandwidth	38	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		46	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		54	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		62	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		102	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		110	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		118	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		126	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		134	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		142	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
	80 MHz Bandwidth	151	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		159	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		42	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00
		58	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25
		106	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		122	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		138	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		155	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 15 of 24

Below table is applicable in the following conditions:

-Simultaneous conditions with Licensed Bands Antenna 1A active

-Simultaneous conditions with LTE Inter-band ULCA active

Mode/ Band		Tones	26T		52T		106T		242T		484T		996T	
		Channel	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal	Maximum	Nominal
Modulated Average - 2 Tx Chain (dBm) SDM - Ant 1B	20 MHz Bandwidth	36	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		40	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		44	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		48	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00				
		52	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		56	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		60	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		64	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25				
		100	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		104	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		108	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		112	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		116	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		120	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		124	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		128	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		132	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		136	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		140	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		144	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		149	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		153	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		157	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		161	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
		165	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75				
	40 MHz Bandwidth	38	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		46	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00		
		54	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		62	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25		
		102	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		110	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		118	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		126	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		134	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		142	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		151	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
		159	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75		
	80 MHz Bandwidth	42	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00	4.50	3.00
		58	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25	2.75	1.25
		106	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		122	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		138	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75
		155	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75	3.25	1.75

Note: In MIMO operations, each antenna transmits at maximum allowed powers as indicated above.

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 16 of 24

1.1 IEEE 802.11ax Measured Powers

Table 1
Maximum 2.4 GHz 802.11ax RU Time-Averaged WLAN Output Power – Ant 3A

Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)	Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)
2412	1	26T	0	12.71	2412	1	52T	37	12.74
			4	12.59				38	12.78
			8	12.35				40	12.56
2437	6	26T	0	12.29	2437	6	52T	37	12.23
			4	12.51				38	12.62
			8	12.27				40	12.35
2462	11	26T	0	12.56	2462	11	52T	37	12.73
			4	12.62				38	12.78
			8	12.37				40	12.13

Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)	Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)
2412	1	106T	53	12.61	2412	1	242T	61	12.89
			54	12.81					
2437	6	106T	53	12.37					
			54	12.34					
2462	11	106T	53	12.27					
			54	12.89					
					2437	6	242T	61	12.73
					2462	11	242T	61	12.82

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 17 of 24

Table 2
Maximum 2.4 GHz 802.11ax RU Time-Averaged WLAN Output Power – Ant 1A

Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)	Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)
2412	1	26T	0	12.40	2412	1	52T	37	12.56
			4	12.57				38	12.78
			8	12.24				40	12.22
2417	2	26T	0	13.16	2417	2	52T	37	12.92
			4	13.67				38	13.64
			8	13.03				40	13.48
2437	6	26T	0	13.11	2437	6	52T	37	13.19
			4	13.33				38	13.31
			8	13.42				40	13.03
2457	10	26T	0	13.06	2457	10	52T	37	13.73
			4	13.32				38	13.38
			8	12.98				40	12.92
2462	11	26T	0	13.39	2462	11	52T	37	13.07
			4	13.04				38	13.18
			8	12.72				40	12.87

Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)		Freq [MHz]	Channel	Tones	RU Index	Avg Conducted Powers (dBm)
2412	1	106T	53	12.53						
			54	12.64						
2417	2	106T	53	12.99						
			54	13.37						
2437	6	106T	53	13.35						
			54	12.89						
2457	10	106T	53	13.44						
			54	12.84						
2462	11	106T	53	13.35						
			54	12.89						
					2412	1	242T	61	12.95	
					2417	2	242T	61	13.25	
					2437	6	242T	61	12.99	
					2457	10	242T	61	12.35	
					2462	11	242T	61	13.33	

FCC ID: BCGA2324	 PCTEST Prove to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 18 of 24

Table 3
Maximum 5 GHz 802.11ax RU Time-Averaged WLAN Output Power – Ant 2B

20MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	4	8
20MHz BW	1	5180	36	26T	9.91	10.45	10.08
		5200	40	26T	9.68	10.44	9.88
		5220	44	26T	9.71	10.38	9.97
		5240	48	26T	9.75	10.37	10.09
	2A	5260	52	26T	11.04	11.48	11.06
		5280	56	26T	10.84	11.42	10.93
		5300	60	26T	10.90	11.42	10.96
		5320	64	26T	10.97	11.47	11.00
	2C	5500	100	26T	9.63	10.14	9.58
		5600	120	26T	9.70	10.17	9.72
		5620	124	26T	9.62	10.21	9.82
		5720	144	26T	9.58	10.01	9.42
	3	5745	149	26T	8.97	9.56	9.15
		5785	157	26T	8.82	9.31	8.90
		5825	165	26T	9.75	9.16	8.92
20MHz BW	1	5180	36	106T	10.03	10.12	
		5200	40	106T	10.13	10.17	
		5220	44	106T	9.97	10.16	
		5240	48	106T	10.02	10.10	
	2A	5260	52	106T	10.75	10.68	
		5280	56	106T	10.71	10.79	
		5300	60	106T	10.62	10.70	
		5320	64	106T	10.61	10.55	
	2C	5500	100	106T	9.95	9.93	
		5600	120	106T	9.61	9.61	
		5620	124	106T	9.71	9.72	
		5720	144	106T	9.51	9.61	
	3	5745	149	106T	9.23	9.31	
		5785	157	106T	9.00	9.19	
		5825	165	106T	8.87	8.96	
20MHz BW	1	5180	36	242T	10.18		
		5200	40	242T	10.21		
		5220	44	242T	10.15		
		5240	48	242T	10.01		
	2A	5260	52	242T	10.89		
		5280	56	242T	10.92		
		5300	60	242T	10.96		
		5320	64	242T	10.84		
	2C	5500	100	242T	9.96		
		5600	120	242T	10.15		
		5620	124	242T	10.21		
		5720	144	242T	10.02		
	3	5745	149	242T	9.50		
		5785	157	242T	9.45		
		5825	165	242T	9.32		
40MHz BW	1	5190	38	26T	9.51	10.45	9.92
		5230	46	26T	9.53	10.46	9.83
		5270	54	26T	10.68	11.46	10.91
		5310	62	26T	10.70	11.48	10.97
	2A	5510	102	26T	9.28	10.07	9.45
		5590	118	26T	9.31	9.91	9.33
		5630	126	26T	9.47	10.22	9.58
		5710	142	26T	9.28	10.23	9.47
	2C	5755	151	26T	8.84	9.72	9.14
		5795	159	26T	8.82	9.74	9.15
40MHz BW	1	5190	38	106T	9.54	10.15	9.84
		5230	46	106T	9.57	10.20	9.88
		5270	54	106T	10.69	11.25	10.77
		5310	62	106T	10.69	11.27	10.80
	2A	5510	102	106T	9.31	9.87	9.42
		5590	118	106T	9.52	10.04	9.61
		5670	126	106T	9.46	10.17	9.56
		5710	142	106T	9.33	10.01	9.58
	2C	5755	151	106T	8.99	9.65	9.19
		5795	159	106T	8.80	9.42	9.07
40MHz BW	1	5190	38	242T	9.58	9.64	
		5230	46	242T	9.60	9.78	
		5270	54	242T	10.89	11.18	
		5310	62	242T	10.98	11.01	
	2A	5510	102	242T	9.52	9.82	
		5590	118	242T	9.69	9.83	
		5670	126	242T	9.71	9.81	
		5710	142	242T	9.70	9.68	
	2C	5755	151	242T	9.07	9.19	
		5795	159	242T	9.05	9.15	

FCC ID: BCGA2324	 PCTEST Prove to be part of element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 19 of 24

40MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					65	N/A	N/A
1	2A	5190	38	484T	9.95		
		5230	46	484T	10.05		
		5270	54	484T	10.83		
2C	2C	5310	62	484T	10.88		
		5510	102	484T	9.89		
		5590	118	484T	10.03		
		5630	126	484T	9.93		
		5710	142	484T	9.97		
3	3	5755	151	484T	8.53		
		5795	159	484T	8.56		

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	18	36
1	5210	42	26T		9.75	10.45	10.03
2A	5290	58	26T		9.53	10.32	9.61
2C	5530	106	26T		9.63	10.23	9.62
	5610	122	26T		9.67	9.99	9.65
	5690	138	26T		9.30	9.95	9.34
3	5775	155	26T		8.80	9.26	8.99

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					37	44	52
1	5210	42	52T		9.75	10.47	9.93
2A	5290	58	52T		10.63	11.36	10.76
2C	5530	106	52T		9.64	10.18	9.83
	5610	122	52T		9.76	10.16	9.83
	5690	138	52T		9.73	10.22	9.72
3	5775	155	52T		9.14	9.71	9.33

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					53	56	60
1	5210	42	106T		10.10	10.48	10.34
2A	5290	58	106T		10.98	11.42	11.03
2C	5530	106	106T		9.83	10.21	9.93
	5610	122	106T		9.87	10.21	10.02
	5690	138	106T		9.71	10.02	9.70
3	5775	155	106T		8.97	9.33	8.98

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					61	62	64
1	5210	42	242T		9.88	10.40	10.05
2A	5290	58	242T		10.82	11.33	10.75
2C	5530	106	242T		9.81	10.21	10.00
	5610	122	242T		9.96	10.23	10.18
	5690	138	242T		9.79	10.23	9.78
3	5775	155	242T		9.37	9.70	9.45

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					65	66	N/A
1	5210	42	484T		10.18	10.19	
2A	5290	58	484T		10.75	10.86	
2C	5530	106	484T		9.96	10.24	
	5610	122	484T		10.10	10.07	
	5690	138	484T		10.02	10.24	
3	5775	155	484T		9.23	9.27	

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					67	N/A	N/A
1	5210	42	996T		10.18		
2A	5290	58	996T		11.24		
2C	5530	106	996T		9.85		
	5610	122	996T		9.90		
	5690	138	996T		10.00		
3	5775	155	996T		9.45		

FCC ID: BCGA2324	 PCTEST Prove to be part of the element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 20 of 24

Table 4
Maximum 5 GHz 802.11ax RU Time-Averaged WLAN Output Power – Ant 2A

20MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	4	8
20MHz BW	1	5180	36	26T	9.80	10.26	9.82
		5200	40	26T	9.80	10.35	9.88
		5220	44	26T	9.77	10.37	10.01
		5240	48	26T	10.00	10.47	10.11
	2A	5260	52	26T	8.80	9.41	8.81
		5280	56	26T	9.01	9.59	9.21
		5300	60	26T	9.07	9.74	9.25
		5320	64	26T	8.95	9.58	9.19
	2C	5500	100	26T	9.85	10.44	10.02
		5520	120	26T	9.82	10.46	9.85
		5620	124	26T	9.80	10.30	9.89
		5720	144	26T	9.96	10.42	9.92
20MHz BW	3	5745	149	26T	10.56	11.02	10.41
		5785	157	26T	10.31	10.79	10.26
		5825	165	26T	10.70	11.23	10.57
	1	5180	36	52T	9.88	10.28	9.95
		5200	40	52T	9.98	10.32	10.05
		5220	44	52T	9.92	10.33	10.03
		5240	48	52T	9.90	10.40	10.03
	2A	5260	52	52T	8.77	9.22	8.86
		5280	56	52T	8.85	9.36	9.01
		5300	60	52T	9.11	9.55	9.20
		5320	64	52T	8.97	9.51	9.20
	2C	5500	100	52T	10.01	10.41	10.10
		5600	120	52T	9.94	10.36	10.04
		5580	124	52T	9.94	10.25	9.97
		5720	144	52T	9.84	10.13	9.86
20MHz BW	3	5745	149	52T	10.68	10.93	10.50
		5785	157	52T	10.40	10.69	10.36
		5825	165	52T	10.84	11.06	10.81
	1	5180	36	242T	10.13	N/A	N/A
		5200	40	242T	10.29		
		5200	44	242T	10.17		
		5240	48	242T	10.23		
	2A	5260	52	242T	9.34		
		5260	56	242T	9.35		
		5300	60	242T	9.51		
		5320	64	242T	9.41		
	2C	5500	100	242T	10.18		
		5600	120	242T	10.25		
		5620	124	242T	10.09		
		5720	144	242T	9.83		
20MHz BW	3	5745	149	242T	10.26		
		5785	157	242T	10.53		
		5825	165	242T	10.93		
	1	5180	38	26T	9.78	10.40	9.81
		5230	46	26T	9.57	10.48	9.88
		5270	54	26T	8.43	9.36	8.80
		5310	62	26T	8.60	9.58	9.06
	2A	5510	102	26T	9.76	10.54	10.00
		5590	118	26T	9.90	10.74	10.03
		5630	126	26T	9.80	10.57	9.90
		5710	142	26T	9.84	10.57	9.83
	2C	5755	151	26T	10.29	10.90	10.25
		5795	159	26T	10.52	11.23	10.69
40MHz BW	1	5180	36	106T	10.01	10.06	
		5200	40	106T	10.12	10.18	
		5220	44	106T	10.15	10.31	
		5240	48	106T	10.10	10.20	
	2A	5260	52	106T	8.93	9.07	
		5280	56	106T	8.95	9.14	
		5300	60	106T	9.22	9.38	
		5320	64	106T	9.23	9.31	
	2C	5500	100	106T	10.14	10.29	
		5600	120	106T	10.19	10.15	
		5620	124	106T	10.10	10.20	
		5720	144	106T	9.90	9.76	
40MHz BW	3	5745	149	106T	10.75	10.76	
		5785	157	106T	10.61	10.57	
		5825	165	106T	10.96	11.02	
	1	5180	36	242T	10.13	N/A	N/A
		5200	40	242T	10.29		
		5200	44	242T	10.17		
		5240	48	242T	10.23		
	2A	5260	52	242T	9.34		
		5260	56	242T	9.35		
		5300	60	242T	9.51		
		5320	64	242T	9.41		
	2C	5500	100	242T	10.18		
		5600	120	242T	10.25		
		5620	124	242T	10.09		
		5720	144	242T	9.83		
40MHz BW	3	5745	149	242T	10.26		
		5785	157	242T	10.53		
		5825	165	242T	10.93		
	1	5180	38	52T	9.65	10.45	10.00
		5230	46	52T	9.75	10.48	9.97
		5270	54	52T	8.90	9.48	8.85
		5310	62	52T	8.85	9.63	9.10
	2A	5510	102	52T	9.90	10.68	10.10
		5590	118	52T	9.90	10.60	9.99
		5630	126	52T	9.86	10.47	9.85
		5710	142	52T	9.78	10.30	9.58
	2C	5755	151	52T	10.46	11.06	10.42
		5795	159	52T	10.42	10.96	10.47
40MHz BW	1	5180	38	242T	10.15	10.33	
		5230	46	242T	10.32	10.39	
		5270	54	242T	9.08	9.25	
		5310	62	242T	9.24	9.43	
	2A	5510	102	242T	10.05	10.25	
		5590	118	242T	10.12	10.15	
		5670	126	242T	9.95	10.10	
		5710	142	242T	9.83	9.81	
	2C	5755	151	242T	10.63	10.59	
		5795	159	242T	10.60	10.62	
	3	5180	38	106T	9.61	10.33	9.99
		5230	46	106T	9.73	10.35	9.93
		5270	54	106T	8.79	9.44	9.03
		5310	62	106T	9.00	9.60	9.33
40MHz BW	2A	5510	102	106T	9.87	10.35	9.90
		5590	118	106T	9.95	10.68	10.14
		5670	126	106T	9.91	10.46	10.06
		5710	142	106T	9.77	10.23	9.75
	2C	5755	151	106T	10.50	10.96	10.51
		5795	159	106T	10.57	11.00	10.51

FCC ID: BCGA2324	 PCTEST Prove to be part of the element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 21 of 24

40MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					65	N/A	N/A
1	2A	5190	38	484T	10.34		
		5230	46	484T	10.27		
		5270	54	484T	9.08		
2C	2A	5310	62	484T	9.10		
		5510	102	484T	9.81		
		5550	118	484T	10.00		
		5630	126	484T	10.06		
		5710	142	484T	9.80		
3	2A	5755	151	484T	10.53		
		5795	159	484T	10.32		

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	18	36
1	2A	5210	42	26T	9.11	9.89	9.41
		5290	58	26T	8.61	9.07	8.73
		5530	106	26T	8.51	9.02	8.57
2C	2A	5610	122	26T	9.97	10.47	9.78
		5690	138	26T	9.92	10.32	9.75
3	2A	5775	155	26T	10.48	11.06	10.34

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					37	44	52
1	2A	5210	42	52T	9.61	10.12	9.72
		5290	58	52T	8.75	9.31	8.77
		5530	106	52T	9.65	10.14	9.89
2C	2A	5610	122	52T	9.89	10.41	9.76
		5690	138	52T	9.90	10.35	9.75
3	2A	5775	155	52T	10.40	10.86	10.48

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					53	56	60
1	2A	5210	42	106T	9.81	10.19	9.85
		5290	58	106T	9.16	9.63	9.10
		5530	106	106T	10.23	10.45	10.06
2C	2A	5610	122	106T	9.80	10.16	9.81
		5690	138	106T	10.43	10.57	9.87
3	2A	5775	155	106T	10.89	10.95	10.34

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					65	66	N/A
1	2A	5210	42	484T	9.70	9.76	
		5290	58	484T	9.25	9.24	
		5530	106	484T	10.43	10.64	
2C	2A	5610	122	484T	10.17	10.25	
		5690	138	484T	10.24	10.06	
3	2A	5775	155	484T	10.50	10.34	

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					67	N/A	N/A
1	2A	5210	42	996T	10.22		
		5290	58	996T	9.50		
		5530	106	996T	10.29		
2C	2A	5610	122	996T	10.40		
		5690	138	996T	10.42		
3	2A	5775	155	996T	10.75		

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 22 of 24

Table 5
Maximum 5 GHz 802.11ax RU Time-Averaged WLAN Output Power – Ant 1B

20MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	4	8
20MHz BW	1	5180	36	26T	9.80	10.26	9.82
		5200	40	26T	9.80	10.35	9.88
		5220	44	26T	9.77	10.37	10.01
		5240	48	26T	10.00	10.47	10.11
	2A	5260	52	26T	8.80	9.41	8.81
		5280	56	26T	9.01	9.59	9.21
		5300	60	26T	9.07	9.74	9.25
		5320	64	26T	8.95	9.58	9.19
	2C	5500	100	26T	9.85	10.44	10.02
		5520	120	26T	9.82	10.46	9.85
		5620	124	26T	9.80	10.30	9.89
		5720	144	26T	9.96	10.42	9.92
20MHz BW	3	5745	149	26T	10.56	11.02	10.41
		5785	157	26T	10.31	10.79	10.26
		5825	165	26T	10.70	11.23	10.57
20MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					37	39	40
20MHz BW	1	5180	36	52T	9.88	10.28	9.95
		5200	40	52T	9.98	10.32	10.05
		5220	44	52T	9.92	10.33	10.03
		5240	48	52T	9.90	10.40	10.03
	2A	5260	52	52T	8.77	9.22	8.86
		5280	56	52T	8.85	9.36	9.01
		5300	60	52T	9.11	9.55	9.20
		5320	64	52T	8.97	9.51	9.20
	2C	5500	100	52T	10.01	10.41	10.10
		5600	120	52T	9.94	10.36	10.04
		5580	124	52T	9.94	10.25	9.97
		5720	144	52T	9.84	10.13	9.86
20MHz BW	3	5745	149	52T	10.68	10.93	10.50
		5785	157	52T	10.40	10.69	10.36
		5825	165	52T	10.84	11.06	10.81
20MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					61	N/A	N/A
20MHz BW	1	5180	36	242T	10.13		
		5200	40	242T	10.29		
		5200	44	242T	10.17		
		5240	48	242T	10.23		
	2A	5260	52	242T	9.34		
		5260	56	242T	9.35		
		5300	60	242T	9.51		
		5320	64	242T	9.41		
	2C	5500	100	242T	10.18		
		5600	120	242T	10.25		
		5620	124	242T	10.09		
		5720	144	242T	9.83		
20MHz BW	3	5745	149	242T	10.26		
		5785	157	242T	10.53		
		5825	165	242T	10.93		
40MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	8	17
40MHz BW	1	5190	38	26T	9.78	10.40	9.81
		5230	46	26T	9.57	10.48	9.88
		5270	54	26T	8.43	9.36	8.80
		5310	62	26T	8.60	9.58	9.06
	2A	5510	102	26T	9.76	10.54	10.00
		5590	118	26T	9.90	10.74	10.03
		5630	126	26T	9.80	10.57	9.90
		5710	142	26T	9.84	10.57	9.83
	2C	5755	151	26T	10.29	10.90	10.25
		5795	159	26T	10.52	11.23	10.69
40MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					53	54	56
40MHz BW	1	5190	38	106T	9.61	10.33	9.99
		5230	46	106T	9.73	10.35	9.93
		5270	54	106T	8.79	9.44	9.03
		5310	62	106T	9.00	9.60	9.33
	2A	5510	102	106T	9.87	10.35	9.90
		5590	118	106T	9.95	10.68	10.14
		5670	126	106T	9.91	10.46	10.06
		5710	142	106T	9.77	10.23	9.75
	2C	5755	151	106T	10.50	10.96	10.51
		5795	159	106T	10.57	11.00	10.51
40MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					61	62	N/A
40MHz BW	1	5190	38	242T	10.15	10.33	
		5230	46	242T	10.32	10.39	
		5270	54	242T	9.08	9.25	
		5310	62	242T	9.24	9.43	
	2A	5510	102	242T	10.05	10.25	
		5590	118	242T	10.12	10.15	
		5670	126	242T	9.95	10.10	
		5710	142	242T	9.83	9.81	
	2C	5755	151	242T	10.63	10.59	
		5795	159	242T	10.60	10.62	

FCC ID: BCGA2324	 PCTEST Prove to be part of the element	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 23 of 24

40MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					65	N/A	N/A
1	2A	5190	38	484T	10.34		
		5230	46	484T	10.27		
		5270	54	484T	9.08		
2C	2C	5310	62	484T	9.10		
		5510	102	484T	9.81		
		5550	118	484T	10.00		
		5630	126	484T	10.06		
		5710	142	484T	9.80		
3	3	5755	151	484T	10.53		
		5795	159	484T	10.32		

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					0	18	36
1	5210	42	26T		9.11	9.89	9.41
2A	5290	58	26T		8.61	9.07	8.73
2C	5530	106	26T		8.51	9.02	8.57
	5610	122	26T		9.97	10.47	9.78
	5690	138	26T		9.92	10.32	9.75
3	5775	155	26T		10.48	11.06	10.34

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					37	44	52
1	5210	42	52T		9.61	10.12	9.72
2A	5290	58	52T		8.75	9.31	8.77
2C	5530	106	52T		9.65	10.14	9.89
	5610	122	52T		9.89	10.41	9.76
	5690	138	52T		9.90	10.35	9.75
3	5775	155	52T		10.40	10.86	10.48

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					53	56	60
1	5210	42	106T		9.81	10.19	9.85
2A	5290	58	106T		9.16	9.63	9.10
2C	5530	106	106T		10.23	10.45	10.06
	5610	122	106T		9.80	10.16	9.81
	5690	138	106T		10.43	10.57	9.87
3	5775	155	106T		10.89	10.95	10.34

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					61	62	64
1	5210	42	242T		10.00	10.42	9.73
2A	5290	58	242T		9.32	9.73	9.22
2C	5530	106	242T		10.27	10.44	10.17
	5610	122	242T		10.07	10.49	10.10
	5690	138	242T		10.57	10.61	10.00
3	5775	155	242T		10.76	10.91	10.40

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					65	66	N/A
1	5210	42	484T		9.70	9.76	
2A	5290	58	484T		9.25	9.24	
2C	5530	106	484T		10.43	10.64	
	5610	122	484T		10.17	10.25	
	5690	138	484T		10.24	10.06	
3	5775	155	484T		10.50	10.34	

80MHz BW	Band	Freq [MHz]	Channel	Tones	Avg Conducted Power (dBm)		
					RU Index		
					67	N/A	N/A
1	5210	42	996T		10.22		
2A	5290	58	996T		9.50		
2C	5530	106	996T		10.29		
	5610	122	996T		10.40		
	5690	138	996T		10.42		
3	5775	155	996T		10.75		

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Reviewed by: Quality Manager
Test Dates: 07/27/2020 – 08/18/2020	DUT Type: Tablet Device		APPENDIX H: Page 24 of 24

APPENDIX I: TIME-AVERAGED SAR VERIFICATION

FCC ID: BCGA2324	 PCTEST Proud to be part of element	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/20 – 08/18/2020	DUT Type: Tablet Device		APPENDIX I Page 1 of 6

1.1 Time-Averaged SAR Verification Summary

This device supports the manufacturer's time-averaged SAR (TAS) mechanism for WLAN operations. The output power is controlled in real-time so that the power averaged over any 60 second window does not exceed the level tested for SAR in this report. The time-averaged SAR algorithm tracks the energy contribution relative to the available energy budget for each transmitter, defined as the "utilization ratio." Once the utilization ratios for each of the individual WLAN transmitters are calculated, they are summed to derive the overall WLAN system power utilization ratio. This metric is used by the WLAN chipset to manage power levels over time and ensure that SAR limits are never exceeded.

Per FCC Guidance, the following test scenarios were defined to validate the TAS mechanism. The specific scenarios are constructed to validate the operation of the algorithm in all operational states, including transitions between states/antennas:

- Change in channel/band
- Change in antenna (includes connection drop scenario)
- Change in device state, e.g Cell on/off WiFi power change

Predefined transmit profiles for each test scenario are provided by the manufacturer's test automation software to control the operation of the DUT while synchronized operational data was recorded from internal firmware and external power monitors. The data was plotted over time relative to the utilization limit to demonstrate that the maximum time-averaged power is never exceeded. "Reported" values were output and captured directly from DUT firmware, while "Measured" results were obtained from external power metering. The uncertainty budget applied to the WLAN power control functions for this device is 1.5 dB. In all test cases, WLAN radios were configured to operate at 100% duty cycle.

Table 1-1
Test Configurations for Time-Averaged SAR Verification

Mode	Antenna	Channel	Plim (dBm)	Plim (mW)
802.11b, 22 MHz Bandwidth	3A	6	13	20
802.11b, 22 MHz Bandwidth (Reduced)	3A	6	6	4
802.11b, 22 MHz Bandwidth	1A	6	13.75	24
802.11a, 20 MHz Bandwidth	2B	149	9.75	9
802.11a, 20 MHz Bandwidth	2A	149	11.25	13

Plim is the maximum time-averaged output power evaluated for SAR compliance

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/20 – 08/18/2020	DUT Type: Tablet Device		APPENDIX I Page 2 of 6

1.2 Verification Summary

Scenario 1: Change in Antenna

For this test, the effect on the time-averaging algorithm from a change in the active transmit antenna was evaluated. Figures I-1 and I-2 show a switch of 2.4 GHz transmissions from antenna 3A to antenna 1A at Time = 120 s, while Figures I-3 and I-4 show a comparable transition for antenna 2B to antenna 2A 5 GHz transmissions. In both cases the test automation is controlling the WLAN radios to operate at 100% duty cycle. In both cases the utilization ratio never exceeds 100% and the average transmit power never exceeds the Plim of each respective antenna.




Figure I-1
60s Average SAR Utilization vs. Time, 2.4 GHz




Figure I-2
60s Average Power vs. Time, 2.4 GHz

FCC ID: BCGA2324	 PCTEST Proud to be part of 	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/20 – 08/18/2020	DUT Type: Tablet Device		APPENDIX I Page 3 of 6




Figure I-3
60s Average SAR Utilization vs. Time, 5 GHz




Figure I-4
60s Average Power vs. Time, 5 GHz

FCC ID: BCGA2324	 SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/20 – 08/18/2020	DUT Type: Tablet Device	APPENDIX I Page 4 of 6

Scenario 2: Change in Channel/Band Test Case

This test demonstrates the efficacy of the time-averaged SAR algorithm while switching between 2.4 GHz and 5 GHz WLAN bands. In addition, it shows that the algorithm tracks time-averaged power and system utilization when the active transmitter is disabled and then reconnects.

The 2.4 GHz Ant 3A transmitter is active at 100% duty cycle until Time = 120 s. When 2.4 GHz transmissions cease, the 5 GHz Ant 2B transmitter is activated and begins to negotiate a new connection. The connection is established and the increase in average transmit power and utilization can clearly be seen. In this case the utilization ratio never exceeds 100% and the average transmit power never exceeds the Plim of each respective antenna.




Figure I-5
60s Average Utilization vs. Time during Band Switch




Figure I-6
60s Average Power vs. Time during Band Switch

FCC ID: BCGA2324	 PCTEST Proud to be part of  element	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/20 – 08/18/2020	DUT Type: Tablet Device		APPENDIX I Page 5 of 6

Scenario 3: Change in Device State

This test demonstrates the efficacy of the time-averaged SAR algorithm when an external power control trigger is activated, transitioning between cell off and cell on at Time = 120 s.

The 2.4 GHz Ant 3A transmitter is active at 100% duty cycle until Time = 120 s. At this point a cellular connection occurs. The connection is established and the decrease in average transmit power and can clearly be seen, while utilization remains consistent. In this case the utilization ratio never exceeds 100% and the average transmit power never exceeds the Plim of the device state.




Figure I-7
60s Average Utilization vs. Time during Mode Switch




Figure I-8
60s Average Power vs. Time during Mode Switch

FCC ID: BCGA2324	 PCTEST Proud to be part of  element	SAR EVALUATION REPORT	Approved by: Quality Manager
Test Dates: 07/27/20 – 08/18/2020	DUT Type: Tablet Device		APPENDIX I Page 6 of 6

APPENDIX J: PROBE AND DIPOLE CALIBRATION CERTIFICATES

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client: **PG Test**

Certificate No.: **D750V3-1097_Sep17**

CALIBRATION CERTIFICATE

Object: **D750V3 - SN:1097**

Calibration procedure(s): **QA CAL-05.v9**
Calibration procedure for dipole validation kits above 700 MHz

Calibration date: **September 08, 2017**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature $(22 \pm 3)^\circ\text{C}$ and humidity $< 70\%$.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02528)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	31-May-17 (No. EX3-7349_May17)	May-18
DAE4	SN: 601	28-Mar-17 (No. DAE4-601_Mar17)	Mar-18

Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292763	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-16)	In house check: Oct-17

Calibrated by: **Claudio Leubler** Function: **Laboratory Technician**

Approved by: **Katja Pokóvic** Technical Manager

Signature:

Issued: September 8, 2017

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions:** Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:** The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:** These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:** One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:** SAR measured at the stated antenna input power.
- SAR normalized:** SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:** The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	15 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	750 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	41.9	0.89 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	41.2 $\pm$ 6 %	0.90 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	2.08 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	8.22 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	1.36 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	5.39 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	55.5	0.96 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	55.5 $\pm$ 6 %	0.96 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	2.14 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	8.56 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	1.42 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	5.68 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	54.4 Ω - 0.6 j Ω
Return Loss	- 27.5 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	50.0 Ω - 3.6 j Ω
Return Loss	- 28.8 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.034 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	July 05, 2013

DASY5 Validation Report for Head TSL

Date: 08.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 750 MHz; Type: D750V3; Serial: D750V3 - SN:1097

Communication System: UID 0 - CW; Frequency: 750 MHz

Medium parameters used: $f = 750 \text{ MHz}$; $\sigma = 0.9 \text{ S/m}$; $\epsilon_r = 41.2$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(10.49, 10.49, 10.49); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 4.9 (front); Type: QD 00L P49 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: $dx=5\text{mm}$, $dy=5\text{mm}$, $dz=5\text{mm}$

Reference Value = 58.59 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 3.19 W/kg

SAR(1 g) = 2.08 W/kg; SAR(10 g) = 1.36 W/kg

Maximum value of SAR (measured) = 2.80 W/kg



0 dB = 2.80 W/kg = 4.47 dBW/kg

Impedance Measurement Plot for Head TSL

8 Sep 2017 13:09:24
 CH1 S11 1 U FS 1: 54.383 Ω -552.73 m Ω 383.92 pF 750.000 000 MHz

*

De1

CA

Avg
16

H1d

CH2 S11 LOG 5 dB/REF -20 dB 1:-27.463 dB 750.000 000 MHz

CA

Avg
16

H1d

START 550.000 000 MHz

STOP 950.000 000 MHz

DASY5 Validation Report for Body TSL

Date: 08.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 750 MHz; Type: D750V3; Serial: D750V3 - SN:1097

Communication System: UID 0 - CW; Frequency: 750 MHz

Medium parameters used: $f = 750$ MHz; $\sigma = 0.96$ S/m; $\epsilon_r = 55.5$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(10.35, 10.35, 10.35); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 4.9 (Back); Type: QD 00R P49 AA; Serial: 1005
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 56.96 V/m; Power Drift = -0.00 dB

Peak SAR (extrapolated) = 3.16 W/kg

SAR(1 g) = 2.14 W/kg; SAR(10 g) = 1.42 W/kg

Maximum value of SAR (measured) = 2.81 W/kg



0 dB = 2.81 W/kg = 4.49 dBW/kg

Impedance Measurement Plot for Body TSL

8 Sep 2017 13:08:43
 CH1 S11 1 U FS 1: 49.951 Ω -3.6172 Ω 58.666 pF 750.000 000 MHz

*
 De1
 CA

Avg
 15

H1d

CH2 S11 LOG 5 dB/REF -20 dB 1: -28.833 dB 750.000 000 MHz

CA

Avg
 16

H1d

START 550.000 000 MHz

STOP 950.000 000 MHz

Certification of Calibration

Object D750V3 – SN: 1097

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.



Extended Calibration date: September 08, 2018

Description: SAR Validation Dipole at 750 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	9/14/2017	Annual	9/14/2018	US39170118
Agilent	N5182A	MXG Vector Signal Generator	3/19/2018	Annual	3/19/2019	US46240505
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2496A	Power Meter	10/9/2017	Annual	10/9/2018	1138001
Anritsu	MA2411B	Pulse Power Sensor	11/15/2017	Annual	11/15/2018	1339007
Anritsu	MA2411B	Pulse Power Sensor	11/22/2017	Annual	11/22/2018	1339008
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/14/2017	Biennial	2/14/2019	170112507
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	6/4/2018	Annual	6/4/2019	MY53401181
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2209-10	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	PE5011-1	Torque Wrench	7/19/2017	Biennial	7/19/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/15/2018	Annual	5/15/2019	1070
SPEAG	ES3DV3	SAR Probe	9/18/2017	Annual	9/18/2018	3287
SPEAG	DAE4	Data Acquisition Electronics	1/26/2018	Annual	1/26/2019	1533
SPEAG	EX3DV4	SAR Probe	7/20/2018	Annual	7/20/2019	7416
SPEAG	DAE4	Dasy Data Acquisition Electronics	1/18/2018	Annual	1/18/2019	793

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Sangmin Cha	Team Lead Engineer	
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 23.0 dBm	Measured Head SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2018	1.034	1.644	1.7	3.41%	1.078	1.12	3.90%	54.4	54.1	0.3	-0.6	-0.6	0	-27.5	-25.5	7.30%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 23.0 dBm	Measured Body SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2018	1.034	1.712	1.78	3.97%	1.136	1.17	2.99%	50	49.6	0.4	-3.6	-3.1	0.5	-28.8	-30.3	-5.20%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Certification of Calibration

Object D750V3 – SN: 1097

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: September 8, 2019

Description: SAR Validation Dipole at 750 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	10/2/2018	Annual	10/2/2019	US39170118
Agilent	E4438C	ESG Vector Signal Generator	6/27/2019	Annual	6/27/2020	MY45093852
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2495A	Power Meter	10/21/2018	Annual	10/21/2019	941001
Anritsu	MA2411B	Pulse Power Sensor	10/30/2018	Annual	10/30/2019	1207470
Anritsu	MA2411B	Pulse Power Sensor	11/20/2018	Annual	11/20/2019	1339007
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/28/2018	Biennial	2/28/2020	170330160
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	NC-100	Torque Wrench	11/1/2017	Biennial	11/1/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/7/2019	Annual	5/7/2020	1070
SPEAG	EX3DV4	SAR Probe	1/24/2019	Annual	1/24/2020	7490
SPEAG	DAE4	Data Acquisition Electronics	1/15/2019	Annual	1/15/2020	1532

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION

Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.

The following dipole was checked to pass the above 3 requirements to have 3-year calibration period from the calibration date:


Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 23.0 dBm	Measured Head SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Head (10g) W/kg @ 23.0 dBm	Measured Head SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2019	1.034	1.644	1.55	-5.11%	1.078	1.03	-4.45%	54.4	55.1	0.7	-0.6	1.7	2.3	-27.5	-25	5.50%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 23.0 dBm	Measured Body SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2019	1.034	1.712	1.65	-3.62%	1.136	1.1	-3.17%	50	51	1	-3.6	-1.3	2.3	-28.8	-31.9	-10.80%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL

CH1 S11 1 U FS 1: 55.143 Ω 1.7363 Ω 368.46 pF 750.000 000 MHz

*
De1
Cor


↑



CH1 S11 LOG 5 dB/REF -20 dB 1:-26.011 dB 750.000 000 MHz

*
De1
Smo
Cor

↑





Object:

D750V3 – SN: 1097

Date Issued:

09/08/2019

Impedance & Return-Loss Measurement Plot for Body TSL





Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client: **PC Test**

Certificate No.: **D835V2-4d180_May18**

CALIBRATION CERTIFICATE

Object: **D835V2 - SN:4d180**

Calibration procedure(s): **QA CAL 05 V10**
Calibration procedure for dipole validation kits above 700 MHz

Calibration date: **May 18, 2018**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature $(22 \pm 3)^\circ\text{C}$ and humidity $< 70\%$.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-18 (No. 217-02672/02673)	Apr-19
Power sensor NRP-Z91	SN: 103244	04-Apr-18 (No. 217-02672)	Apr-19
Power sensor NRP-Z91	SN: 103245	04-Apr-18 (No. 217-02673)	Apr-19
Reference 20 dB Attenuator	SN: 5058 (20k)	04-Apr-18 (No. 217-02682)	Apr-19
Type-N mismatch combination	SN: 5047.2 / 06327	04-Apr-18 (No. 217-02683)	Apr-19
Reference Probe EX3DV4	SN: 7349	30-Dec-17 (No. EX3-7349_Dec17)	Dec-18
DAE4	SN: 601	28-Oct-17 (No. DAE4-601_Oct17)	Oct-18

Secondary Standards	ID #	Check Date (In house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (In house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (In house check Oct-17)	In house check: Oct-18

Calibrated by: **Manu Seltz** Name: **Manu Seltz** Function: **Laboratory Technician** Signature:

Approved by: **Karla Pokovic** Name: **Karla Pokovic** Function: **Technical Manager** Signature:

Issued: May 22, 2018

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions:** Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:** The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:** These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:** One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:** SAR measured at the stated antenna input power.
- SAR normalized:** SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:** The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.1
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	15 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	835 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	41.5	0.90 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	40.8 $\pm$ 6 %	0.92 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	2.45 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	9.60 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	1.58 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	6.22 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	55.2	0.97 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	54.6 $\pm$ 6 %	0.99 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	2.44 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	9.59 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	1.60 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	6.31 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	50.7 Ω - 5.1 j Ω
Return Loss	- 25.9 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	47.2 Ω - 8.2 j Ω
Return Loss	- 21.1 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.396 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	September 24, 2014

DASY5 Validation Report for Head TSL

Date: 17.05.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 835 MHz; Type: D835V2; Serial: D835V2 - SN:4d180

Communication System: UID 0 - CW; Frequency: 835 MHz

Medium parameters used: $f = 835 \text{ MHz}$; $\sigma = 0.92 \text{ S/m}$; $\epsilon_r = 40.8$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(9.9, 9.9, 9.9) @ 835 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 4.9 (front); Type: QD 00L P49 AA; Serial: 1001
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Head Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:



Measurement grid: $dx=5\text{mm}$, $dy=5\text{mm}$, $dz=5\text{mm}$

Reference Value = 65.39 V/m; Power Drift = -0.06 dB

Peak SAR (extrapolated) = 3.78 W/kg


SAR(1 g) = 2.45 W/kg; SAR(10 g) = 1.58 W/kg

Maximum value of SAR (measured) = 3.32 W/kg



0 dB = 3.32 W/kg = 5.21 dBW/kg

Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 18.05.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 835 MHz; Type: D835V2; Serial: D835V2 - SN:4d180

Communication System: UID 0 - CW; Frequency: 835 MHz

Medium parameters used: $f = 835$ MHz; $\sigma = 0.99$ S/m; $\epsilon_r = 54.6$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(10.05, 10.05, 10.05) @ 835 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 4.9 (Back); Type: QD 00R P49 AA; Serial: 1005
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Body Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 60.80 V/m; Power Drift = -0.02 dB

Peak SAR (extrapolated) = 3.62 W/kg

SAR(1 g) = 2.44 W/kg; SAR(10 g) = 1.6 W/kg

Maximum value of SAR (measured) = 3.23 W/kg




0 dB = 3.23 W/kg = 5.09 dBW/kg


Impedance Measurement Plot for Body TSL

CH1 S11 1 U FS 18 May 2018 10:19:30
1: 47.234 Ω -8.1504 Ω 23.386 pF 835.000 000 MHz

*
Del
Cor



Avg
16
H1d



Certification of Calibration

Object D835V2 – SN: 4d180

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: May 16, 2019

Description: SAR Validation Dipole at 835 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	10/2/2018	Annual	10/2/2019	US39170118
Agilent	N5182A	MXG Vector Signal Generator	6/15/2018	Annual	6/15/2019	MY47420837
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2495A	Power Meter	10/21/2018	Annual	10/21/2019	941001
Anritsu	MA2411B	Pulse Power Sensor	10/30/2018	Annual	10/30/2019	1207470
Anritsu	MA2411B	Pulse Power Sensor	11/20/2018	Annual	11/20/2019	1339007
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/28/2018	Biennial	2/28/2020	170330160
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	6/4/2018	Annual	6/4/2019	MY53401181
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	PE5011-1	Torque Wrench	7/19/2017	Biennial	7/19/2019	N/A
SPEAG	DAKS-3.5	Portable DAK	9/11/2018	Annual	9/11/2019	1045
SPEAG	EX3DV4	SAR Probe	7/20/2018	Annual	7/20/2019	7416
SPEAG	DAE4	Dasy Data Acquisition Electronics	7/10/2018	Annual	7/10/2019	1402

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 23.0 dBm	Measured Head SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Head (10g) W/kg @ 23.0 dBm	Measured Head SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
5/18/2018	5/16/2019	1.396	1.92	1.89	3.65%	1.244	1.3	4.50%	50.7	49.8	0.9	-5.1	-6.5	1.4	-25.9	-25.2	2.60%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 23.0 dBm	Measured Body SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
5/18/2018	5/16/2019	1.396	1.918	2.05	6.88%	1.262	1.34	6.18%	47.2	47.3	0.1	-8.2	-6.3	1.9	-21.1	-23.1	-9.20%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Certification of Calibration

Object D835V2 – SN: 4d180

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: May 18, 2020

Description: SAR Validation Dipole at 835 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	1/16/2020	Annual	1/16/2021	US39170118
Agilent	N5182A	MXG Vector Signal Generator	8/19/2019	Annual	8/19/2020	MY47420837
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	MA2411B	Pulse Power Sensor	1/21/2020	Annual	1/21/2021	1207470
Anritsu	MA2411B	Pulse Power Sensor	1/21/2020	Annual	1/21/2021	1339007
Anritsu	ML2495A	Power Meter	1/15/2020	Annual	1/15/2021	1328004
Control Company	62344-734	Therm./ Clock/ Humidity Monitor	3/18/2019	Biennial	3/18/2021	192038436
Control Company	4352	Ultra Long Stem Thermometer	8/2/2018	Biennial	8/2/2020	181292000
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
MiniCircuits	VLF-6000+	Low Pass Filter	CBT	N/A	CBT	N/A
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	NC-100	Torque Wrench	5/23/2018	Biennial	5/23/2020	N/A
SPEAG	DAE4	Dasy Data Acquisition Electronics	8/12/2019	Annual	8/12/2020	1408
SPEAG	DAE4	Dasy Data Acquisition Electronics	3/19/2020	Annual	3/19/2021	604
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/12/2020	Annual	5/12/2021	1070
SPEAG	EX3DV4	SAR Probe	8/29/2019	Annual	8/29/2020	3949
SPEAG	EX3DV4	SAR Probe	3/20/2020	Annual	3/20/2021	7421

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Managing Director	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 3-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 23.0 dBm	Measured Head SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
5/18/2018	5/18/2020	1.396	1.92	2	4.17%	1.244	1.32	6.11%	50.7	51.2	0.5	-5.1	-1	4.1	-25.9	-28	-8.10%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 23.0 dBm	Measured Body SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
5/18/2018	5/18/2020	1.396	1.918	2	4.28%	1.262	1.31	3.80%	47.2	46.3	1.1	-8.2	-3.4	4.8	-21.1	-24.9	-18.00%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client: **PC Test**

Certificate No: **D850V2-1010_Sep17**

CALIBRATION CERTIFICATE

Object: **D850V2 - SN:1010**

Calibration procedure(s): **QACAL-05.v9**
Calibration procedure for dipole validation kits above 700 MHz

Calibration date: **September 08, 2017**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature $(22 \pm 3)^\circ\text{C}$ and humidity $< 70\%$.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02528)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	31-May-17 (No. EX3-7349_May17)	May-18
DAE4	SN: 601	28-Mar-17 (No. DAE4-601_Mer17)	Mar-18

Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-16)	In house check: Oct-17

Calibrated by: **Claudio Leubler** **Laboratory Technician**

Approved by: **Katja Pokovic** **Technical Manager**

Signature:

Signature:

Issued: September 8, 2017

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	15 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	850 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	41.5	0.92 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	40.9 $\pm$ 6 %	0.94 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	2.53 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	9.93 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	1.63 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	6.42 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	55.2	0.99 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	55.3 $\pm$ 6 %	0.99 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm ³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	2.55 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	10.2 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	1.67 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	6.68 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	50.2 Ω - 3.1 j Ω
Return Loss	- 30.2 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	46.6 Ω - 5.8 j Ω
Return Loss	- 23.2 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.432 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	September 04, 2012

DASY5 Validation Report for Head TSL

Date: 08.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 850 MHz; Type: D850V2; Serial: D850V2 - SN:1010

Communication System: UID 0 - CW; Frequency: 850 MHz

Medium parameters used: $f = 850$ MHz; $\sigma = 0.94$ S/m; $\epsilon_r = 40.9$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(9.93, 9.93, 9.93); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 4.9 (front); Type: QD 00L P49 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 63.32 V/m; Power Drift = -0.01 dB

Peak SAR (extrapolated) = 3.85 W/kg

SAR(1 g) = 2.53 W/kg; SAR(10 g) = 1.63 W/kg

Maximum value of SAR (measured) = 3.41 W/kg



0 dB = 3.41 W/kg = 5.33 dBW/kg

Impedance Measurement Plot for Head TSL

8 Sep 2017 13:24:25
 CH1 S11 1 U FS 1: 50.227 Ω -3.0996 Ω 60.408 pF 850.000 000 MHz

*

De1

CA

Avg
16

H1d

CH2 S11 LOG 5 dB/REF -20 dB 1: -30.173 dB 850.000 000 MHz

CA

Avg
16

H1d

START 650.000 000 MHz

STOP 1 850.000 000 MHz

DASY5 Validation Report for Body TSL

Date: 08.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 850 MHz; Type: D850V2; Serial: D850V2 - SN:1010

Communication System: UID 0 - CW; Frequency: 850 MHz

Medium parameters used: $f = 850 \text{ MHz}$; $\sigma = 0.99 \text{ S/m}$; $\epsilon_r = 55.3$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(10.11, 10.11, 10.11); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 4.9 (Back); Type: QD 00R P49 AA; Serial: 1005
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: $dx=5\text{mm}$, $dy=5\text{mm}$, $dz=5\text{mm}$

Reference Value = 61.09 V/m; Power Drift = -0.02 dB


Peak SAR (extrapolated) = 3.79 W/kg

SAR(1 g) = 2.55 W/kg; SAR(10 g) = 1.67 W/kg

Maximum value of SAR (measured) = 3.36 W/kg



Impedance Measurement Plot for Body TSL



Certification of Calibration

Object D850V2 – SN: 1010

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.



Extended Calibration date: September 08, 2018

Description: SAR Validation Dipole at 850 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	9/14/2017	Annual	9/14/2018	US39170118
Agilent	N5182A	MXG Vector Signal Generator	3/19/2018	Annual	3/19/2019	US46240505
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2496A	Power Meter	10/9/2017	Annual	10/9/2018	1138001
Anritsu	MA2411B	Pulse Power Sensor	11/15/2017	Annual	11/15/2018	1339007
Anritsu	MA2411B	Pulse Power Sensor	11/22/2017	Annual	11/22/2018	1339008
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/14/2017	Biennial	2/14/2019	170112507
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	6/4/2018	Annual	6/4/2019	MY53401181
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2209-10	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	PE5011-1	Torque Wrench	7/19/2017	Biennial	7/19/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/15/2018	Annual	5/15/2019	1070
SPEAG	ES3DV3	SAR Probe	9/18/2017	Annual	9/18/2018	3287
SPEAG	DAE4	Data Acquisition Electronics	1/26/2018	Annual	1/26/2019	1533
SPEAG	EX3DV4	SAR Probe	1/26/2018	Annual	1/26/2019	7490
SPEAG	DAE4	Data Acquisition Electronics	1/26/2018	Annual	1/26/2019	1532

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Sangmin Cha	Team Lead Engineer	
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 23.0 dBm	Measured Head SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Head (10g) W/kg @ 23.0 dBm	Measured Head SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2018	1.432	1.986	2.01	1.21%	1.284	1.31	2.02%	50.2	48.9	1.3	-3.1	-2.3	0.8	-30.2	-30.1	0.30%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 23.0 dBm	Measured Body SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2017	1.432	2.04	2.01	-1.47%	1.336	1.32	-1.20%	46.6	46.7	0.1	-5.8	-3.4	2.4	-23.2	-25.8	-11.20%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Certification of Calibration

Object D850V2 – SN: 1010

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: September 8, 2019

Description: SAR Validation Dipole at 850 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	10/2/2018	Annual	10/2/2019	US39170118
Agilent	E4438C	ESG Vector Signal Generator	6/27/2019	Annual	6/27/2020	MY45093852
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2495A	Power Meter	10/21/2018	Annual	10/21/2019	941001
Anritsu	MA2411B	Pulse Power Sensor	10/30/2018	Annual	10/30/2019	1207470
Anritsu	MA2411B	Pulse Power Sensor	11/20/2018	Annual	11/20/2019	1339007
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/28/2018	Biennial	2/28/2020	170330160
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	NC-100	Torque Wrench	11/1/2017	Biennial	11/1/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/7/2019	Annual	5/7/2020	1070
SPEAG	EX3DV4	SAR Probe	1/24/2019	Annual	1/24/2020	7490
SPEAG	DAE4	Data Acquisition Electronics	1/15/2019	Annual	1/15/2020	1532

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 3-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 23.0 dBm	Measured Head SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2019	1.432	1.986	2.03	2.22%	1.284	1.33	3.55%	50.2	49.7	0.5	-3.1	-1.5	1.6	-30.2	-33.6	-11.30%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 23.0 dBm	Measured Body SAR (1g) W/kg @ 23.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 23.0 dBm	Measured Body SAR (10g) W/kg @ 23.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/8/2017	9/8/2019	1.432	2.04	2.05	0.49%	1.336	1.36	1.80%	46.6	47.2	0.6	-5.8	-3.4	2.4	-23.2	-27.1	-16.80%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL





Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client: **PC Test**

Certificate No.: **D1750V2-1092_May18**

CALIBRATION CERTIFICATE

Object: **D1750V2-SN1092**

Calibration procedure(s):

GA-GAL-05-V10
Calibration procedure for dipole validation kits above 700 MHz

SC ✓
5/31/2018

Calibration date:

May 15, 2018

BSN ✓
06/01/2019

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature $(22 \pm 3)^\circ\text{C}$ and humidity $< 70\%$.

ATM ✓
06/11/2020

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-18 (No. 217-02672/02673)	Apr-19
Power sensor NRP-Z91	SN: 103244	04-Apr-18 (No. 217-02672)	Apr-19
Power sensor NRP-Z91	SN: 103245	04-Apr-18 (No. 217-02673)	Apr-19
Reference 20 dB Attenuator	SN: 5058 (20k)	04-Apr-18 (No. 217-02682)	Apr-19
Type-N mismatch combination	SN: 5047.2 / 06327	04-Apr-18 (No. 217-02683)	Apr-19
Reference Probe EX3DV4	SN: 7349	30-Dec-17 (No. EX3-7349_Dec17)	Dec-18
DAE4	SN: 601	26-Oct-17 (No. DAE4-601_Oct17)	Oct-18
Secondary Standards	ID #	Check Date (In house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-05	SN: 100972	15-Jun-15 (In house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (In house check Oct-17)	In house check: Oct-18

	Name	Function	Signature
Calibrated by:	Manu Saitz	Laboratory Technician	
Approved by:	Katja Pokovic	Technical Manager	

Issued: May 17, 2018

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 0108**

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.1
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1750 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.1	1.37 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	39.0 $\pm$ 6 %	1.34 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	8.95 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	36.1 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	4.73 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	19.0 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.4	1.49 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	53.2 $\pm$ 6 %	1.46 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	8.99 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	36.4 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	4.81 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	19.4 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	49.2 Ω - 1.0 j Ω
Return Loss	- 37.8 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	44.8 Ω - 0.6 j Ω
Return Loss	- 25.2 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.217 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	November 07, 2012

DASY5 Validation Report for Head TSL

Date: 15.05.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2 - SN:1092

Communication System: UID 0 - CW; Frequency: 1750 MHz

Medium parameters used: $f = 1750$ MHz; $\sigma = 1.34$ S/m; $\epsilon_r = 39$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.5, 8.5, 8.5) @ 1750 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 106.8 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 16.3 W/kg

SAR(1 g) = 8.95 W/kg; SAR(10 g) = 4.73 W/kg

Maximum value of SAR (measured) = 13.8 W/kg



0 dB = 13.8 W/kg = 11.40 dBW/kg

Impedance Measurement Plot for Head TSL

15 May 2018 11:09:26
 [CH1] S11 1 U FS 1: 49.203 Ω -1.0117 Ω 89.892 pF 1 750.000 000 MHz


*

Del

CA

Avg
16

H1d




CH2 S11 LOG 5 dB/REF -20 dB 1: -37.762 dB 1 750.000 000 MHz

CA

Avg
16

H1d



DASY5 Validation Report for Body TSL

Date: 15.05.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2 - SN:1092

Communication System: UID 0 - CW; Frequency: 1750 MHz

Medium parameters used: $f = 1750$ MHz; $\sigma = 1.46$ S/m; $\epsilon_r = 53.2$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.35, 8.35, 8.35) @ 1750 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 101.4 V/m; Power Drift = -0.06 dB

Peak SAR (extrapolated) = 15.8 W/kg


SAR(1 g) = 8.99 W/kg; SAR(10 g) = 4.81 W/kg

Maximum value of SAR (measured) = 13.4 W/kg



0 dB = 13.4 W/kg = 11.27 dBW/kg

Impedance Measurement Plot for Body TSL



Certification of Calibration

Object D1750V2 – SN: 1092

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: May 15, 2019

Description: SAR Validation Dipole at 1750 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	10/2/2018	Annual	10/2/2019	US39170118
Agilent	N5182A	MXG Vector Signal Generator	6/15/2018	Annual	6/15/2019	MY47420837
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2495A	Power Meter	10/21/2018	Annual	10/21/2019	941001
Anritsu	MA2411B	Pulse Power Sensor	10/30/2018	Annual	10/30/2019	1207470
Anritsu	MA2411B	Pulse Power Sensor	11/20/2018	Annual	11/20/2019	1339007
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/28/2018	Biennial	2/28/2020	170330160
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	6/4/2018	Annual	6/4/2019	MY53401181
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2209-10	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	PE5011-1	Torque Wrench	7/19/2017	Biennial	7/19/2019	N/A
SPEAG	DAKS-3.5	Portable DAK	9/11/2018	Annual	9/11/2019	1045
SPEAG	EX3DV4	SAR Probe	7/20/2018	Annual	7/20/2019	7416
SPEAG	DAE4	Dasy Data Acquisition Electronics	7/10/2018	Annual	7/10/2019	1402

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION


Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.


The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Head (10g) W/kg @ 20.0 dBm	Measured Head SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
5/15/2018	5/15/2019	1.217	3.61	3.59	-0.55%	1.9	1.89	-0.53%	49.2	48.4	0.8	-1	-0.1	0.9	-37.8	-38.2	-1.00%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
5/15/2018	5/15/2019	1.217	3.64	3.62	-0.55%	1.94	1.91	-1.59%	44.8	44.2	0.6	-0.6	1.1	1.7	-25.2	-24.2	3.90%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Certification of Calibration

Object: D1750V2 – SN: 1092

Calibration procedure(s): Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: May 15, 2020

Description: SAR Validation Dipole at 1750 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	1/16/2020	Annual	1/16/2021	US39170118
Agilent	N5182A	MXG Vector Signal Generator	8/19/2019	Annual	8/19/2020	MY47420837
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	MA2411B	Pulse Power Sensor	1/21/2020	Annual	1/21/2021	1207470
Anritsu	MA2411B	Pulse Power Sensor	1/21/2020	Annual	1/21/2021	1339007
Anritsu	ML2495A	Power Meter	1/15/2020	Annual	1/15/2021	1328004
Control Company	62344-734	Therm./ Clock/ Humidity Monitor	3/18/2019	Biennial	3/18/2021	192038436
Control Company	4352	Ultra Long Stem Thermometer	8/2/2018	Biennial	8/2/2020	181292000
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
MiniCircuits	VLF-6000+	Low Pass Filter	CBT	N/A	CBT	N/A
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	NC-100	Torque Wrench	5/23/2018	Biennial	5/23/2020	N/A
SPEAG	DAE4	Dasy Data Acquisition Electronics	2/13/2020	Annual	2/13/2021	1403
SPEAG	DAE4	Dasy Data Acquisition Electronics	3/19/2020	Annual	3/19/2021	604
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/12/2020	Annual	5/12/2021	1070
SPEAG	EX3DV4	SAR Probe	2/19/2020	Annual	2/19/2021	7427
SPEAG	EX3DV4	SAR Probe	3/20/2020	Annual	3/20/2021	7421

Measurement Uncertainty = $\pm 23\%$ ($k=2$)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Managing Director	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.


The following dipole was checked to pass the above 3 requirements to have 3-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
5/15/2018	5/15/2020	1.217	3.61	3.7	2.49%	1.9	1.97	3.68%	49.2	46.7	2.5	-1	-2	1	-37.8	-31	18.00%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
5/15/2018	5/15/2020	1.217	3.64	3.77	3.57%	1.94	2	3.09%	44.8	43.7	1.1	-0.6	-0.1	0.5	-25.2	-23.6	6.30%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Calibration Laboratory of
Schmid & Partner
Engineering AG
 Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
 The Swiss Accreditation Service is one of the signatories to the EA
 Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **PC Test**

Certificate No: **D1750V2-1104_Sep17**

CALIBRATION CERTIFICATE

Object **D1750V2 - SN:1104**

Calibration procedure(s) **QA CAL-05.v9**
 Calibration procedure for dipole validation kits above 700 MHz

Calibration date: **September 07, 2017**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
 The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02528)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	31-May-17 (No. EX3-7349_May17)	May-18
DAE4	SN: 601	28-Mar-17 (No. DAE4-601_Mar17)	Mar-18

Secondary Standards	ID #	Check Date (In house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	16-Jun-15 (In house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (In house check Oct-16)	In house check: Oct-17

Calibrated by: **Michael Weber** Name: **Michael Weber** Function: **Laboratory Technician**

Approved by: **Katja Pokovic** Name: **Katja Pokovic** Technical Manager

Signature

[Signature]

[Signature]

Issued: September 7, 2017

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 0108**

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions:** Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:** The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:** These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:** One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:** SAR measured at the stated antenna input power.
- SAR normalized:** SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:** The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1750 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.1	1.37 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	39.1 $\pm$ 6 %	1.36 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.11 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	36.4 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	4.81 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	19.2 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.4	1.49 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	53.8 $\pm$ 6 %	1.46 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	9.03 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	36.6 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	4.85 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	19.6 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	50.8 Ω - 0.2 j Ω
Return Loss	- 41.5 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	46.5 Ω - 0.7 j Ω
Return Loss	- 28.7 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.217 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	May 16, 2013

DASY5 Validation Report for Head TSL

Date: 07.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2 - SN:1104

Communication System: UID 0 - CW; Frequency: 1750 MHz

Medium parameters used: $f = 1750 \text{ MHz}$; $\sigma = 1.36 \text{ S/m}$; $\epsilon_r = 39.1$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.73, 8.73, 8.73); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:



Measurement grid: $dx=5\text{mm}$, $dy=5\text{mm}$, $dz=5\text{mm}$

Reference Value = 104.9 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 17.0 W/kg

SAR(1 g) = 9.11 W/kg; SAR(10 g) = 4.81 W/kg

Maximum value of SAR (measured) = 13.9 W/kg




0 dB = 13.9 W/kg = 11.43 dBW/kg

Impedance Measurement Plot for Head TSL

7 Sep 2017 12:19:31
 CH1 S11 1 U FS 1: 50.834 Ω -150.39 m Ω 604.73 pF 1 750.000 000 MHz

*
 Del
 CA



Avg
 16


H1d

CH2 S11 LOG 5 dB/REF -20 dB 1: -41.481 dB 1 750.000 000 MHz

CA

Avg
 16

H1d



DASY5 Validation Report for Body TSL

Date: 07.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2 - SN:1104

Communication System: UID 0 - CW; Frequency: 1750 MHz

Medium parameters used: $f = 1750$ MHz; $\sigma = 1.46$ S/m; $\epsilon_r = 53.8$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.46, 8.46, 8.46); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 99.30 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 15.6 W/kg

SAR(1 g) = 9.03 W/kg; SAR(10 g) = 4.85 W/kg

Maximum value of SAR (measured) = 12.9 W/kg




0 dB = 12.9 W/kg = 11.11 dBW/kg

Impedance Measurement Plot for Body TSL


7 Sep 2017 12:18:38
CH1 S11 1 U FS 1: 46.527 Ω -689.45 m Ω 131.91 pF 1 750.000 000 MHz

*
Del
CA
Avg
16
H1d



CH2 S11 LOG 5 dB/REF -20 dB 1:-28.710 dB 1 750.000 000 MHz

CA
Avg
16
H1d



Certification of Calibration

Object D1750V2 – SN: 1104

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.



Extended Calibration date: September 07, 2018

Description: SAR Validation Dipole at 1750 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	9/14/2017	Annual	9/14/2018	US39170118
Agilent	N5182A	MXG Vector Signal Generator	3/19/2018	Annual	3/19/2019	US46240505
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2496A	Power Meter	10/9/2017	Annual	10/9/2018	1138001
Anritsu	MA2411B	Pulse Power Sensor	11/15/2017	Annual	11/15/2018	1339007
Anritsu	MA2411B	Pulse Power Sensor	11/22/2017	Annual	11/22/2018	1339008
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/14/2017	Biennial	2/14/2019	170112507
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	6/4/2018	Annual	6/4/2019	MY53401181
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2209-10	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	PE5011-1	Torque Wrench	7/19/2017	Biennial	7/19/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/15/2018	Annual	5/15/2019	1070
SPEAG	ES3DV3	SAR Probe	9/18/2017	Annual	9/18/2018	3287
SPEAG	DAE4	Data Acquisition Electronics	1/26/2018	Annual	1/26/2019	1533

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Sangmin Cha	Team Lead Engineer	
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Head (10g) W/kg @ 20.0 dBm	Measured Head SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2018	1.217	3.64	3.62	-0.55%	1.92	1.94	1.04%	50.8	49.8	1	-0.2	-0.3	0.1	-41.5	-35.9	13.50%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2018	1.217	3.66	3.84	4.92%	1.96	2.07	5.61%	46.527	45.4	1.1	-0.69	-1.6	0.9	-28.7	-25.8	10.10%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Certification of Calibration

Object D1750V2 – SN: 1104

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: September 7, 2019

Description: SAR Validation Dipole at 1750 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	10/2/2018	Annual	10/2/2019	US39170118
Agilent	E4438C	ESG Vector Signal Generator	6/27/2019	Annual	6/27/2020	MY45093852
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2495A	Power Meter	10/21/2018	Annual	10/21/2019	941001
Anritsu	MA2411B	Pulse Power Sensor	10/30/2018	Annual	10/30/2019	1207470
Anritsu	MA2411B	Pulse Power Sensor	11/20/2018	Annual	11/20/2019	1339007
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/28/2018	Biennial	2/28/2020	170330160
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	NC-100	Torque Wrench	11/1/2017	Biennial	11/1/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/7/2019	Annual	5/7/2020	1070
SPEAG	EX3DV4	SAR Probe	1/24/2019	Annual	1/24/2020	7490
SPEAG	DAE4	Data Acquisition Electronics	1/15/2019	Annual	1/15/2020	1532

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION


Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 3-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2019	1.217	3.64	3.54	-2.75%	1.92	1.88	-2.08%	50.8	48.5	-2.3	-0.2	-2.5	2.3	-41.5	-41.7	-0.50%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2019	1.217	3.66	3.67	0.27%	1.96	1.96	0.00%	46.5	45.5	-1	-0.7	-2.3	1.6	-28.7	-25.5	11.10%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL





Accredited by the Swiss Accreditation Service (SAS)
 The Swiss Accreditation Service is one of the signatories to the EA
 Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **PC Test**

Certificate No: **D1900V2-5d030_Jun19**

CALIBRATION CERTIFICATE

Object **D1900V2 - SN:5d030**

Calibration procedure(s) **QA CAL-05.v11**
Calibration Procedure for SAR Validation Sources between 0.7-3 GHz

Calibration date: **June 19, 2019**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
 The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature $(22 \pm 3)^{\circ}\text{C}$ and humidity $< 70\%$.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	03-Apr-19 (No. 217-02892/02893)	Apr-20
Power sensor NRP-Z91	SN: 103244	03-Apr-19 (No. 217-02892)	Apr-20
Power sensor NRP-Z91	SN: 103245	03-Apr-19 (No. 217-02893)	Apr-20
Reference 20 dB Attenuator	SN: 5058 (20k)	04-Apr-19 (No. 217-02894)	Apr-20
Type-N mismatch combination	SN: 5047.2 / 06327	04-Apr-19 (No. 217-02895)	Apr-20
Reference Probe EX3DV4	SN: 7349	29-May-19 (No. EX3-7349_May19)	May-20
DAE4	SN: 601	30-Apr-19 (No. DAE4-601_Apr19)	Apr-20

Secondary Standards	ID #	Check Date (In house)	Scheduled Check
Power meter E4419B	SN: GB39512476	30-Oct-14 (In house check Feb-19)	In house check: Oct-20
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (In house check Oct-18)	In house check: Oct-20
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (In house check Oct-18)	In house check: Oct-20
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (In house check Oct-18)	In house check: Oct-20
Network Analyzer Agilent E8358A	SN: US41080477	31-Mar-14 (In house check Oct-18)	In house check: Oct-19

Calibrated by: **Gaudio Leubler** **Laboratory Technician**

Approved by: **Katja Pokovic** **Technical Manager**

Signature

Issued: June 20, 2019

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 0108**

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions:** Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:** The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:** These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:** One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:** SAR measured at the stated antenna input power.
- SAR normalized:** SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:** The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.2
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1900 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.0	1.40 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	41.4 $\pm$ 6 %	1.39 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.85 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	39.9 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	5.19 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	20.9 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.3	1.52 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	54.2 $\pm$ 6 %	1.50 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	9.86 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	39.9 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	5.24 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	21.1 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	$50.0\ \Omega + 4.2\ j\Omega$
Return Loss	- 27.6 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	$47.0\ \Omega + 5.4\ j\Omega$
Return Loss	- 24.0 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.191 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
-----------------	-------

DASY5 Validation Report for Head TSL

Date: 19.06.2019

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN:5d030

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.39$ S/m; $\epsilon_r = 41.4$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.44, 8.44, 8.44) @ 1900 MHz; Calibrated: 29.05.2019
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 30.04.2019
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.2(1504); SEMCAD X 14.6.12(7470)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 109.2 V/m; Power Drift = 0.03 dB


Peak SAR (extrapolated) = 18.2 W/kg

SAR(1 g) = 9.85 W/kg; SAR(10 g) = 5.19 W/kg

Maximum value of SAR (measured) = 15.3 W/kg



Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 19.06.2019

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN:5d030

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.5$ S/m; $\epsilon_r = 54.2$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.42, 8.42, 8.42) @ 1900 MHz; Calibrated: 29.05.2019
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 30.04.2019
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.2(1504); SEMCAD X 14.6.12(7470)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 104.1 V/m; Power Drift = -0.06 dB


Peak SAR (extrapolated) = 17.6 W/kg

SAR(1 g) = 9.86 W/kg; SAR(10 g) = 5.24 W/kg

Maximum value of SAR (measured) = 15.0 W/kg



Impedance Measurement Plot for Body TSL



Certification of Calibration

Object D1900V2 – SN: 5d030

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: June 19, 2020

Description: SAR Validation Dipole at 1900 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	1/16/2020	Annual	1/16/2021	US39170118
Agilent	N5182A	MXG Vector Signal Generator	8/19/2019	Annual	8/19/2020	MY47420837
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	MA2411B	Pulse Power Sensor	1/21/2020	Annual	1/21/2021	1207470
Anritsu	MA2411B	Pulse Power Sensor	1/21/2020	Annual	1/21/2021	1339007
Anritsu	ML2495A	Power Meter	1/15/2020	Annual	1/15/2021	1328004
Control Company	62344-734	Therm./ Clock/ Humidity Monitor	3/18/2019	Biennial	3/18/2021	192038436
Control Company	4352	Ultra Long Stem Thermometer	8/2/2018	Biennial	8/2/2020	181292000
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
MiniCircuits	VLF-6000+	Low Pass Filter	CBT	N/A	CBT	N/A
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Seekonk	NC-100	Torque Wrench	7/18/2019	Annual	7/18/2020	N/A
SPEAG	DAE4	Dasy Data Acquisition Electronics	1/14/2020	Annual	1/14/2021	793
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/12/2020	Annual	5/12/2021	1070
SPEAG	EX3DV4	SAR Probe	1/20/2020	Annual	1/20/2021	3837

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Managing Director	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION



Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.



The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
6/19/2019	6/19/2020	1.191	3.99	4.3	7.77%	2.09	2.2	5.25%	50	46.8	3.2	4.2	2	2.2	-27.6	-30.3	-9.80%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
6/19/2019	6/19/2020	1.191	3.99	4.29	7.52%	2.11	2.2	4.27%	47	45.1	1.9	5.4	2.5	2.9	-24	-25	-4.20%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **PC Test**

Certificate No: **D1900V2-5d181_Sep17**

CALIBRATION CERTIFICATE

Object **D1900V2 - SN:5d181**

Calibration procedure(s) **QA CAL-05.v9
Calibration procedure for dipole validation kits above 700 MHz**

Calibration date: **September 07, 2017**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature $(22 \pm 3)^{\circ}\text{C}$ and humidity $< 70\%$.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02526)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	31-May-17 (No. EX3-7349_May17)	May-18
DAE4	SN: 601	28-Mar-17 (No. DAE4-601_Mar17)	Mar-18
Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-16)	In house check: Oct-17

Calibrated by: **Jeton Kastrali** Function: **Laboratory Technician**

Approved by: **Katja Pokovic** Technical Manager

Signature

Issued: September 7, 2017

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 0108**

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1900 MHz $\pm$ 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.0	1.40 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	39.0 $\pm$ 6 %	1.38 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.85 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	39.5 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	5.15 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	20.6 W/kg $\pm$ 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.3	1.52 mho/m
Measured Body TSL parameters	(22.0 $\pm$ 0.2) °C	54.3 $\pm$ 6 %	1.47 mho/m $\pm$ 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	9.65 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	39.5 W/kg $\pm$ 17.0 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	5.14 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	20.9 W/kg $\pm$ 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	$53.7 \Omega + 4.6 j\Omega$
Return Loss	- 24.9 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	$49.2 \Omega + 5.6 j\Omega$
Return Loss	- 24.8 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.200 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	August 23, 2013

DASY5 Validation Report for Head TSL

Date: 07.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN:5d181

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.38$ S/m; $\epsilon_r = 39$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.43, 8.43, 8.43); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:

Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 106.8 V/m; Power Drift = -0.06 dB

Peak SAR (extrapolated) = 18.5 W/kg

SAR(1 g) = 9.85 W/kg; SAR(10 g) = 5.15 W/kg

Maximum value of SAR (measured) = 14.8 W/kg



0 dB = 14.8 W/kg = 11.70 dBW/kg

Impedance Measurement Plot for Head TSL

7 Sep 2017 09:10:32
 CH1 S11 1 U FS 3: 53.668 Ω 4.5957 Ω 384.96 μH 1 900.000 000 MHz


*

De1

CA

Avg
16

H1d




CH2 S11 LOG 5 dB/REF -20 dB 3:-24.931 dB 1 900.000 000 MHz

CA

Avg
16

H1d



DASY5 Validation Report for Body TSL

Date: 07.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN:5d181

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.47$ S/m; $\epsilon_r = 54.3$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.2, 8.2, 8.2); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:



Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 101.4 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 17.0 W/kg

SAR(1 g) = 9.65 W/kg; SAR(10 g) = 5.14 W/kg

Maximum value of SAR (measured) = 13.8 W/kg




0 dB = 13.8 W/kg = 11.40 dBW/kg

Impedance Measurement Plot for Body TSL

7 Sep 2017 09:09:41
 CH1 S11 1 U FS 3: 49.201 Ω 5.6484 Ω 473.15 pF 1 900.000 000 MHz

*
 Del
 CA



Avg
 15


H1d

CH2 S11 LOG 5 dB/REF -20 dB 3: -24.816 dB 1 900.000 000 MHz

CA

Avg
 15

H1d



Certification of Calibration

Object D1900V2 – SN: 5d181

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.



Extended Calibration date: September 07, 2018

Description: SAR Validation Dipole at 1900 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	9/14/2017	Annual	9/14/2018	US39170118
Agilent	N5182A	MXG Vector Signal Generator	3/19/2018	Annual	3/19/2019	US46240505
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2496A	Power Meter	10/9/2017	Annual	10/9/2018	1138001
Anritsu	MA2411B	Pulse Power Sensor	11/15/2017	Annual	11/15/2018	1339007
Anritsu	MA2411B	Pulse Power Sensor	11/22/2017	Annual	11/22/2018	1339008
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/14/2017	Biennial	2/14/2019	170112507
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	6/4/2018	Annual	6/4/2019	MY53401181
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2209-10	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	PE5011-1	Torque Wrench	7/19/2017	Biennial	7/19/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/15/2018	Annual	5/15/2019	1070
SPEAG	ES3DV3	SAR Probe	9/18/2017	Annual	9/18/2018	3287
SPEAG	DAE4	Data Acquisition Electronics	1/26/2018	Annual	1/26/2019	1533
SPEAG	ES3DV3	SAR Probe	3/13/2018	Annual	3/13/2019	3131
SPEAG	DAE4	Dasy Data Acquisition Electronics	3/7/2018	Annual	3/7/2019	604

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Sangmin Cha	Team Lead Engineer	
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	

DIPOLE CALIBRATION EXTENSION

Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:



1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.

The following dipole was checked to pass the above 3 requirements to have 2-year calibration period from the calibration date:



Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Head (10g) W/kg @ 20.0 dBm	Measured Head SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2018	1.2	3.95	3.99	1.01%	2.06	2.07	0.49%	53.7	49.6	4.1	4.6	2.6	2	-24.9	-28.9	-16.10%	PASS

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2018	1.2	3.95	4.13	4.56%	2.09	2.14	2.39%	49.2	45.8	3.4	5.6	2.1	3.5	-24.8	-24.7	0.40%	PASS

Impedance & Return-Loss Measurement Plot for Head TSL



Impedance & Return-Loss Measurement Plot for Body TSL



Certification of Calibration

Object D1900V2 – SN: 5d181

Calibration procedure(s) Procedure for Calibration Extension for SAR Dipoles.

Extended Calibration date: September 7, 2019

Description: SAR Validation Dipole at 1900 MHz.

Calibration Equipment used:

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Agilent	8753ES	S-Parameter Network Analyzer	10/2/2018	Annual	10/2/2019	US39170118
Agilent	E4438C	ESG Vector Signal Generator	6/27/2019	Annual	6/27/2020	MY45093852
Amplifier Research	15S1G6	Amplifier	CBT	N/A	CBT	343972
Anritsu	ML2495A	Power Meter	10/21/2018	Annual	10/21/2019	941001
Anritsu	MA2411B	Pulse Power Sensor	10/30/2018	Annual	10/30/2019	1207470
Anritsu	MA2411B	Pulse Power Sensor	11/20/2018	Annual	11/20/2019	1339007
Control Company	4040	Temperature / Humidity Monitor	2/28/2018	Biennial	2/28/2020	150761911
Control Company	4352	Ultra Long Stem Thermometer	2/28/2018	Biennial	2/28/2020	170330160
Keysight Technologies	85033E	Standard Mechanical Calibration Kit (DC to 9GHz, 3.5mm)	7/2/2019	Annual	7/2/2020	MY53401181
Keysight	772D	Dual Directional Coupler	CBT	N/A	CBT	MY52180215
Mini-Circuits	BW-N20W5+	DC to 18 GHz Precision Fixed 20 dB Attenuator	CBT	N/A	CBT	N/A
Mini-Circuits	NLP-2950+	Low Pass Filter DC to 2700 MHz	CBT	N/A	CBT	N/A
Narda	4772-3	Attenuator (3dB)	CBT	N/A	CBT	9406
Pasternack	PE2208-6	Bidirectional Coupler	CBT	N/A	CBT	N/A
Pasternack	NC-100	Torque Wrench	11/1/2017	Biennial	11/1/2019	N/A
SPEAG	DAK-3.5	Dielectric Assessment Kit	5/7/2019	Annual	5/7/2020	1070
SPEAG	EX3DV4	SAR Probe	1/24/2019	Annual	1/24/2020	7490
SPEAG	DAE4	Data Acquisition Electronics	1/15/2019	Annual	1/15/2020	1532

Measurement Uncertainty = $\pm 23\%$ (k=2)

	Name	Function	Signature
Calibrated By:	Parker Jones	Team Lead Engineer	<i>Parker Jones</i>
Approved By:	Kaitlin O'Keefe	Senior Technical Manager	<i>KOK</i>

DIPOLE CALIBRATION EXTENSION

Per KDB 865664 D01, calibration intervals of up to three years may be considered for reference dipoles when it is demonstrated that the SAR target, impedance and return loss of a dipole have remained stable according to the following requirements:

1. The measured SAR does not deviate more than 10% from the target on the calibration certificate.
2. The return-loss does not deviate more than 20% from the previous measurement and meets the required 20dB minimum return-loss requirement.
3. The measurement of real or imaginary parts of impedance does not deviate more than 5Ω from the previous measurement.

The following dipole was checked to pass the above 3 requirements to have 3-year calibration period from the calibration date:

Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Head (1g) W/kg @ 20.0 dBm	Measured Head SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Head (Ohm) Real	Measured Impedance Head (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Head (Ohm) Imaginary	Measured Impedance Head (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Head (dB)	Measured Return Loss Head (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2019	1.2	3.95	3.92	-0.76%	2.06	2.04	-0.97%	53.7	50.3	-3.4	4.6	0.2	-4.4	-24.9	-27	-8.40%	PASS
Calibration Date	Extension Date	Certificate Electrical Delay (ns)	Certificate SAR Target Body (1g) W/kg @ 20.0 dBm	Measured Body SAR (1g) W/kg @ 20.0 dBm	Deviation 1g (%)	Certificate SAR Target Body (10g) W/kg @ 20.0 dBm	Measured Body SAR (10g) W/kg @ 20.0 dBm	Deviation 10g (%)	Certificate Impedance Body (Ohm) Real	Measured Impedance Body (Ohm) Real	Difference (Ohm) Real	Certificate Impedance Body (Ohm) Imaginary	Measured Impedance Body (Ohm) Imaginary	Difference (Ohm) Imaginary	Certificate Return Loss Body (dB)	Measured Return Loss Body (dB)	Deviation (%)	PASS/FAIL
9/7/2017	9/7/2019	1.2	3.95	4.05	2.53%	2.09	2.1	0.48%	49.2	46.2	-3	5.6	2.7	-2.9	-24.8	-23.1	6.90%	PASS