

Greg Turner

Director
Global Offer Management
Building Solutions

Automation and Control Solutions

Honeywell
140 SouthCenter Court
Suite 300
Morrisville, NC 27560
919-319-5302
919-319-5333 Fax
Greg.Turner@Honeywell.com

Differences between BTBAS, BTSTD and BTFPT

There are three models exist under IdentIPoint:

BTBAS – Basic model, IP65 waterproof

BTSTD – Standard model, with keypad and display

BTFPT – Fingerprint model, with keypad, display and fingerprint sensor.

Here is a summary of the differences between the 3 models of IdentIPoint

	BTBAS	BTSTD	BTFPT
Appearance			
LCD	Not present	128 x 64 ASTN	128 x 64 ASTN
LED indicator position	Mid upper half	Above LCD	Above LCD
Keypad	Not present	3 x 4	3 x 4
Fingerprint circuit	Not present	Not present	Capacitive Fingerprint detection with Infrared finger sensing
Board configuration	Top board + Bottom board	Top board + Bottom board	Top board + Bottom board + Fingerprint board

All three models are built under the same circuitry and carry the same software.

Sincerely,

A handwritten signature in black ink, appearing to read "Gregory Turner", with a long, sweeping horizontal line extending to the right.

Gregory Turner

Director of Global Offerings