

HAC_E_Dipole_835_160227**DUT: HAC-Dipole 835 MHz**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ S/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.5 °C

DASY5 Configuration

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2016/1/19;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE3 Sn495; Calibrated: 2015/5/22
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7331)

E Scan - measurement distance from the probe sensor center to CD835 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x361x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 115.2 V/m; Power Drift = 0.02 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 109.3 V/m

Average value of Total=(109.3+99.98) / 2 = 104.64 V/m

PMF scaled E-field



Grid 1 M4 107.0 V/m	Grid 2 M4 109.3 V/m	Grid 3 M4 106.8 V/m
Grid 4 M4 57.86 V/m	Grid 5 M4 59.59 V/m	Grid 6 M4 58.90 V/m
Grid 7 M4 97.51 V/m	Grid 8 M4 99.98 V/m	Grid 9 M4 98.46 V/m

Cursor:

Total = 109.3 V/m

E Category: M4

Location: 0, -77.5, 9.7 mm



0 dB = 109.3 V/m = 40.77 dBV/m

HAC_E_Dipole_1880_160227**DUT: HAC Dipole 1880 MHz**

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ S/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.5 °C

DASY5 Configuration

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2016/1/19;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE3 Sn495; Calibrated: 2015/5/22
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7331)

E Scan - measurement distance from the probe sensor center to CD1880 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x181x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 138.0 V/m; Power Drift = -0.02 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 91.73 V/m

Average value of Total=(89.88+91.73) / 2 = 90.805 V/m

PMF scaled E-field



Grid 1 M3 88.25 V/m	Grid 2 M3 89.88 V/m	Grid 3 M3 88.51 V/m
Grid 4 M3 71.84 V/m	Grid 5 M3 72.64 V/m	Grid 6 M3 71.84 V/m
Grid 7 M3 90.83 V/m	Grid 8 M3 91.73 V/m	Grid 9 M3 89.49 V/m

Cursor:

Total = 91.73 V/m

E Category: M3

Location: 0.5, 30.5, 9.7 mm



0 dB = 91.73 V/m = 39.25 dBV/m