

HAC_E_Dipole_1880_140927**DUT: HAC Dipole 1880 MHz**

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ S/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.2 °C

DASY5 Configuration

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2014/1/30;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1279; Calibrated: 2014/7/23
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

E Scan - measurement distance from the probe sensor center to CD1880 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x181x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 153.4 V/m; Power Drift = 0.02 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 87.31 V/m

Average value of Total=(87.31+83.23) / 2 = 85.27 V/m

PMF scaled E-field



Grid 1 M3 85.95 V/m	Grid 2 M3 87.31 V/m	Grid 3 M3 86.17 V/m
Grid 4 M3 67.69 V/m	Grid 5 M3 68.27 V/m	Grid 6 M3 66.86 V/m
Grid 7 M3 81.85 V/m	Grid 8 M3 83.23 V/m	Grid 9 M3 81.74 V/m

Cursor:

Total = 87.31 V/m

E Category: M3

Location: 0, -31, 9.7 mm



0 dB = 87.31 V/m = 38.82 dBV/m