

HAC_E_Dipole_835_150525**DUT: HAC-Dipole 835 MHz**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ S/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.4 °C

DASY5 Configuration

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2015/1/26;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2014/8/21
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

E Scan - measurement distance from the probe sensor center to CD835 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x361x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 103.4 V/m; Power Drift = -0.09 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 107.4 V/m

Average value of Total=(107.4+102) / 2 = 104.7V/m

PMF scaled E-field



Grid 1 M4 106.0 V/m	Grid 2 M4 107.4 V/m	Grid 3 M4 105.4 V/m
Grid 4 M4 65.60 V/m	Grid 5 M4 65.95 V/m	Grid 6 M4 64.52 V/m
Grid 7 M4 101.3 V/m	Grid 8 M4 102.0 V/m	Grid 9 M4 99.48 V/m

Cursor:

Total = 107.4 V/m

E Category: M4

Location: 0.5, -69, 9.7 mm



0 dB = 107.4 V/m = 40.62 dBV/m

HAC_E_Dipole_1880_150525**DUT: HAC Dipole 1880 MHz**

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ S/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.4 °C

DASY5 Configuration

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2015/1/26;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2014/8/21
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

E Scan - measurement distance from the probe sensor center to CD1880 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x181x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 147.2 V/m; Power Drift = -0.03 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 90.34 V/m

Average value of Total=(90.34+84.68) / 2 = 87.51V/m

PMF scaled E-field



Grid 1 M3 89.16 V/m	Grid 2 M3 90.34 V/m	Grid 3 M3 88.69 V/m
Grid 4 M3 71.39 V/m	Grid 5 M3 72.07 V/m	Grid 6 M3 70.71 V/m
Grid 7 M3 83.70 V/m	Grid 8 M3 84.68 V/m	Grid 9 M3 83.02 V/m

Cursor:

Total = 90.34 V/m

E Category: M3

Location: 0, -30.5, 9.7 mm



0 dB = 90.34 V/m = 39.12 dBV/m