

Test Laboratory: KES Co., Ltd.

System verification_450_HSL

DUT: Dipole 450 MHz; Type: D450V3; Serial: D450V3 - SN:1084


Communication System: CW; Frequency: 450 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 450$ MHz; $\sigma = 0.873$ mho/m; $\epsilon_r = 43.4$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASY4 (High Precision Assessment)

DASY4 Configuration:

- Probe: EX3DV4 - SN3879; ConvF(9.98, 9.98, 9.98); Calibrated: 2014-11-19
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1344; Calibrated: 2014-11-12
- Phantom: ELI v5.0_2013_01_23; Type: QDOVA002AA; Serial: TP:1190
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Flat-Section_HSL_450/Area Scan (41x201x1): Measurement grid: dx=15mm, dy=15mm
Maximum value of SAR (interpolated) = 1.30 mW/g

Flat-Section_HSL_450/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 38.6 V/m; Power Drift = -0.069 dB
Peak SAR (extrapolated) = 1.68 W/kg
SAR(1 g) = 1.22 mW/g; SAR(10 g) = 0.887 mW/g
Maximum value of SAR (measured) = 1.29 mW/g



Test Laboratory: KES Co., Ltd.

System verification_450_MSL

DUT: Dipole 450 MHz; Type: D450V3; Serial: D450V3 - SN:1084


Communication System: CW; Frequency: 450 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 450$ MHz; $\sigma = 0.923$ mho/m; $\epsilon_r = 57.4$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASY4 (High Precision Assessment)

DASY4 Configuration:

- Probe: EX3DV4 - SN3879; ConvF(10.25, 10.25, 10.25); Calibrated: 2014-11-19
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1344; Calibrated: 2014-11-12
- Phantom: ELI v5.0_2013_01_23; Type: QDOVA002AA; Serial: TP:1190
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Flat-Section_MSL_450/Area Scan (41x201x1): Measurement grid: dx=15mm, dy=15mm
Maximum value of SAR (interpolated) = 1.26 mW/g

Flat-Section_MSL_450/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 37.3 V/m; Power Drift = -0.046 dB
Peak SAR (extrapolated) = 1.71 W/kg
SAR(1 g) = 1.18 mW/g; SAR(10 g) = 0.815 mW/g
Maximum value of SAR (measured) = 1.26 mW/g



Plot 1

Date/Time: 2014-12-15 PM 4:11:40

Test Laboratory: KES Co., Ltd.

Face_GMRS_Analog_25mm_Gap_462.6375

DUT: T65; Type: Bar; Serial: N/A

Communication System: CW; Frequency: 462.637 MHz; Duty Cycle: 1:1

Medium parameters used (interpolated): $f = 462.637$ MHz; $\sigma = 0.884$ mho/m; $\epsilon_r = 43.2$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASYS4 (High Precision Assessment)

DASY4 Configuration:

- Probe: EX3DV4 - SN3879; ConvF(9.98, 9.98, 9.98); Calibrated: 2014-11-19
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1344; Calibrated: 2014-11-12
- Phantom: ELI v5.0_2013_01_23; Type: QDOVA002AA; Serial: TP:1190
- Measurement SW: DASYS4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Face_GMRS_Analog_25mm_Gap_462.6375/Area Scan (51x121x1): Measurement grid: dx=15mm, dy=15mm

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (interpolated) = 0.782 mW/g

Face_GMRS_Analog_25mm_Gap_462.6375/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm


Reference Value = 30.6 V/m; Power Drift = -0.084 dB

Peak SAR (extrapolated) = 0.840 W/kg

SAR(1 g) = 0.699 mW/g; SAR(10 g) = 0.567 mW/g

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (measured) = 0.725 mW/g



Test Laboratory: KES Co., Ltd.

Face_FRS_Analog_25mm Gap_467.6375

DUT: T65; Type: Bar; Serial: N/A

Communication System: CW; Frequency: 467.637 MHz; Duty Cycle: 1:1
Medium parameters used (interpolated): $f = 467.637$ MHz; $\sigma = 0.882$ mho/m; $\epsilon_r = 42.9$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASY4 (High Precision Assessment)

DASY4 Configuration:

- Probe: EX3DV4 - SN3879; ConvF(9.98, 9.98, 9.98); Calibrated: 2014-11-19
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1344; Calibrated: 2014-11-12
- Phantom: ELI v5.0_2013_01_23; Type: QDOVA002AA; Serial: TP:1190
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Face_FRS_Analog_25mm Gap_467.6375/Area Scan (51x121x1): Measurement grid: dx=15mm, dy=15mm

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (interpolated) = 0.470 mW/g

Face_FRS_Analog_25mm Gap_467.6375/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm


Reference Value = 23.6 V/m; Power Drift = -0.203 dB

Peak SAR (extrapolated) = 0.521 W/kg

SAR(1 g) = 0.430 mW/g; SAR(10 g) = 0.349 mW/g

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (measured) = 0.446 mW/g



Test Laboratory: KES Co., Ltd.

Body_GMRS_Analog_Touch_462.6375

DUT: T65; Type: Bar; Serial: N/A

Communication System: CW; Frequency: 462.637 MHz; Duty Cycle: 1:1
Medium parameters used (interpolated): $f = 462.637$ MHz; $\sigma = 0.934$ mho/m; $\epsilon_r = 57.8$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASYS4 (High Precision Assessment)

DASY4 Configuration:

- Probe: EX3DV4 - SN3879; ConvF(10.25, 10.25, 10.25); Calibrated: 2014-11-19
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1344; Calibrated: 2014-11-12
- Phantom: ELI v5.0_2013_01_23; Type: QDOVA002AA; Serial: TP:1190
- Measurement SW: DASYS4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Body_GMRS_Analog_Touch_462.6375/Area Scan (51x121x1): Measurement grid: dx=15mm, dy=15mm

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (interpolated) = 1.05 mW/g

Body_GMRS_Analog_Touch_462.6375/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm


Reference Value = 33.6 V/m; Power Drift = -0.143 dB

Peak SAR (extrapolated) = 1.27 W/kg

SAR(1 g) = 0.940 mW/g; SAR(10 g) = 0.692 mW/g

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (measured) = 0.988 mW/g



Test Laboratory: KES Co., Ltd.

Body_FRS_Analog_Touch_467.6375

DUT: T65; Type: Bar; Serial: N/A

Communication System: CW; Frequency: 467.637 MHz; Duty Cycle: 1:1
Medium parameters used (interpolated): $f = 467.637$ MHz; $\sigma = 0.937$ mho/m; $\epsilon_r = 57.3$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASYS4 (High Precision Assessment)

DASY4 Configuration:

- Probe: EX3DV4 - SN3879; ConvF(10.25, 10.25, 10.25); Calibrated: 2014-11-19
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1344; Calibrated: 2014-11-12
- Phantom: ELI v5.0_2013_01_23; Type: QDOVA002AA; Serial: TP:1190
- Measurement SW: DASYS4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Body_FRS_Analog_Touch_467.6375/Area Scan (51x121x1): Measurement grid: dx=15mm, dy=15mm

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (interpolated) = 0.461 mW/g

Body_FRS_Analog_Touch_467.6375/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 21.3 V/m; Power Drift = -0.174 dB

Peak SAR (extrapolated) = 0.574 W/kg

SAR(1 g) = 0.430 mW/g; SAR(10 g) = 0.315 mW/g

[Info: Interpolated medium parameters used for SAR evaluation.](#)

Maximum value of SAR (measured) = 0.455 mW/g

