

### HAC\_E\_Dipole\_835\_20100311

#### DUT: Dipole 835 MHz

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.5 °C

DASY4 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE3 Sn577; Calibrated: 2009/8/24
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

**E Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1):** Measurement grid: dx=5mm, dy=5mm



Maximum value of peak Total field = 178.5 V/m

Probe Modulation Factor = 1.00

Reference Value = 131.8 V/m; Power Drift = -0.010 dB

**Average Xclue of Total'±'(176.3 + 178.5) / 2 = 177.4 V/m**

|                           |                           |                           |
|---------------------------|---------------------------|---------------------------|
| Grid 1<br><b>171.7 M4</b> | Grid 2<br><b>176.3 M4</b> | Grid 3<br><b>169.9 M4</b> |
| Grid 4<br><b>87.9 M4</b>  | Grid 5<br><b>93.5 M4</b>  | Grid 6<br><b>92.3 M4</b>  |
| Grid 7<br><b>168.6 M4</b> | Grid 8<br><b>178.5 M4</b> | Grid 9<br><b>175.2 M4</b> |



0 dB = 178.5V/m

**HAC\_E\_Dipole\_1880\_20100311**

**DUT: HAC Dipole 1880 MHz**

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.5 °C

DASY4 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE3 Sn577; Calibrated: 2009/8/24
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

**E Scan - measurement distance from the probe sensor center to CD1880 Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 143.9 V/m



Probe Modulation Factor = 1.00

Reference Value = 148.8 V/m; Power Drift = -0.019 dB

**Average Xclue of Total'=(142.6 + 143.9) / 2 =143.25 V/m**

Peak E-field in V/m

|                           |                           |                           |
|---------------------------|---------------------------|---------------------------|
| Grid 1<br><b>139.3 M2</b> | Grid 2<br><b>142.6 M2</b> | Grid 3<br><b>136.8 M2</b> |
| Grid 4<br><b>90.5 M3</b>  | Grid 5<br><b>96.6 M3</b>  | Grid 6<br><b>96.0 M3</b>  |
| Grid 7<br><b>138.0 M2</b> | Grid 8<br><b>143.9 M2</b> | Grid 9<br><b>141.6 M2</b> |



0 dB = 143.9V/m

## HAC\_H\_Dipole\_835\_20100311

### DUT: HAC-Dipole 835 MHz

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>


Ambient Temperature : 22.5 °C

DASY4 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE3 Sn577; Calibrated: 2009/8/24
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

**H Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1):** Measurement grid: dx=5mm, dy=5mm  
 Probe Modulation Factor = 1.00  
 Reference Value = 0.515 A/m; Power Drift = -0.022 dB  
**Maximum Value of Total = 0.464 A/m**

|                           |                           |                           |
|---------------------------|---------------------------|---------------------------|
| Grid 1<br><b>0.396 M4</b> | Grid 2<br><b>0.409 M4</b> | Grid 3<br><b>0.390 M4</b> |
| Grid 4<br><b>0.444 M4</b> | Grid 5<br><b>0.464 M4</b> | Grid 6<br><b>0.443 M4</b> |
| Grid 7<br><b>0.398 M4</b> | Grid 8<br><b>0.416 M4</b> | Grid 9<br><b>0.394 M4</b> |



0 dB = 0.464A/m

## HAC\_H\_Dipole\_1880\_20100311

### DUT: HAC Dipole 1880 MHz

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.5 °C

DASY4 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE3 Sn577; Calibrated: 2009/8/24
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186


### H Scan - measurement distance from the probe sensor center to CD1880 Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm

Probe Modulation Factor = 1.00

Reference Value = 0.502 A/m; Power Drift = 0.011 dB

**Maximum Value of Total = 0.454 A/m**

|                           |                           |                           |
|---------------------------|---------------------------|---------------------------|
| Grid 1<br><b>0.401 M2</b> | Grid 2<br><b>0.417 M2</b> | Grid 3<br><b>0.395 M2</b> |
| Grid 4<br><b>0.438 M2</b> | Grid 5<br><b>0.454 M2</b> | Grid 6<br><b>0.432 M2</b> |
| Grid 7<br><b>0.403 M2</b> | Grid 8<br><b>0.418 M2</b> | Grid 9<br><b>0.393 M2</b> |



0 dB = 0.454A/m