

**HAC\_E\_Dipole\_835\_100805****DUT: Dipole 835 MHz**

Communication System: GSM850; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.3

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**E Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1):** Measurement grid: dx=5mm, dy=5mm

Probe Modulation Factor = 1

Reference Value = 132.9 V/m; Power Drift = -0.011 dB

**Average Value of Total = (175.9 + 178.1) / 2 = 177 V/m**

Peak E-field in V/m



Grid 1 <b>168.8 M4</b>	Grid 2 <b>175.9 M4</b>	Grid 3 <b>170.5 M4</b>
Grid 4 <b>92.4 M4</b>	Grid 5 <b>95.6 M4</b>	Grid 6 <b>93.4 M4</b>
Grid 7 <b>175.0 M4</b>	Grid 8 <b>178.1 M4</b>	Grid 9 <b>172.4 M4</b>

**Cursor:**

Total = 178.1 V/m

E Category: M4

Location: 0.5, 73.5, 4.7 mm



0 dB = 178.1V/m

**HAC\_E\_Dipole\_1880\_100805**

**DUT: HAC Dipole 1880 MHz**

Communication System: GSM850; Frequency: 1880 MHz; Duty Cycle: 1:1  
 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>  
 Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2009/9/18
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**E Scan - measurement distance from the probe sensor center to CD1880 Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1):** Measurement grid: dx=5mm, dy=5mm

Probe Modulation Factor = 1

Reference Value = 147.5 V/m; Power Drift = -0.015 dB

**Average Value of Total = (143.8 + 145.3) / 2 = 144.55 V/m**

Peak E-field in V/m



Grid 1 <b>140.7 M2</b>	Grid 2 <b>143.8 M2</b>	Grid 3 <b>137.0 M2</b>
Grid 4 <b>96.5 M3</b>	Grid 5 <b>100.5 M3</b>	Grid 6 <b>99.1 M3</b>
Grid 7 <b>141.5 M2</b>	Grid 8 <b>145.3 M2</b>	Grid 9 <b>141.8 M2</b>

**Cursor:**

Total = 145.3 V/m

E Category: M2

Location: 0, 32, 4.7 mm



0 dB = 145.3V/m

**HAC\_H\_Dipole\_835\_100805**

**DUT: HAC-Dipole 835 MHz**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2009/9/18
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**H Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1):** Measurement grid: dx=5mm, dy=5mm

Probe Modulation Factor = 1

Reference Value = 0.482 A/m; Power Drift = 0.00742 dB

**Maximum Value of Total = 0.434 A/m**

Peak H-field in A/m


Grid 1 <b>0.369 M4</b>	Grid 2 <b>0.380 M4</b>	Grid 3 <b>0.354 M4</b>
Grid 4 <b>0.419 M4</b>	Grid 5 <b>0.434 M4</b>	Grid 6 <b>0.406 M4</b>
Grid 7 <b>0.375 M4</b>	Grid 8 <b>0.389 M4</b>	Grid 9 <b>0.363 M4</b>

**Cursor:**

Total = 0.434 A/m

H Category: M4

Location: 0.5, 1, 5.2 mm



0 dB = 0.434A/m

**HAC\_H\_Dipole\_1880\_100805****DUT: HAC Dipole 1880 MHz**

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.6

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**H Scan - measurement distance from the probe sensor center to CD1880 Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1):** Measurement grid: dx=5mm, dy=5mm

Probe Modulation Factor = 1

Reference Value = 0.517 A/m; Power Drift = -0.00983 dB

**Maximum Value of Total = 0.470 A/m**

Peak H-field in A/m


Grid 1 <b>0.412 M2</b>	Grid 2 <b>0.422 M2</b>	Grid 3 <b>0.395 M2</b>
Grid 4 <b>0.457 M2</b>	Grid 5 <b>0.470 M2</b>	Grid 6 <b>0.442 M2</b>
Grid 7 <b>0.419 M2</b>	Grid 8 <b>0.434 M2</b>	Grid 9 <b>0.407 M2</b>

**Cursor:**

Total = 0.470 A/m

H Category: M2

Location: 0.5, 1, 5.2 mm



0 dB = 0.470A/m