

**#05 HAC\_E\_CDMA2000 BC0\_RC1\_SO55\_Loop\_Eighth Rate\_Ch384\_PDA 1\_Battery 1****DUT: 072126**

Communication System: CDMA ; Frequency: 836.52 MHz; Duty Cycle: 1:1  
 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>  
 Ambient Temperature : 22.5

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2009/9/18
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 66.8 V/m

Probe Modulation Factor = 2.94

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 27.4 V/m; Power Drift = 0.284 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>61.1 M4</b>	Grid 2 <b>66.8 M4</b>	Grid 3 <b>65 M4</b>
Grid 4 <b>57.7 M4</b>	Grid 5 <b>66.8 M4</b>	Grid 6 <b>65.1 M4</b>
Grid 7 <b>55.4 M4</b>	Grid 8 <b>63 M4</b>	Grid 9 <b>62 M4</b>

**Cursor:**

Total = 66.8 V/m

E Category: M4

Location: -4.5, -20, 8.7 mm



0 dB = 66.8V/m

**#16 HAC\_E\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch1013\_PDA 1\_Battery 1**

**DUT: 072126**

Communication System: CDMA ; Frequency: 824.7 MHz;Duty Cycle: 1:1  
 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>  
 Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2009/9/18
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch1013/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 56.8 V/m

Probe Modulation Factor = 2.94

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 23.2 V/m; Power Drift = 0.262 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>52 M4</b>	Grid 2 <b>56.8 M4</b>	Grid 3 <b>55.5 M4</b>
Grid 4 <b>50.2 M4</b>	Grid 5 <b>56.8 M4</b>	Grid 6 <b>55.5 M4</b>
Grid 7 <b>47.7 M4</b>	Grid 8 <b>53 M4</b>	Grid 9 <b>52 M4</b>

**Cursor:**

Total = 56.8 V/m

E Category: M4

Location: -2.5, -18.5, 8.7 mm



0 dB = 56.8V/m

**#17 HAC\_E\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch777\_PDA 1\_Battery 1****DUT: 072126**

Communication System: CDMA ; Frequency: 848.31 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.3

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch777/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 62.4 V/m

Probe Modulation Factor = 2.94

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 26.7 V/m; Power Drift = 0.065 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1	Grid 2	Grid 3
<b>56.9 M4</b>	<b>63.5 M4</b>	<b>62.1 M4</b>
Grid 4	Grid 5	Grid 6
<b>56.4 M4</b>	<b>62.4 M4</b>	<b>62.1 M4</b>
Grid 7	Grid 8	Grid 9
<b>52.7 M4</b>	<b>60.1 M4</b>	<b>59.4 M4</b>

**Cursor:**

Total = 63.5 V/m

E Category: M4

Location: -1, -15.5, 8.7 mm



0 dB = 63.5V/m

**#18 HAC\_E\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch384\_PDA 2\_Battery 2****DUT: 072126**

Communication System: CDMA ; Frequency: 836.52 MHz; Duty Cycle: 1:1  
 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>  
 Ambient Temperature : 22.3

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2009/9/18
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 68.1 V/m

Probe Modulation Factor = 2.94

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 28.9 V/m; Power Drift = 0.145 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>62.7 M4</b>	Grid 2 <b>69.3 M4</b>	Grid 3 <b>68.7 M4</b>
Grid 4 <b>61.8 M4</b>	Grid 5 <b>68.1 M4</b>	Grid 6 <b>66.8 M4</b>
Grid 7 <b>60 M4</b>	Grid 8 <b>65.3 M4</b>	Grid 9 <b>63.4 M4</b>

**Cursor:**

Total = 69.3 V/m

E Category: M4

Location: -5, -13.5, 8.7 mm



0 dB = 69.3V/m

**#19 HAC\_E\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch384\_Slide Right\_PDA  
2\_Battery 2****DUT: 072126**

Communication System: CDMA ; Frequency: 836.52 MHz; Duty Cycle: 1:1  
 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>  
 Ambient Temperature : 22.3

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn778; Calibrated: 2009/9/18
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 60.3 V/m

Probe Modulation Factor = 2.94

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 25.1 V/m; Power Drift = -0.089 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>50.7 M4</b>	Grid 2 <b>56.9 M4</b>	Grid 3 <b>55.8 M4</b>
Grid 4 <b>54.3 M4</b>	Grid 5 <b>60.3 M4</b>	Grid 6 <b>59.5 M4</b>
Grid 7 <b>56.1 M4</b>	Grid 8 <b>60.5 M4</b>	Grid 9 <b>57.7 M4</b>

**Cursor:**

Total = 60.5 V/m

E Category: M4

Location: -2.5, 11, 8.7 mm



**#20 HAC\_E\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch600\_PDA 1\_Battery 1****DUT: 072126**

Communication System: CDMA ; Frequency: 1880 MHz;Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch600/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 28.6 V/m

Probe Modulation Factor = 3.18

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 5.93 V/m; Power Drift = -0.00825 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>19.6 M4</b>	Grid 2 <b>26.7 M4</b>	Grid 3 <b>28.6 M4</b>
Grid 4 <b>21.7 M4</b>	Grid 5 <b>22.5 M4</b>	Grid 6 <b>21.2 M4</b>
Grid 7 <b>32.2 M4</b>	Grid 8 <b>30.8 M4</b>	Grid 9 <b>30.2 M4</b>

**Cursor:**

Total = 32.2 V/m

E Category: M4

Location: 25, 25, 8.7 mm



0 dB = 32.2V/m

**#21 HAC\_E\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch25\_PDA 1\_Battery 1****DUT: 072126**

Communication System: CDMA ; Frequency: 1851.25 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 30.6 V/m

Probe Modulation Factor = 3.18

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 5.32 V/m; Power Drift = 0.196 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>20 M4</b>	Grid 2 <b>31.3 M4</b>	Grid 3 <b>31.7 M4</b>
Grid 4 <b>22 M4</b>	Grid 5 <b>22.2 M4</b>	Grid 6 <b>21.6 M4</b>
Grid 7 <b>28.8 M4</b>	Grid 8 <b>30.6 M4</b>	Grid 9 <b>29.8 M4</b>

**Cursor:**

Total = 31.7 V/m

E Category: M4

Location: -12, -25, 8.7 mm



0 dB = 31.7V/m

**#22 HAC\_E\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch1175\_PDA 1\_Battery 1**

**DUT: 072126**

Communication System: CDMA ; Frequency: 1908.75 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch1175/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 28.7 V/m

Probe Modulation Factor = 3.18

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 5.74 V/m; Power Drift = -0.139 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>23.3 M4</b>	Grid 2 <b>28.7 M4</b>	Grid 3 <b>28.7 M4</b>
Grid 4 <b>21 M4</b>	Grid 5 <b>23 M4</b>	Grid 6 <b>20 M4</b>
Grid 7 <b>29.2 M4</b>	Grid 8 <b>32.6 M4</b>	Grid 9 <b>30.8 M4</b>

**Cursor:**

Total = 32.6 V/m

E Category: M4

Location: -4, 25, 8.7 mm



0 dB = 32.6V/m

**#23 HAC\_E\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch25\_PDA 2\_Battery 2****DUT: 072126**

Communication System: CDMA ; Frequency: 1851.25 MHz;Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 30.8 V/m

Probe Modulation Factor = 3.18

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 10.9 V/m; Power Drift = -0.057 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>25.8 M4</b>	Grid 2 <b>39.5 M4</b>	Grid 3 <b>40.6 M4</b>
Grid 4 <b>21.2 M4</b>	Grid 5 <b>30.8 M4</b>	Grid 6 <b>30.9 M4</b>
Grid 7 <b>30.4 M4</b>	Grid 8 <b>28.8 M4</b>	Grid 9 <b>26.1 M4</b>

**Cursor:**

Total = 40.6 V/m

E Category: M4

Location: -10.5, -25, 8.7 mm



0 dB = 40.6V/m

**#24 HAC\_E\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch25\_Slide Right\_PDA 2\_Battery 2**

**DUT: 072126**

Communication System: CDMA ; Frequency: 1851.25 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 25.4 V/m

Probe Modulation Factor = 3.18

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 7.81 V/m; Power Drift = 0.132 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m


Grid 1 <b>19.1 M4</b>	Grid 2 <b>27.1 M4</b>	Grid 3 <b>26.9 M4</b>
Grid 4 <b>18.3 M4</b>	Grid 5 <b>25.4 M4</b>	Grid 6 <b>25.6 M4</b>
Grid 7 <b>25.2 M4</b>	Grid 8 <b>23.4 M4</b>	Grid 9 <b>23.1 M4</b>

**Cursor:**

Total = 27.1 V/m

E Category: M4

Location: -6, -19.5, 8.7 mm



0 dB = 27.1V/m

**#25 HAC\_H\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch384\_PDA 1\_Battery 1**

**DUT: 072126**

Communication System: CDMA ; Frequency: 836.52 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.4 ; Liquid Temperature : 22.0

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.095 A/m

Probe Modulation Factor = 2.71

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.023 A/m; Power Drift = 0.084 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.110 M4</b>	Grid 2 <b>0.078 M4</b>	Grid 3 <b>0.049 M4</b>
Grid 4 <b>0.090 M4</b>	Grid 5 <b>0.068 M4</b>	Grid 6 <b>0.048 M4</b>
Grid 7 <b>0.095 M4</b>	Grid 8 <b>0.074 M4</b>	Grid 9 <b>0.049 M4</b>

**Cursor:**

Total = 0.110 A/m

H Category: M4

Location: 25, -25, 9.2 mm



0 dB = 0.110A/m

**#26 HAC\_H\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch1013\_PDA 1\_Battery 1**

**DUT: 072126**

Communication System: CDMA ; Frequency: 824.7 MHz;Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch1013/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.086 A/m

Probe Modulation Factor = 2.71

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.021 A/m; Power Drift = 0.068 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.093 M4</b>	Grid 2 <b>0.067 M4</b>	Grid 3 <b>0.044 M4</b>
Grid 4 <b>0.081 M4</b>	Grid 5 <b>0.059 M4</b>	Grid 6 <b>0.046 M4</b>
Grid 7 <b>0.086 M4</b>	Grid 8 <b>0.066 M4</b>	Grid 9 <b>0.046 M4</b>

**Cursor:**

Total = 0.093 A/m

H Category: M4

Location: 25, -25, 9.2 mm



0 dB = 0.093A/m

**#27 HAC\_H\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch777\_PDA 1\_Battery 1**

**DUT: 072126**

Communication System: CDMA ; Frequency: 848.31 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.5

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch777/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.091 A/m

Probe Modulation Factor = 2.71

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.022 A/m; Power Drift = 0.042 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.109 M4</b>	Grid 2 <b>0.077 M4</b>	Grid 3 <b>0.046 M4</b>
Grid 4 <b>0.089 M4</b>	Grid 5 <b>0.067 M4</b>	Grid 6 <b>0.046 M4</b>
Grid 7 <b>0.091 M4</b>	Grid 8 <b>0.070 M4</b>	Grid 9 <b>0.046 M4</b>

**Cursor:**

Total = 0.109 A/m

H Category: M4

Location: 25, -25, 9.2 mm



0 dB = 0.109A/m

**#28 HAC\_H\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch384\_PDA 2\_Battery 2****DUT: 072126**

Communication System: CDMA ; Frequency: 836.52 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.4

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.110 A/m

Probe Modulation Factor = 2.71

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.026 A/m; Power Drift = 0.042 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.116 M4</b>	Grid 2 <b>0.082 M4</b>	Grid 3 <b>0.047 M4</b>
Grid 4 <b>0.099 M4</b>	Grid 5 <b>0.075 M4</b>	Grid 6 <b>0.050 M4</b>
Grid 7 <b>0.110 M4</b>	Grid 8 <b>0.083 M4</b>	Grid 9 <b>0.056 M4</b>

**Cursor:**

Total = 0.116 A/m

H Category: M4

Location: 25, -25, 9.2 mm



0 dB = 0.116A/m

**#29 HAC\_H\_CDMA2000 BC0\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch384\_Slide Right\_PDA 2\_Battery 2****DUT: 072126**

Communication System: CDMA ; Frequency: 836.52 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.5

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.102 A/m

Probe Modulation Factor = 2.71

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.021 A/m; Power Drift = 0.138 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.102 M4</b>	Grid 2 <b>0.077 M4</b>	Grid 3 <b>0.051 M4</b>
Grid 4 <b>0.099 M4</b>	Grid 5 <b>0.071 M4</b>	Grid 6 <b>0.046 M4</b>
Grid 7 <b>0.107 M4</b>	Grid 8 <b>0.075 M4</b>	Grid 9 <b>0.044 M4</b>

**Cursor:**

Total = 0.107 A/m

H Category: M4

Location: 25, 25, 9.2 mm



0 dB = 0.107A/m

**#30 HAC\_H\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch600\_PDA 1\_Battery 1****DUT: 072126**

Communication System: CDMA ; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.6

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch600/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.077 A/m

Probe Modulation Factor = 2.67

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.041 A/m; Power Drift = 0.069 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.068 M4</b>	Grid 2 <b>0.072 M4</b>	Grid 3 <b>0.071 M4</b>
Grid 4 <b>0.069 M4</b>	Grid 5 <b>0.077 M4</b>	Grid 6 <b>0.076 M4</b>
Grid 7 <b>0.062 M4</b>	Grid 8 <b>0.075 M4</b>	Grid 9 <b>0.069 M4</b>

**Cursor:**

Total = 0.077 A/m

H Category: M4

Location: -5, 3.5, 9.2 mm



0 dB = 0.077A/m

**#31 HAC\_H\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch25\_PDA 1\_Battery 1****DUT: 072126**

Communication System: CDMA ; Frequency: 1851.25 MHz;Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.6

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.090 A/m

Probe Modulation Factor = 2.67

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.049 A/m; Power Drift = -0.033 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.072 M4</b>	Grid 2 <b>0.080 M4</b>	Grid 3 <b>0.079 M4</b>
Grid 4 <b>0.071 M4</b>	Grid 5 <b>0.090 M4</b>	Grid 6 <b>0.087 M4</b>
Grid 7 <b>0.067 M4</b>	Grid 8 <b>0.087 M4</b>	Grid 9 <b>0.079 M4</b>

**Cursor:**

Total = 0.090 A/m

H Category: M4

Location: -4.5, 4.5, 9.2 mm



0 dB = 0.090A/m

**#32 HAC\_H\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch1175\_PDA 1\_Battery 1**

**DUT: 072126**

Communication System: CDMA ; Frequency: 1908.75 MHz;Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.6

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch1175/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.077 A/m

Probe Modulation Factor = 2.67

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.039 A/m; Power Drift = 0.052 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.070 M4</b>	Grid 2 <b>0.074 M4</b>	Grid 3 <b>0.072 M4</b>
Grid 4 <b>0.071 M4</b>	Grid 5 <b>0.077 M4</b>	Grid 6 <b>0.075 M4</b>
Grid 7 <b>0.062 M4</b>	Grid 8 <b>0.074 M4</b>	Grid 9 <b>0.072 M4</b>

**Cursor:**

Total = 0.077 A/m

H Category: M4

Location: -2, -0.5, 9.2 mm



0 dB = 0.077A/m

**#33 HAC\_H\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch25\_PDA 2\_Battery 2****DUT: 072126**

Communication System: CDMA ; Frequency: 1851.25 MHz;Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.6

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.102 A/m

Probe Modulation Factor = 2.67

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.048 A/m; Power Drift = -0.699 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.076 M4</b>	Grid 2 <b>0.076 M4</b>	Grid 3 <b>0.076 M4</b>
Grid 4 <b>0.061 M4</b>	Grid 5 <b>0.095 M4</b>	Grid 6 <b>0.087 M4</b>
Grid 7 <b>0.064 M4</b>	Grid 8 <b>0.102 M4</b>	Grid 9 <b>0.087 M4</b>

**Cursor:**

Total = 0.102 A/m

H Category: M4

Location: -1, 15, 9.2 mm



0 dB = 0.102A/m

**#34 HAC\_H\_CDMA2000 BC1\_RC1\_SO55\_Voice\_Loop\_Eighth Rate\_Ch25\_Slide Right\_PDA 2\_Battery 2**

**DUT: 072126**

Communication System: CDMA ; Frequency: 1851.25 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Ambient Temperature : 22.6

DASY5 Configuration:

- Probe: H3DV6 - SN6184; ; Calibrated: 2010/1/22

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn778; Calibrated: 2009/9/18

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;

- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

**Ch25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.060 A/m

Probe Modulation Factor = 2.67

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.026 A/m; Power Drift = -0.068 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m


Grid 1 <b>0.058 M4</b>	Grid 2 <b>0.058 M4</b>	Grid 3 <b>0.043 M4</b>
Grid 4 <b>0.059 M4</b>	Grid 5 <b>0.059 M4</b>	Grid 6 <b>0.044 M4</b>
Grid 7 <b>0.060 M4</b>	Grid 8 <b>0.054 M4</b>	Grid 9 <b>0.048 M4</b>

**Cursor:**

Total = 0.060 A/m

H Category: M4

Location: 21.5, 25, 9.2 mm



0 dB = 0.060A/m