

COMOHAC Broadband 800-950 MHz dipole Calibration Report



Ref: CR-280-21-08-SATB-A

Page: 1/4

Issue: A

Date: 2012/10/06

**COMOHAC BROADBAND 800-950 MHZ DIPOLE
CALIBRATION REPORT**

Prepared By: LUC Jérôme, SATIMO

Project Description: HAC TEST BENCH

Prepared For (End User): Shenzhen Morlab Communication Technology

This document is issued by SATIMO, in confidence and is not to be reproduced in whole or in part without the prior written permission. The information contained herein is to be used only for the purpose for which it is submitted and is not to be released in whole or in part without the prior written permission of SATIMO.

COMOHAC Broadband 800-950 MHz dipole Calibration Report



Ref: CR-280-21-08-SATB-A

Page: 2/4

Issue: A

Date: 2012/10/06

COMOHAC BROADBAND DIPOLE 800-950 MHz CALIBRATION REPORT

DATE: 14/11/2008

REFERENCE: SN 36/08 DHA16

OBJECT: BROADBAND DIPOLE 800-950 Mhz

MANUFACTURER: SATIMO

SERIAL NUMBER: SN 36/08 DHA16

CUSTOMER: Shenzhen Morlab Communication Technology

CONTRACT: PF2130108b_SAR_Morlab

DATE OF CALIBRATION: 06/10/2012

WARRANTY:

This Calibration certificate may not be reproduced other than in full. Calibration certificates without signature and seal are not valid. This documentation contains property information which is protected by copyright. All right are reserved. No part of this document may be photocopied, reproduced without the prior written agreement of SATIMO. SATIMO shall not be liable for errors contained herein or for incidental or consequential in connection with the furnishing, performance or use of this material. Warranty doesn't apply to Normal wear, Normal tear, Improper use, Improper maintain, Improper installation.

Date

Oct. 06, 2012

SAR TEAM MANAGER

SATIMO Bretagne
Technopôle Brest Iroise
Zone du Vernis
225 rue Pierre Rivoalon
29200 BREST

COMOHAC Broadband 800-950 MHz dipole Calibration Report



Ref: CR-280-21-08-SATB-A

Page: 3/4

Issue: A

Date: 2012/10/06

PRODUCT DESCRIPTION




CALIBRATION TEST EQUIPMENT

TYPE	IDENTIFICATION
Vector Network Analyzer	HP8753D

MEASUREMENT PROCEDURE

Measurement of the return loss of the dipole in air



VSWR between 800 and 950 MHz < -10 dB.

COMOHAC Broadband 800-950 MHz dipole Calibration Report



Ref: CR-280-21-08-SATB-A

Page: 4/4

Issue: A

Date: 2012/10/06

MEASUREMENT RESULT

Input power of the dipole: 20 dBm

Distance between the dipole and the probe: 10 mm

Scan resolution: 5 mm

Frequency	E-Field	H-Field
900 MHz	205 V/m	0.448 A/m