

Response to FCC Correspondence 11365

As indicated on page 3 of the technical report this product has no capability to be powered from the AC mains. This sensor is a small part of a building-wide access control network consisting of possibly hundreds of components fed by a DC bus. We used a DC power supply to simulate this bus which is not representative of an actual installation, but rather a convenience to facilitate laboratory testing.