



We help ideas meet the real world

DELTA Test Report

TEST REPORT issued by an Accredited Testing Laboratory



1688
ISO/IEC 17025

EMC emission test of Sense X-S

Performed for Precise Biometrics AB

REC-E703141_2F

Project no.: E703141

Page 1 of 17

19 Feb.2012

**DELTA Development
Technology AB**

Finnslätten
Elektronikgatan 47
721 36 Västerås
Sweden

Tel. 021-31 44 80
Fax 021-31 44 81
info@delta-dt.se
www.delta-dt.se

Bankgiro 5534-7728
VAT SE 556556207001

DELTA Development
Technology AB
is a subsidiary company of
DELTA

Title EMC emission test of Sense X-S

Test object Sense X-S

Report no. REC-E703141_2F

Project no. E703141

Test period 15 Feb. 2012

Client Precise Biometrics AB
Scheelevägen 30
SE-220 07 Lund
Sweden
Tel.: 046-311100

Contact person Lena Strutz
E-mail: Lena.strutz@precisebiometrics.com

Manufacturer Precise Biometrics AB

Specifications FCC Part 15 Subpart B


Results The test object was found to be in compliance with the specifications, as listed in Section 1

Test personnel Daniela Coman

Date 19 Feb. 2012

Project Manager 

Daniela Coman
DELTA

Responsible 

Ulf Bjerke Technical Manager
DELTA



	Table of contents	Page
1.	Summary of tests	4
2.	Test object(s) and auxiliary equipment	5
2.1	Test object(s)	5
2.2	Auxiliary equipment	6
3.	General test conditions	7
3.1	Test setup during test	7
3.1.1	Description and intended use of test object	7
3.1.2	Test modes during emission tests	7
3.1.3	Nominal power consumption	7
3.2	Modifications of the test object	8
3.3	Test sequence	8
4.	Test results	9
4.1	Measurement of radio frequency voltage on mains	9
4.2	Measurement of radio frequency electromagnetic field	13
5.	National registrations and accreditations	16
5.1	FCC Registrations	16
5.2	SWEDAC Accreditation	16
6.	List of instruments	17



1. Summary of tests

Tests	Test methods	Results
Measurement of radio frequency voltage on mains	ANSI C63.4:2009	Passed
Measurement of radio frequency electromagnetic field	ANSI C63.4:2009	Passed

Conclusion

The test object(s) mentioned in this report meet(s) the requirements of the standard(s) stated below.

- 47 CFR – Telecommunication, Chapter I – FCC Part 15 – Radio Frequency Devices - Subpart B: Unintentional radiators

The test results relate only to the object(s) tested.



2. Test object(s) and auxiliary equipment

2.1 Test object(s)

Test object 2.1.1

Name of test object	Sense X-S
Model / type	Precise Sense X-S
Part no.	SAA 103 1002
Serial no.	0-1
Manufacturer	Precise Biometrics AB
Supply voltage	5V
Software version	N/A
Hardware version	R2A
Highest frequency generated or used	12 MHz
Comment	



Photo 2.1.1 Precise Sense X-S

2.2 Auxiliary equipment

Auxiliary equipment 2.2.1

Name of auxiliary equipment	Computer
Model / type	Thinkpad 600E
Part no.	2645-8BG
Serial no.	5537CNN 02/99
Sw version	SPA 123 1004 R2A
Manufacturer	IBM
Supply voltage	230V

Auxiliary equipment supplied by the client, who also has the responsibility for its correct function and set up.

Auxiliary equipment 2.2.2

Name of auxiliary equipment	Desktop Printer
Model / type	Deskjet895Cxi
Part no.	C6410A
Serial no.	HU0151N087
Manufacturer	Hewlett Packard
Supply voltage	230V

Auxiliary equipment supplied by the client, who also has the responsibility for its correct function and set up.

Auxiliary equipment 2.2.3

Name of auxiliary equipment	Computer Mouse
Model / type	Wheel Mouse
Part no.	83351-576
Serial no.	0304842
Manufacturer	Microsoft
Supply voltage	5V

Auxiliary equipment supplied by the client, who also has the responsibility for its correct function and set up.



3. General test conditions

3.1 Test setup during test




Figure 3.1.1 Block diagram of test object(s) with cables and auxiliary equipment.

Name	Cat.	Type	Max. Length
Signal Cable 1	Shielded	USB Cable with ferrite	1.5 m
Power cable	Unshielded	3 x 1.5 mm ²	1.8 m
Power cable	Unshielded	3 x 1.5 mm ²	1.8 m
Printer cable	Shielded		1.9 m

3.1.1 Description and intended use of test object

Fingerprint reader intended for office or personal use.

3.1.2 Test modes during emission tests

Continuous fingerprint sensor image capture.

3.1.3 Nominal power consumption

< 120 mA



3.2 Modifications of the test object

No modification was implemented to the test object.

3.3 Test sequence

The tests described in this test report were performed in the following sequence:

- | |
|--|
| <ol style="list-style-type: none">1. Measurement of radio frequency electromagnetic field2. Measurement of radio frequency voltage on mains |
|--|



4. Test results

4.1 Measurement of radio frequency voltage on mains

Test object	Sense X-S	Sheet	CE-2
Type	Precise Sense X-S	Project no.	E703141
Serial no.	0-1	Date	13 Feb. 2012
Client	Precise Biometrics AB	Initials	DAC
Specification	FCC Part 15 Subpart B, Class B	Frequency	0.15-30 MHz


Test method	ANSI C63.4:2009	Temperature	21 °C
Characteristics	Artificial mains network: 50 Ω , 50 μ H	Humidity	31 % RH
Detector	Peak, quasi peak, and average	Bandwidth	9 kHz
Test equipm.	EMC Hall A Västerås Setup VEA1	Uncertainty	1.8 dB

Line under test	Maximum of Line and Neutral
Test result	The measured voltages were below the limit of Class B equipment.
Compliant	Yes
Comments	Mains voltage: 230 VAC to the personal computer to which Sense X-S is connected. During test an artificial hand was applied to the test object, please see photo

Conducted emission 2012-02-13

Complete measurement 0.15 - 30 MHz

EUT: Sense X-S 01
Manufacturer: Precise Biometrics AB
Operating Condition: 230 VAC 50Hz
Test Site: Delta Development Technology AB
Operator: Daniela Coman
Test Specification: FCC Part 15 Subpart B. Class B



MEASUREMENT RESULT: "E703141T2 CE_fin"

13-02-2012 14:23

Frequency MHz	Level dBμV	Transd dB	Limit dBμV	Margin dB	Detector	Line	PE
0.150000	53.60	0.3	66	12.4	QP	N	FLO
0.515000	47.30	0.3	56	8.7	QP	N	FLO
0.730000	46.80	0.3	56	9.2	QP	L1	FLO
1.165000	44.90	0.4	56	11.1	QP	L1	FLO
2.190000	43.20	0.6	56	12.8	QP	N	FLO
2.345000	42.10	0.5	56	13.9	QP	L1	FLO
2.390000	37.40	0.6	56	18.6	QP	N	FLO
2.550000	38.00	0.5	56	18.0	QP	L1	FLO
8.380000	43.70	0.9	60	16.3	QP	L1	FLO

MEASUREMENT RESULT: "E703141T2 CE_fin2"

13-02-2012 14:23

Frequency MHz	Level dBμV	Transd dB	Limit dBμV	Margin dB	Detector	Line	PE
0.310000	46.60	0.2	50	3.4	AV	L1	FLO
0.515000	42.10	0.2	46	3.9	AV	L1	FLO
0.735000	43.80	0.3	46	2.2	AV	L1	FLO
1.365000	38.90	0.4	46	7.1	AV	L1	FLO
2.160000	27.20	0.5	46	18.8	AV	L1	FLO
2.595000	27.10	0.5	46	18.9	AV	L1	FLO
4.795000	31.60	0.8	46	14.4	AV	N	FLO
6.695000	30.20	1.0	50	19.8	AV	N	FLO
7.740000	30.50	0.9	50	19.5	AV	L1	FLO
8.990000	32.70	0.9	50	17.3	AV	L1	FLO





Photo 4.1.1 Test setup regarding measurement of radio frequency voltage on mains.




Photo 4.1.2 Test setup regarding measurement of radio frequency voltage on mains, view from left side.



4.2 Measurement of radio frequency electromagnetic field

Test object	Sense X-S	Sheet	RE-2
Type	Precise Sense X-S	Project no.	E703141
Serial no.	0-1	Date	13 Feb. 2012
Client	Precise Biometrics AB	Initials	DAC
Specification	FCC Part 15 Subpart B, Class B	Frequency	30-1000 MHz

Test method	ANSI C63.4:2009	Temperature	22 °C
Characteristics	Complete test, height: 1-4 m, v/h pol.	Humidity	31 % RH
Detector	Peak and quasi peak	Bandwidth	120 kHz
Test equipm.	EMC Hall A Västerås Setup VEC1	Uncertainty	5.1 dB

Test result The measured field strengths are below the limit of Class B equipment.

Compliant Yes


Comments Final maximal measurements by variation of turntable azimuth, antenna height, and antenna polarisation



Radiated emission 2012-02-13

Complete measurement 30-1000 MHz

EUT: X-S 0-1
Manufacturer: Precise Biometrics AB
Operating Condition: Powered via USB from PC
Test Site: DELTA Development Technology AB
Operator: Daniela Coman
Test Specification: FCC Part 15B Class B
Comment: Measured at 10 m measuring distance.



MEASUREMENT RESULT: "E703141T2 RE_fin"

13-02-2012 10:53

Frequency MHz	Level dBμV/m	Transd dB	Limit dBμV/m	Margin dB	Det.	Height cm	Azimuth deg	Polarization
32.880000	12.70	-9.6	29.5	16.8	QP	153.0	278.00	VERTICAL
100.170000	26.10	-15.9	33.1	7.0	QP	111.0	337.00	VERTICAL
108.180000	28.20	-15.2	33.1	4.9	QP	100.0	324.00	VERTICAL
116.190000	27.30	-14.5	33.1	5.8	QP	103.0	0.00	VERTICAL
164.190000	16.90	-15.4	33.1	16.2	QP	200.0	316.00	VERTICAL
195.660000	23.70	-17.0	33.1	9.4	QP	100.0	285.00	VERTICAL
199.890000	24.00	-16.8	33.1	9.1	QP	100.0	292.00	VERTICAL
223.680000	24.80	-15.5	35.5	10.7	QP	114.0	157.00	VERTICAL
479.310000	32.90	-8.2	35.5	2.6	QP	200.0	87.00	HORIZONTAL
511.290000	30.70	-7.6	35.5	4.8	QP	101.0	311.00	VERTICAL





Photo 4.2.1 Test setup regarding measurement of radio frequency electromagnetic field.
Front view.




Photo 4.2.2 Test setup regarding measurement of radio frequency electromagnetic field.
Side view.



5. National registrations and accreditations

5.1 FCC Registrations

Organization: Federal Communications Commission, USA

Registration Number: 516880

Facilities: EMC chamber A, 3 m and 10 m

5.2 SWEDAC Accreditation

Organization: Swedish Board for Accreditation and Conformity Assessment - SWEDAC, see www.swedac.se and www.ilac.org

Registration Number: 1688

SWEDAC is part of ILAC (International Laboratory Accreditation Cooperation) including its MRA (Mutual Recognition Arrangement).



6. List of instruments

Setup VEA1					
Measurement of radio frequency voltage on mains					
Used	ID no.	Description	Manufacturer	Type no.	Setup uncertainty
☒	36032	Software	Rohde & Schwarz	ES-K1 ver 1.71 SP2	1.8 dB
☒	36020	Measuring receiver	Rohde & Schwarz	ESU26	
☒	IE-B918	LISN 4 x 100 A 800 V	Schwarzbeck	NNLK 8129	
☒	IE-B919	LISN 2 x 10 A 250 V	Rohde & Schwarz	ESH3-Z5	

Setup VEC1					
Measurement of radio frequency electromagnetic field					
Used	ID no.	Description	Manufacturer	Type no.	Setup uncertainty
☒	36032	Software	Rohde & Schwarz	ES-K1 ver 1.71 SP2	5.1 dB
☒	36020	Measuring receiver	Rohde & Schwarz	ESU26	
☒	IE-B928	Antenna Bilog	Chase	CBL6111A	
☒	IE-B758	Preamplifier	HP	8447F	
☒	IE-B918	LISN 4 x 100 A 800 V	Schwarzbeck	NNLK 8129	
☒	IE-B920	Controller	Heinrich Deisel	HD 100	
☒		Turntable	Heinrich Deisel	DT 440	
☒		Antenna mast	Heinrich Deisel	MA 240	

Other instruments used					
Used	ID no.	Description	Manufacturer	Type no.	Setup uncertainty
☒	IM-A308	Temperature- and hygrometer	Vaisala	HMI31	

