

 **Fueling Technologies, Inc.**
Woodinville, Washington

Liquid Level Gauge For LP Gas

Part No.: 2800027

Model 100 Tank Unit for

Model 100 LPG Tank Gauge System

Intrinsically Safe When Installed in Accordance

With Control Drawing 4000427

Class I, Div 1, Group D

Warning: Substitution of Components May

Impair Intrinsic Safety



LISTED

9EX3

Only Use FTI Supplied Battery Assembly

Part No's 2500201-1 or -2

Temperature Code: T6

Do Not Connect Any External Wiring

This device complies with part 15 of the FCC rules.

Operation is subject to the following two conditions:

1. This device may not cause harmful interference, and
2. This device must accept any interference that may cause undesired operation.

FCC ID: PGXM100TU

Locate on Exterior Cover of Unit