


Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 12.07.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2450 MHz; Type: D2450V2; Serial: D2450V2 - SN:829

Communication System: UID 0 - CW; Frequency: 2450 MHz

Medium parameters used: $f = 2450$ MHz; $\sigma = 2.02$ S/m; $\epsilon_r = 51.9$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.01, 8.01, 8.01) @ 2450 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 107.9 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 25.6 W/kg


SAR(1 g) = 13 W/kg; SAR(10 g) = 6.06 W/kg

Maximum value of SAR (measured) = 21.1 W/kg



0 dB = 21.1 W/kg = 13.24 dBW/kg

Impedance Measurement Plot for Body TSL





Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 0108**

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Client **RF Exposure Lab**

Certificate No: **D5GHzV2-1085_Jul18**

CALIBRATION CERTIFICATE

Object **D5GHzV2 - SN:1085**

Calibration procedure(s) **QA CAL-22.v3
Calibration procedure for dipole validation kits between 3-6 GHz**

Calibration date: **July 19, 2018**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-18 (No. 217-02672/02673)	Apr-19
Power sensor NRP-Z91	SN: 103244	04-Apr-18 (No. 217-02672)	Apr-19
Power sensor NRP-Z91	SN: 103245	04-Apr-18 (No. 217-02673)	Apr-19
Reference 20 dB Attenuator	SN: 5058 (20k)	04-Apr-18 (No. 217-02682)	Apr-19
Type-N mismatch combination	SN: 5047.2 / 06327	04-Apr-18 (No. 217-02683)	Apr-19
Reference Probe EX3DV4	SN: 3503	30-Dec-17 (No. EX3-3503_Dec17)	Dec-18
DAE4	SN: 601	26-Oct-17 (No. DAE4-601_Oct17)	Oct-18
Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18
Network Analyzer Agilent E8358A	SN: US41080477	31-Mar-14 (in house check Oct-17)	In house check: Oct-18

Calibrated by: **Manu Seitz** Name **Laboratory Technician** Function **Signature**

Approved by: **Katja Pokovic** Technical Manager

Issued: July 19, 2018

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions:** Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:** The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:** These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:** One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:** SAR measured at the stated antenna input power.
- SAR normalized:** SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:** The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.1
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom V5.0	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy = 4.0 mm, dz = 1.4 mm	Graded Ratio = 1.4 (Z direction)
Frequency	5250 MHz $\pm$ 1 MHz 5600 MHz $\pm$ 1 MHz 5750 MHz $\pm$ 1 MHz	

Head TSL parameters at 5250 MHz

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	35.9	4.71 mho/m
Measured Head TSL parameters	(22.0 $\pm$ 0.2) °C	36.1 $\pm$ 6 %	4.56 mho/m $\pm$ 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL at 5250 MHz

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	100 mW input power	8.28 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	82.8 W/kg $\pm$ 19.9 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	100 mW input power	2.40 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	24.0 W/kg $\pm$ 19.5 % (k=2)

Head TSL parameters at 5600 MHz

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	35.5	5.07 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	35.6 ± 6 %	4.92 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL at 5600 MHz

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	100 mW input power	8.55 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	85.4 W / kg ± 19.9 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	100 mW input power	2.46 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	24.6 W/kg ± 19.5 % (k=2)

Head TSL parameters at 5750 MHz

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	35.4	5.22 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	35.4 ± 6 %	5.08 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL at 5750 MHz

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	100 mW input power	8.40 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	83.9 W/kg ± 19.9 % (k=2)

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	100 mW input power	2.41 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	24.1 W/kg ± 19.5 % (k=2)

Body TSL parameters at 5250 MHz

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	48.9	5.36 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	46.9 ± 6 %	5.47 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL at 5250 MHz

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	100 mW input power	7.74 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	76.8 W/kg ± 19.9 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	100 mW input power	2.17 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	21.5 W/kg ± 19.5 % (k=2)

Body TSL parameters at 5600 MHz

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	48.5	5.77 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	46.3 ± 6 %	5.94 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL at 5600 MHz

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	100 mW input power	8.02 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	79.5 W/kg ± 19.9 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	100 mW input power	2.26 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	22.4 W/kg ± 19.5 % (k=2)

Body TSL parameters at 5750 MHz

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	48.3	5.94 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	46.0 ± 6 %	6.14 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL at 5750 MHz

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	100 mW input power	7.69 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	76.2 W/kg ± 19.9 % (k=2)

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	100 mW input power	2.16 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	21.3 W/kg ± 19.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL at 5250 MHz

Impedance, transformed to feed point	48.4 Ω - 7.7 j Ω
Return Loss	- 22.0 dB

Antenna Parameters with Head TSL at 5600 MHz

Impedance, transformed to feed point	53.7 Ω - 4.3 j Ω
Return Loss	- 25.3 dB

Antenna Parameters with Head TSL at 5750 MHz

Impedance, transformed to feed point	54.9 Ω - 4.6 j Ω
Return Loss	- 23.8 dB

Antenna Parameters with Body TSL at 5250 MHz

Impedance, transformed to feed point	48.5 Ω - 4.9 j Ω
Return Loss	- 25.8 dB

Antenna Parameters with Body TSL at 5600 MHz

Impedance, transformed to feed point	57.0 Ω - 3.5 j Ω
Return Loss	- 22.7 dB

Antenna Parameters with Body TSL at 5750 MHz

Impedance, transformed to feed point	55.5 Ω - 1.4 j Ω
Return Loss	- 25.4 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.204 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	December 21, 2009

DASY5 Validation Report for Head TSL

Date: 18.07.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole D5GHzV2; Type: D5GHzV2; Serial: D5GHzV2 - SN:1085

Communication System: UID 0 - CW; Frequency: 5250 MHz, Frequency: 5600 MHz, Frequency: 5750 MHz

Medium parameters used: $f = 5250$ MHz; $\sigma = 4.56$ S/m; $\epsilon_r = 36.1$; $\rho = 1000$ kg/m³,

Medium parameters used: $f = 5600$ MHz; $\sigma = 4.92$ S/m; $\epsilon_r = 35.6$; $\rho = 1000$ kg/m³,

Medium parameters used: $f = 5750$ MHz; $\sigma = 5.08$ S/m; $\epsilon_r = 35.4$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN3503; ConvF(5.51, 5.51, 5.51) @ 5250 MHz, ConvF(5.05, 5.05, 5.05) @ 5600 MHz, ConvF(4.98, 4.98, 4.98) @ 5750 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Head Tissue/Pin=100mW, dist=10mm, f=5250 MHz/Zoom Scan, dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 76.65 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 28.1 W/kg

SAR(1 g) = 8.28 W/kg; SAR(10 g) = 2.4 W/kg

Maximum value of SAR (measured) = 18.3 W/kg

Dipole Calibration for Head Tissue/Pin=100mW, dist=10mm, f=5600 MHz/Zoom Scan, dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 75.65 V/m; Power Drift = -0.08 dB

Peak SAR (extrapolated) = 31.7 W/kg

SAR(1 g) = 8.55 W/kg; SAR(10 g) = 2.46 W/kg

Maximum value of SAR (measured) = 20.7 W/kg


Dipole Calibration for Head Tissue/Pin=100mW, dist=10mm, f=5750 MHz/Zoom Scan, dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 74.43 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 32.1 W/kg


SAR(1 g) = 8.4 W/kg; SAR(10 g) = 2.41 W/kg

Maximum value of SAR (measured) = 20.6 W/kg



0 dB = 20.6 W/kg = 13.14 dBW/kg

Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 19.07.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole D5GHzV2; Type: D5GHzV2; Serial: D5GHzV2 - SN:1085

Communication System: UID 0 - CW; Frequency: 5250 MHz, Frequency: 5600 MHz, Frequency: 5750 MHz

Medium parameters used: $f = 5250$ MHz; $\sigma = 5.47$ S/m; $\epsilon_r = 46.9$; $\rho = 1000$ kg/m³,

Medium parameters used: $f = 5600$ MHz; $\sigma = 5.94$ S/m; $\epsilon_r = 46.3$; $\rho = 1000$ kg/m³,

Medium parameters used: $f = 5750$ MHz; $\sigma = 6.14$ S/m; $\epsilon_r = 46$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN3503; ConvF(5.26, 5.26, 5.26) @ 5250 MHz, ConvF(4.65, 4.65, 4.65) @ 5600 MHz, ConvF(4.57, 4.57, 4.57) @ 5750 MHz; Calibrated: 30.12.2017
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.1(1476); SEMCAD X 14.6.11(7439)

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5250 MHz/Zoom Scan,

dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 68.42 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 29.2 W/kg

SAR(1 g) = 7.74 W/kg; SAR(10 g) = 2.17 W/kg

Maximum value of SAR (measured) = 17.6 W/kg

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5600 MHz/Zoom Scan,

dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 68.20 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 32.9 W/kg

SAR(1 g) = 8.02 W/kg; SAR(10 g) = 2.26 W/kg

Maximum value of SAR (measured) = 18.8 W/kg

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5750 MHz/Zoom Scan,


dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 66.91 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 32.0 W/kg


SAR(1 g) = 7.69 W/kg; SAR(10 g) = 2.16 W/kg

Maximum value of SAR (measured) = 18.2 W/kg



0 dB = 18.2 W/kg = 12.60 dBW/kg

Impedance Measurement Plot for Body TSL



Appendix F – Phantom Calibration Data Sheets

Certificate of Conformity / First Article Inspection

Item	Oval Flat Phantom ELI 4.0
Type No	QD OVA 001 B
Series No	1003 and higher
Manufacturer	Untersee Composites Knebelstrasse 8 CH-8268 Mannenbach, Switzerland

Tests

Complete tests were made on the prototype units QD OVA 001 AA 1001, QD OVA 001 AB 1002, pre-series units QD OVA 001 BA 1003-1005 as well as on the series units QD OVA 001 BB, 1006 ff.

Test	Requirement	Details	Units tested
Material thickness	Compliant with the standard requirements	Bottom plate: 2.0mm +/- 0.2mm	all
Material parameters	Dielectric parameters for required frequencies	< 6 GHz: Rel. permittivity = 4 +/-1, Loss tangent ≤ 0.05	Material sample
Material resistivity	The material has been tested to be compatible with the liquids defined in the standards if handled and cleaned according to the instructions.	DGBE based simulating liquids. Observe Technical Note for material compatibility.	Equivalent phantoms, Material sample
Shape	Thickness of bottom material, Internal dimensions, Sagging compatible with standards from minimum frequency	Bottom elliptical 600 x 400 mm Depth 190 mm, Shape is within tolerance for filling height up to 155 mm, Eventual sagging is reduced or eliminated by support via DUT	Prototypes, Sample testing

Standards

- [1] CENELEC EN 50361-2001, « Basic standard for the measurement of the Specific Absorption Rate related to human exposure to electromagnetic fields from mobile phones (300 MHz – 3 GHz) », July 2001
- [2] IEEE 1528-2003, "Recommended Practice for Determining the Peak Spatial-Average Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques, December 2003
- [3] IEC 62209 – 1, "Specific Absorption Rate (SAR) in the frequency range of 300 MHz to 3 GHz – Measurement Procedure, Part 1: Hand-held mobile wireless communication devices", February 2005
- [4] IEC 62209 – 2, Draft, "Human Exposure to Radio Frequency Fields from Handheld and Body-Mounted Wireless Communication Devices – Human models, Instrumentation and Procedures – Part 2: Procedure to determine the Specific Absorption Rate (SAR) in the head and body for 30 MHz to 6 GHz Handheld and Body-Mounted Devices used in close proximity to the Body.", February 2005
- [5] OET Bulletin 65, Supplement C, "Evaluating Compliance with FCC Guidelines for Human Exposure to Radiofrequency Electromagnetic Fields", Edition January 2001

Based on the tests above, we certify that this item is in compliance with the standards [1] to [5] if operated according to the specific requirements and considering the thickness. The dimensions are fully compliant with [4] from 30 MHz to 6 GHz. For the other standards, the minimum lower frequency limit is limited due to the dimensional requirements ([1]: 450 MHz, [2]: 300 MHz, [3]: 800 MHz, [5]: 375 MHz) and possibly further by the dimensions of the DUT.

s p e a g

Date 28.4.2008

Signature / Stamp

Schmid & Partner Engineering AG
 Zeughausstrasse 43, 8004 Zurich, Switzerland
 Phone +41 44 245 9700, Fax +41 44 245 9779
 info@speag.com, http://www.speag.com

Appendix G – Validation Summary

Per FCC KDB 865664 D02 v01r02, SAR system validation status should be documented to confirm measurement accuracy. The SAR systems (including SAR probes, system components and software versions) used for this device were validated against its performance specifications prior to the SAR measurements. Reference dipoles were used with the required tissue equivalent media for system validation according to the procedures outlined in FCC KDB 865664 D01 v01r04 and IEEE 1528-2013. Since SAR probe calibrations are frequency dependent, each probe calibration point was validated at a frequency within the valid frequency range of the probe calibration point using the system that normally operates with the probe for routine SAR measurements and according to the required tissue equivalent media.

A tabulated summary of the system validation status including the validation date(s), measurement frequencies, SAR probes and tissue dielectric parameters has been included.

Table G-1
SAR System Validation Summary

SAR System #	Freq. (MHz)	Date	Probe S/N	Probe Type	Probe Cal. Point		Cond. (σ)	Perm. (ϵ_r)	CW Validation			Modulation Validation		
									Sens-itivity	Probe Linearity	Probe Isotropy	Modulation Type	Duty Factor	PAR
3	750	5/11/2018	3662	EX3DV4	750	Body	0.98	55.51	Pass	Pass	Pass	QPSK	Pass	Pass
3	750	5/07/2019	3662	EX3DV4	750	Body	0.99	55.57	Pass	Pass	Pass	QPSK	Pass	Pass
3	835	5/11/2018	3662	EX3DV4	835	Body	0.98	55.27	Pass	Pass	Pass	WCDMA	Pass	Pass
3	835	5/11/2018	3662	EX3DV4	835	Body	0.98	55.27	Pass	Pass	Pass	QPSK	Pass	Pass
3	835	5/07/2019	3662	EX3DV4	835	Body	0.99	55.91	Pass	Pass	Pass	QPSK	Pass	Pass
3	1750	5/11/2018	3662	EX3DV4	1750	Body	1.54	53.25	Pass	Pass	Pass	WCDMA	Pass	Pass
3	1750	5/11/2018	3662	EX3DV4	1750	Body	1.54	53.25	Pass	Pass	Pass	QPSK	Pass	Pass
3	1750	5/07/2019	3662	EX3DV4	1750	Body	1.52	53.32	Pass	Pass	Pass	QPSK	Pass	Pass
3	1900	5/09/2018	3662	EX3DV4	1900	Body	1.48	52.01	Pass	Pass	Pass	WCDMA	Pass	Pass
3	1900	5/09/2018	3662	EX3DV4	1900	Body	1.48	52.01	Pass	Pass	Pass	QPSK	Pass	Pass
3	1900	5/07/2019	3662	EX3DV4	1900	Body	1.47	52.07	Pass	Pass	Pass	QPSK	Pass	Pass
3	3500	5/12/2018	3662	EX3DV4	3500	Body	3.36	51.29	Pass	Pass	Pass	QPSK	Pass	Pass
3	3500	5/7/2019	3662	EX3DV4	3500	Body	3.33	50.93	Pass	Pass	Pass	QPSK	Pass	Pass
3	3700	5/12/2018	3662	EX3DV4	3700	Body	3.36	51.29	Pass	Pass	Pass	QPSK	Pass	Pass
3	3700	5/7/2019	3662	EX3DV4	3700	Body	3.53	50.68	Pass	Pass	Pass	QPSK	Pass	Pass
3	2450	5/06/2018	3662	EX3DV4	2450	Body	1.96	52.64	Pass	Pass	Pass	OFDM/TDD	Pass	Pass
3	5250	5/05/2018	3662	EX3DV4	5250	Body	5.30	48.93	Pass	Pass	Pass	OFDM	N/A	Pass
3	5750	5/05/2018	3662	EX3DV4	5750	Body	5.97	48.13	Pass	Pass	Pass	OFDM	N/A	Pass

Appendix H – Carrier Aggregation & MIMO Downlink Conducted Powers

PCC										SCC1				SCC2				SCC3				SCC4				SCC5				Power with DL CA	Power without DL CA
Combination	Band	BW	Ch.	Freq.	Mod.	RB #	Offset	DL Ch.	DL Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.		
2A-2A-4A-5A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	4	20 MHz	2175	2132.5	5	10 MHz	2525	881.5	-----	-----	-----	-----	-----	-----	-----	-----	21.86	22.00
2A-5A-4B	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	5	10 MHz	2525	881.5	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	-----	-----	-----	-----	21.97	22.00
2A-5B	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	5	10 MHz	2525	881.5	5	10 MHz	2560	885	5	10 MHz	2490	878	-----	-----	-----	-----	-----	-----	-----	-----	21.92	22.00
2A-13A-4B	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	13	10 MHz	5230	851	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	-----	-----	-----	-----	21.88	22.00
2A-6A-4B	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	66	20 MHz	66886	2155	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	48	20 MHz	55890	3615	21.83	22.00
4A-4A-2A-5A	B4	20 MHz	20175	1732.5	QPSK	1	49	2175	2132.5	4	20 MHz	2075	2122.5	2	20 MHz	900	1960	5	10 MHz	2525	881.5	-----	-----	-----	-----	-----	-----	-----	-----	23.69	23.73
4A-4A-5B	B4	20 MHz	20175	1732.5	QPSK	1	49	2175	2132.5	4	20 MHz	2075	2122.5	5	10 MHz	2525	881.5	5	10 MHz	2560	885	-----	-----	-----	-----	-----	-----	-----	-----	23.62	23.73
4A-2A-13A	B4	20 MHz	20175	1732.5	QPSK	1	49	2175	2132.5	2	20 MHz	900	1960	13	10 MHz	5230	751	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	23.66	23.73
5A-4B-4B	B5	10 MHz	20525	836.5	QPSK	1	24	2525	881.5	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	48	20 MHz	56290	3655	-----	-----	-----	-----	23.84	23.95
5B-2A-4A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	4	20 MHz	2175	2132.5	5	10 MHz	2525	881.5	5	10 MHz	2490	878	-----	-----	-----	-----	-----	-----	-----	-----	21.89	22.00
5B-2A-6A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	66	20 MHz	66886	2155	5	10 MHz	2525	881.5	5	10 MHz	2490	878	-----	-----	-----	-----	-----	-----	-----	-----	21.92	22.00
6A-6A-2A-2A-5A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	2	20 MHz	900	1960	2	20 MHz	910	1961	5	10 MHz	2525	881.5	-----	-----	-----	-----	22.94	23.07
6A-6A-5A-5A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	5	10 MHz	2525	881.5	5	10 MHz	2490	878	-----	-----	-----	-----	-----	-----	-----	-----	22.93	23.07
6A-6A-2A-13A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2155	2	20 MHz	900	1960	13	10 MHz	5230	751	-----	-----	-----	-----	-----	-----	-----	-----	22.87	23.07
6B-2A-2A-5A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	5	10 MHz	2525	881.5	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	21.79	22.00
6B-13A-4B	B13	10 MHz	23230	782	QPSK	1	24	5230	751	48	20 MHz	55990	3625	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	23.85	23.98
6B-5B-2A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	5	10 MHz	2525	881.5	5	10 MHz	2560	885	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	21.93	22.00
6B-2A-13A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	13	10 MHz	5230	751	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	21.83	22.00
6C-2A-2A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	21.88	22.00
6C-2A-2A-5A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	5	10 MHz	2525	881.5	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	21.87	22.00
6C-5A-5A	B5	10 MHz	20525	836.5	QPSK	1	24	2525	881.5	5	10 MHz	2560	885	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	23.82	23.95
6C-5B-2A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	5	10 MHz	2525	881.5	5	10 MHz	2560	885	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	21.95	22.00
6C-2A-13A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	13	10 MHz	5230	751	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	21.94	22.00
6C-13A-4B	B13	10 MHz	23230	782	QPSK	1	24	5230	751	48	20 MHz	55990	3625	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	23.86	23.98
6C-6A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	66	20 MHz	66986	2165	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	22.95	23.07
2A-5A-4B-4B	B2	20 MHz	19100	1900	QPSK	1	24	900	1960	5	10 MHz	2525	881.5	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	-----	-----	-----	-----	21.97	22.00
4B-4A	B4	20 MHz	20175	1732.5	QPSK	1	24	2175	2132.5	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	48	20 MHz	56290	3655	-----	-----	-----	-----	23.66	23.73
4B-5A-4B-6A	B5	10 MHz	20525	836.5	QPSK	1	49	2525	881.5	48	20 MHz	55990	3625	66	20 MHz	66886	2155	48	20 MHz	56090	3635	48	20 MHz	56190	3645	-----	-----	-----	-----	23.84	23.95
4B-4B-13A-6A	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	48	20 MHz	56090	3635	13	10 MHz	5230	751	66	20 MHz	66886	2155	-----	-----	-----	-----	-----	-----	-----	-----	23.24	23.38
4B-4B-6A-2A-13A	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	48	20 MHz	56090	3635	2	20 MHz	900	1960	13	10 MHz	5230	751	66	20 MHz	-----	-----	-----	-----	-----	-----	23.19	23.38
4B-4B-5A-6A	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	48	20 MHz	56090	3635	5	10 MHz	2525	881.5	66	20 MHz	66886	2155	-----	-----	-----	-----	-----	-----	-----	-----	23.15	23.38
4B-4B-6B	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	48	20 MHz	56090	3635	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	23.25	23.38
4B-4B-6C	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	48	20 MHz	56090	3635	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	23.28	23.38
4B-2A-13A-6A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	13	10 MHz	5230	751	66	20 MHz	66886	2155	48	20 MHz	55990	3625	48	20 MHz	56090	3635	-----	-----	-----	-----	21.96	22.00
4B-5A-2A-6A	B5	10 MHz	20525	836.5	QPSK	1	24	2525	881.5	2	20 MHz	900	1960	66	20 MHz	66886	2155	48	20 MHz	55990	3625	48	20 MHz	56090	3635	-----	-----	-----	-----	23.84	23.95
4B-4A	B4	20 MHz	20175	1732.5	QPSK	1	49	2175	2132.5	48	20 MHz	55990	3625	48	20 MHz	56090	3635	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	23.66	23.73
4B-13A-6B	B13	10 MHz	23230	782	QPSK	1	24	5230	751	66	10 MHz	66886	2155	66	10 MHz	66786	2145	48	20 MHz	55990	3625	48	20 MHz	56090	3635	-----	-----	-----	-----	23.87	23.98
4B-4B-6C-6A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	48	20 MHz	55990	3625	48	20 MHz	56090	3635	48	20 MHz	56190	3645	48	20 MHz	56190	3645	-----	-----	-----	-----	22.96	23.07
4B-6B	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	48	20 MHz	56090	3635	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	23.22	23.38
4B-6C-13A	B13	10 MHz	23230	782	QPSK	1	24	5230	751	48	20 MHz	55990	3625	48	20 MHz	56090	3635	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	23.91	23.98
4B-4B-2A	B48	20 MHz	55990	3625	QPSK	1	49	55990	3625	2	20 MHz	900	1960	48	20 MHz	56090	3635	48	20 MHz	56190											

Combination	PC									SC1				SC2				SC3				SCC4				Power with DL MIMO	Power without DL MIMO
	Band	BW	Ch.	Freq.	Mod.	RB #	Offset	DL Ch.	DL Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.	Band	BW	Ch.	Freq.		
2A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	21.92	22.00
2A-2A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	2	20 MHz	920	1962	-----	-----	-----	-----	-----	-----	-----	-----	21.84	22.00
2A-2A-4A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	2	20 MHz	920	1962	4	20 MHz	2175	2132.5	-----	-----	-----	-----	21.88	22.00
2A-4A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	4	20 MHz	2175	2132.5	-----	-----	-----	-----	-----	-----	-----	-----	21.93	22.00
2A-4A-4A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	4	20 MHz	2175	2132.5	4	20 MHz	2075	2122.5	-----	-----	-----	-----	21.98	22.00
2A-66A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	66	20 MHz	66886	2155	-----	-----	-----	-----	-----	-----	-----	-----	21.84	22.00
2A-2A-66A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	2	20 MHz	920	1962	66	20 MHz	66886	2155	-----	-----	-----	-----	21.82	22.00
2A-66A-66A	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	66	20 MHz	66886	2155	-----	-----	-----	-----	-----	-----	-----	-----	21.81	22.00
2A-66B	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	66	10 MHz	66886	2155	66	10 MHz	66786	2145	-----	-----	-----	-----	21.93	22.00
2A-2A-66B	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	2	20 MHz	920	1962	66	10 MHz	66886	2155	66	10 MHz	66786	2145	21.96	22.00
2A-66C	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	66	20 MHz	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	21.90	22.00
2A-2A-66C	B2	20 MHz	19100	1900	QPSK	1	49	900	1960	2	20 MHz	910	1961	2	20 MHz	920	1962	66	20 MHz	66886	2155	66	20 MHz	66786	2145	21.89	22.00
4A	B4	20 MHz	20175	1732.5	QPSK	1	24	2175	2132.5	4	20 MHz	2075	2122.5	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	23.66	23.73
4A-4A	B4	20 MHz	20175	1732.5	QPSK	1	24	2175	2132.5	4	20 MHz	2075	2122.5	4	20 MHz	2275	2142.5	-----	-----	-----	-----	-----	-----	-----	-----	23.72	23.73
66A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	23.06	23.07
66A-66A	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	66	20 MHz	66986	2165	-----	-----	-----	-----	-----	-----	-----	-----	22.92	23.07
66A-66C	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	66	20 MHz	66986	2165	66	20 MHz	66836	2150	-----	-----	-----	-----	22.97	23.07
66B	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	10 MHz	66786	2145	66	10 MHz	66986	2165	-----	-----	-----	-----	-----	-----	-----	-----	23.02	23.07
66C	B66	20 MHz	132322	1745	QPSK	1	49	66886	2155	66	20 MHz	66786	2145	66	20 MHz	66986	2165	-----	-----	-----	-----	-----	-----	-----	-----	22.99	23.07