

# **MEASUREMENT/TECHNICAL REPORT**

**Company: Philips Medical Systems  
Model: M3813A  
FCC ID: PQCM3813A2  
January 21, 2002**

Description: This is a report to support a request for a Class II permissive change.

Equipment Type: Low Power Communications Device Transmitter (DXX)

Report prepared for: Philips Medical Systems  
3500 Deer Creek Road  
Palo Alto, CA 94304  
Phone: (650) 857-8720  
Fax: (650) 236-9981

Report prepared by: Evan D. Gould  
Curtis-Straus LLC  
527 Great Road  
Littleton, MA 01460 USA  
Phone: 978-486-8880  
FAX: 978-486-8828

## Introduction

The purpose of this report is to demonstrate the continued compliance of a Transmitter operating pursuant to 47 CFR 15.249 following a change in the EUT's configuration. The configuration tested originally was just the transmitter in its plastic chassis sitting on a turntable. The configuration covered by this report has the EUT mounted on a base (scale). There have been no changes made to the circuitry of the device. The reason that a Class II permissive change is required is the increased amplitude of certain emissions due to the changed configuration. An additional configuration was also tested and is covered in report EC0041-1. The model number covered by this report is M3813A. The setup photo appears below.



Setup Photo

### Test Methodology

Radiated emission testing was performed according to the procedures in ANSI C63.4 (1992). The testing was performed at an antenna to EUT distance of 3 meters below 1 GHz, and at a distance of 3 or 1 meter(s) above 1 GHz. The actual test distance used is noted in the test data sheets. The device's performance was investigated to 10GHz. The EUT was powered by four Duracell PC1500 PROCELL 1.5Volt AA batteries. Fresh batteries were used for all testing. The circuit board was hardwired so as to produce a continuous transmission signal as opposed to the momentary transmission that occurs during regular operation. Since the device is floor standing, the emissions were maximized around the vertical axis and the maximum reading was recorded. The integrated antenna cannot be maximized separately.

### **Test Facility**

#### *Curtis-Straus LLC*

All testing for the range 30–10,000MHz was performed at Curtis-Straus (A2LA Certificate Number 1627-01). The open area test site used to collect the radiated data is located at 527 Great Road, Littleton, MA 01460. Site "F" was used.

**Test Equipment Used**

<b>SPECTRUM ANALYZERS</b>					
<b>x</b>	<b>Analyzer</b>	<b>Model No.</b>	<b>Company</b>	<b>Serial No.</b>	<b>Calibration Due</b>
	<b>GREEN</b> 9kHz-26.5GHz	8593E	HP	3829A03618	04-OCT-2002

<b>OPEN AREA TEST SITES (OATS)</b>					
<b>x</b>	<b>Site</b>	<b>FCC Code</b>	<b>IC Code</b>	<b>VCCI Code</b>	<b>Calibration Due</b>
	<b>“F”</b> Florida	93448	IC 2762-F	R-468/ C-480	23-JUN-2002

<b>ANTENNAS</b>					
<b>x</b>	<b>Antenna</b>	<b>Model No.</b>	<b>Company</b>	<b>Serial No.</b>	<b>Calibration Due</b>
	<b>GREEN-WHITE</b> Bilog: 30MHz-2GHz	CBL6112B	Chase	2574	28-JUN-2002
	<b>ORANGE</b> Horn: 1-18GHz	3115	EMCO	0004-6123	27-MAY-2002

<b>PREAMPLIFIERS</b>					
<b>x</b>	<b>Preamplifier</b>	<b>Model No.</b>	<b>Company</b>	<b>Serial No.</b>	<b>Calibration Due</b>
	<b>BLUE-BLACK</b> 0.01-2000MHz	ZFL-1000-LN	MiniCircuits/ C-S	n/a	24-SEP-2002
	<b>ORANGE-BLACK</b> 1-20GHz	SMC-12A	MITEQ	690639	06-AUG-2002

Unless otherwise noted the calibration interval is one year. All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.

## Measurement Results

### Operating Frequency

This device operates at 916.5MHz.

### Electric Field Strength Radiation Measurements

Radiated Emissions Table							Curtis-Straus LLC						
Date: 18-Jan-02			Company: Philips Medical Systems				Table 1						
Engineer: Evan Gould			EUT Desc: M3813A				Work Order: C0041						
Frequency Range: 30MHz-1GHz							Measurement Distance: 1 m						
Notes: EUT mounted on base. Fundamental and second through tenth harmonics. 916.5MHz and 1833.1MHz were taken at 3m.							EUT Max Freq: 916.5MHz						
							Analyzer: Green						
Antenna Polarization (H / V)	Frequency (MHz)	Reading (dB $\mu$ V)	Preamp Factor (dB)	Antenna Factor (dB/m)	Cable Factor (dB)	Adjusted Reading (dB $\mu$ V/m)	FCC Class B						
							Limit (dB $\mu$ V/m)	Margin (dB)	Result (Pass/Fail)				
H	916.5	86.3	22.4	20.7	4.1	88.7	94.0	-5.3	Pass				
H	1833.1	33.5	16.8	26.5	6.5	49.7	54.0	-4.3	Pass				
H	2749.7	36.7	24.4	28.8	2.5	43.6	63.5	-19.9	Pass				
H	3666.2	30.2	24.2	31.8	3.3	41.1	63.5	-22.4	Pass				
H	4582.8	29.0	24.3	32.3	3.7	40.7	63.5	-22.8	Pass				
H	5499.3	28.9	24.0	34.4	3.8	43.1	63.5	-20.4	Pass				
H	6415.8	28.7	23.1	34.2	3.9	43.7	63.5	-19.8	Pass				
H	7332.4	33.8	22.2	36.8	4.0	52.4	63.5	-11.1	Pass				
H	8249.5	34.3	21.2	37.3	4.1	54.5	63.5	-9.0	Pass				
H	9166.1	33.7	20.6	37.9	4.3	55.3	63.5	-8.2	Pass				
<b>Table Result:</b> Pass			by		-4.3 dB	<b>Worst Freq:</b> 1833.1 MHz							
Test Site: "F"			Pre-Amp: Blue-Blk, Or-Blk		Cable: 3m Microflex, 65 ft RG8A/U		Antenna: Grn-Wht, Orange Horn						

Radiated Emissions Table							Curtis-Straus LLC						
Date: 18-Jan-02			Company: Philips Medical Systems				Table 2						
Engineer: Evan Gould			EUT Desc: M3813A				Work Order: C0041						
Frequency Range: 30MHz-10GHz							Measurement Distance: 3 m						
Notes: EUT mounted on base. spurious emissions							EUT Max Freq: 916.5MHz						
							Analyzer: Green						
Antenna Polarization (H / V)	Frequency (MHz)	Reading (dB $\mu$ V)	Preamp Factor (dB)	Antenna Factor (dB/m)	Cable Factor (dB)	Adjusted Reading (dB $\mu$ V/m)	FCC Class B						
							Limit (dB $\mu$ V/m)	Margin (dB)	Result (Pass/Fail)				
H	817.1	36.7	22.5	20.1	3.9	38.2	46.0	-7.8	Pass				
H	971.8	25.2	22.3	21.1	4.3	28.3	54.0	-25.7	Pass				
H	983.8	23.3	22.3	21.2	4.3	26.5	54.0	-27.5	Pass				
H	1016.0	35.6	22.1	21.4	4.4	39.3	54.0	-14.7	Pass				
H	1375.0	30.7	20.4	24.2	5.5	40.0	54.0	-14.0	Pass				
H	2291.4	38.5	24.5	27.4	2.2	43.6	63.5	-19.9	Pass				
<b>Table Result:</b> Pass			by		-7.8 dB	<b>Worst Freq:</b> 817.1 MHz							
Test Site: "F"			Pre-Amp: Blue-Blk, Or-Blk		Cable: 3m Microflex, 65 ft RG8A/U		Antenna: Grn-Wht, Orange Horn						

## Emissions Plots

## Fundamental

