

## System Check\_Body\_750MHz\_121210

**DUT: D750V3-SN:1012**

Communication System: CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: MSL\_750\_121210 Medium parameters used:  $f = 750$  MHz;  $\sigma = 0.961$  mho/m;  $\epsilon_r = 53.917$ ;  $\rho =$

$1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.5 °C ; Liquid Temperature : 21.5 °C

DASY5 Configuration:

- Probe: ET3DV6 - SN1787; ConvF(6.2, 6.2, 6.2); Calibrated: 2012/5/29;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn495; Calibrated: 2012/4/23
- Phantom: SAM Right; Type: QD000P40CD; Serial: TP:1644
- Measurement SW: DASY52, Version 52.8 (3); SEMCAD X Version 14.6.5 (6469)

**Configuration/Pin=250mW/Area Scan (61x61x1):** Measurement grid: dx=15mm, dy=15mm  
Maximum value of SAR (interpolated) = 2.38 mW/g


**Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 51.242 V/m; Power Drift = -0.02 dB

Peak SAR (extrapolated) = 3.145 mW/g

**SAR(1 g) = 2.21 mW/g; SAR(10 g) = 1.49 mW/g**

Maximum value of SAR (measured) = 2.38 mW/g



0 dB = 2.38 mW/g = 7.53 dB mW/g

## System Check\_Body\_835MHz\_121209

**DUT: D835V2-SN:499**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: MSL\_850\_121209 Medium parameters used:  $f = 835$  MHz;  $\sigma = 0.997$  mho/m;  $\epsilon_r = 55.12$ ;  $\rho =$

$1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.7 °C; Liquid Temperature : 21.7 °C

DASY5 Configuration:

- Probe: ES3DV3 - SN3270; ConvF(6.16, 6.16, 6.16); Calibrated: 2012/9/28;
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn778; Calibrated: 2012/8/27
- Phantom: SAM-Left; Type: QD 000 P40 C; Serial: TP-1477
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.6 (6477)

**Configuration/Pin=250mW/Area Scan (61x61x1):** Measurement grid: dx=15mm, dy=15mm  
Maximum value of SAR (interpolated) = 3.08 mW/g


**Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 57.250 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 3.864 mW/g

**SAR(1 g) = 2.63 mW/g; SAR(10 g) = 1.73 mW/g**

Maximum value of SAR (measured) = 3.04 mW/g



0 dB = 3.04 mW/g = 9.66 dB mW/g

## System Check\_Body\_1750MHz\_121209

**DUT: D1750V2-SN:1068**

Communication System: CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: MSL\_1750\_121209 Medium parameters used:  $f = 1750$  MHz;  $\sigma = 1.501$  mho/m;  $\epsilon_r = 51.984$ ;  $\rho$

$= 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.6 °C ; Liquid Temperature : 21.6 °C

DASY5 Configuration:

- Probe: ES3DV3 - SN3270; ConvF(4.98, 4.98, 4.98); Calibrated: 2012/9/28;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn778; Calibrated: 2012/8/27
- Phantom: SAM-Right; Type: QD 000 P40 C; Serial: TP-1383
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.6 (6477)

**Configuration/Pin=250mW/Area Scan (61x61x1):** Measurement grid: dx=15mm, dy=15mm  
 Maximum value of SAR (interpolated) = 10.5 mW/g



**Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 80.521 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 15.522 mW/g

**SAR(1 g) = 8.64 mW/g; SAR(10 g) = 4.54 mW/g**

Maximum value of SAR (measured) = 9.77 mW/g



0 dB = 9.77 mW/g = 19.80 dB mW/g

## System Check\_Body\_1750MHz\_121209

### DUT: D1750V2-SN:1068

Communication System: CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: MSL\_1750\_121209 Medium parameters used:  $f = 1750$  MHz;  $\sigma = 1.489$  mho/m;  $\epsilon_r = 53.474$ ;  $\rho$

$= 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.4 °C ; Liquid Temperature : 21.4 °C

DASY5 Configuration:

- Probe: ET3DV6 - SN1787; ConvF(4.81, 4.81, 4.81); Calibrated: 2012/5/29;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn495; Calibrated: 2012/4/23
- Phantom: SAM Right; Type: QD000P40CD; Serial: TP:1644
- Measurement SW: DASY52, Version 52.8 (3); SEMCAD X Version 14.6.5 (6469)

**Configuration/Pin=250mW/Area Scan (61x61x1):** Measurement grid: dx=15mm, dy=15mm  
Maximum value of SAR (interpolated) = 10.7 mW/g


**Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 86.604 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 13.770 mW/g

**SAR(1 g) = 8.78 mW/g; SAR(10 g) = 4.79 mW/g**

Maximum value of SAR (measured) = 10.1 mW/g



0 dB = 10.1 mW/g = 20.09 dB mW/g

## System Check\_Body\_1900MHz\_121208

### DUT: D1900V2-SN:5d041

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL\_1900\_121208 Medium parameters used:  $f = 1900$  MHz;  $\sigma = 1.514$  mho/m;  $\epsilon_r = 54.141$ ;  $\rho$

$= 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.7 °C ; Liquid Temperature : 21.7 °C

#### DASY5 Configuration:

- Probe: ES3DV3 - SN3270; ConvF(4.67, 4.67, 4.67); Calibrated: 2012/9/28;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn778; Calibrated: 2012/8/27
- Phantom: SAM-Right; Type: QD 000 P40 C; Serial: TP-1383
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.6 (6477)

**Configuration/Pin=250mW/Area Scan (91x91x1):** Measurement grid: dx=10mm, dy=10mm  
 Maximum value of SAR (interpolated) = 11.0 mW/g



**Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 85.864 V/m; Power Drift = -0.01 dB

Peak SAR (extrapolated) = 18.127 mW/g

**SAR(1 g) = 9.66 mW/g; SAR(10 g) = 4.96 mW/g**

Maximum value of SAR (measured) = 10.9 mW/g



0 dB = 10.9 mW/g = 20.75 dB mW/g

## System Check\_Body\_1900MHz\_121209

### DUT: D1900V2-SN:5d041

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL\_1900\_121209 Medium parameters used:  $f = 1900$  MHz;  $\sigma = 1.539$  mho/m;  $\epsilon_r = 54.55$ ;  $\rho =$

$1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.6 °C ; Liquid Temperature : 21.6 °C

DASY5 Configuration:

- Probe: ET3DV6 - SN1787; ConvF(4.58, 4.58, 4.58); Calibrated: 2012/5/29;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn495; Calibrated: 2012/4/23
- Phantom: SAM Right; Type: QD000P40CD; Serial: TP:1644
- Measurement SW: DASY52, Version 52.8 (3); SEMCAD X Version 14.6.5 (6469)

**Configuration/Pin=250mW/Area Scan (61x61x1):** Measurement grid: dx=15mm, dy=15mm  
Maximum value of SAR (interpolated) = 11.4 mW/g


**Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 88.644 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 15.299 mW/g

**SAR(1 g) = 9.6 mW/g; SAR(10 g) = 5.16 mW/g**

Maximum value of SAR (measured) = 11.0 mW/g



0 dB = 11.0 mW/g = 20.83 dB mW/g

## System Check\_Body\_2450MHz\_121210

### DUT: D2450V2-SN:736

Communication System: CW; Frequency: 2450 MHz; Duty Cycle: 1:1

Medium: MSL\_2450\_121210 Medium parameters used:  $f = 2450$  MHz;  $\sigma = 2.015$  mho/m;  $\epsilon_r = 53.957$ ;  $\rho$

$= 1000$  kg/m<sup>3</sup>

Ambient Temperature : 22.5 °C ; Liquid Temperature : 21.5 °C

#### DASY5 Configuration:

- Probe: EX3DV4 - SN3697; ConvF(6.57, 6.57, 6.57); Calibrated: 2012/9/28;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1279; Calibrated: 2012/5/3
- Phantom: SAM LEFT; Type: QD000P40CD; Serial: TP:1718
- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.5 (6469)

**Configuration/Pin=250mW/Area Scan (61x61x1):** Measurement grid: dx=12mm, dy=12mm  
Maximum value of SAR (interpolated) = 21.6 mW/g



**Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 98.943 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 28.201 mW/g

**SAR(1 g) = 12.9 mW/g; SAR(10 g) = 5.97 mW/g**

Maximum value of SAR (measured) = 19.9 mW/g



0 dB = 19.9 mW/g = 25.98 dB mW/g