

HAC_E_Dipole_835_130815

DUT: HAC Dipole 835 MHz

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.2 °C

DASY5 Configuration:

- Probe: ER3DV6 - SN2476; ConvF(1, 1, 1); Calibrated: 2012-12-12
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1210; Calibrated: 2013-6-19
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (5); SEMCAD X Version 14.4.5 (3634)

E Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 176.6 V/m

Probe Modulation Factor = 1.000

Reference Value = 108.0 V/m; Power Drift = 0.0042 dB

Average value of Total=(151.9+176.6)/2=164.25 V/m

Peak E-field in V/m



| | | |
|----------------------------|----------------------------|----------------------------|
| Grid 1 148.8 M4 | Grid 2 151.9 M4 | Grid 3 148.2 M4 |
| Grid 4 85.064 M4 | Grid 5 86.667 M4 | Grid 6 83.678 M4 |
| Grid 7 171.7 M4 | Grid 8 176.6 M4 | Grid 9 169.8 M4 |

Cursor:

Total = 176.6 V/m

E Category: M4

Location: 0, 82.5, 4.7 mm



0 dB = 176.6V/m

HAC_E_Dipole_1880_130815

DUT: HAC Dipole 1880 MHz

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.2 °C

DASY5 Configuration:

- Probe: ER3DV6 - SN2476; ConvF(1, 1, 1); Calibrated: 2012-12-12
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1210; Calibrated: 2013-6-19
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (5); SEMCAD X Version 14.4.5 (3634)

E Scan - measurement distance from the probe sensor center to CD1880 Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 150.1 V/m

Probe Modulation Factor = 1.000

Reference Value = 170.8 V/m; Power Drift = -0.004 dB

Average value of Total=(129.9+150.1)=140 V/m

Peak E-field in V/m



| | | |
|----------------------------|----------------------------|----------------------------|
| Grid 1 126.3 M2 | Grid 2 129.9 M2 | Grid 3 127.3 M2 |
| Grid 4 90.961 M3 | Grid 5 92.398 M3 | Grid 6 88.897 M3 |
| Grid 7 144.6 M2 | Grid 8 150.1 M2 | Grid 9 144.5 M2 |

Cursor:

Total = 150.1 V/m

E Category: M2

Location: 0, 38.5, 4.7 mm



0 dB = 150.1V/m

HAC_H_Dipole_835_130815

DUT: HAC Dipole 835 MHz

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.2 °C

DASY5 Configuration:

- Probe: H3DV6 - SN6300; ; Calibrated: 2012-12-12
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1210; Calibrated: 2013-6-19
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (5); SEMCAD X Version 14.4.5 (3634)

H Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1): Measurement grid: dx=5mm, dy=5mm
 Probe Modulation Factor = 1.000
 Reference Value = 0.479 A/m; Power Drift = -0.0042 dB
 Maximum value of peak Total field = 0.454 A/m

Peak H-field in A/m


| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.382 M4 | Grid 2 0.394 M4 | Grid 3 0.374 M4 |
| Grid 4 0.438 M4 | Grid 5 0.454 M4 | Grid 6 0.430 M4 |
| Grid 7 0.396 M4 | Grid 8 0.411 M4 | Grid 9 0.389 M4 |

Cursor:

Total = 0.454 A/m

H Category: M4

Location: 0.5, 4, 4.7 mm



0 dB = 0.450A/m

HAC_H_Dipole_1880_130815

DUT: HAC Dipole 1880 MHz

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 0$ kg/m³

Ambient Temperature : 23.2 °C

DASY5 Configuration:

- Probe: H3DV6 - SN6300; ; Calibrated: 2012-12-12
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1210; Calibrated: 2013-6-19
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (5); SEMCAD X Version 14.4.5 (3634)

H Scan - measurement distance from the probe sensor center to CD835 Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm
 Probe Modulation Factor = 1.000
 Reference Value = 0.490 A/m; Power Drift = -0.01 dB
 Maximum value of peak Total field = 0.465 A/m

Peak H-field in A/m



| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.404 M2 | Grid 2 0.415 M2 | Grid 3 0.394 M2 |
| Grid 4 0.452 M2 | Grid 5 0.465 M2 | Grid 6 0.441 M2 |
| Grid 7 0.421 M2 | Grid 8 0.436 M2 | Grid 9 0.411 M2 |

Cursor:

Total = 0.465 A/m

H Category: M2

Location: 0.5, 3.5, 4.7 mm



0 dB = 0.470A/m