

PRELIMINARY

REVISIONS							
ZONE	REV	ECO	DESCRIPTION	BY	DATE	CK'D	DATE
	01	XX-XXXX	RELEASE TO PRODUCTION	SP	03/27/2012	-	-



6 62698 60361 3

Model: 263B-CO-OEM
FCC ID: QPY-263XCO-Z

For servicing, return to:
UTC – Climate,
Controls & Security
325 N Main St,
Pittsfield, ME 04967

The device complies with part 15 of the FCC Rules as well as Industry Canada Rules and Regulations license-exempt RSS standard(s). Operation is subject to the following two conditions:
(1) This device may not cause harmful interference, and
(2) this device must accept any interference received, including interference that may cause undesired operation.

WARNING USE ONLY BATTERIES SPECIFIED. USE OF A DIFFERENT BATTERY MAY HAVE DETRIMENTAL EFFECT ON ALARM OPERATION.

To replace batteries: Remove batteries and replace with 3 fresh AA batteries. Use only Duracell MN 1500 or MX 1500 or E91 Energizer from local hardware store.



Date of Mfg:

Alarm response time: 400
PPM within 4-15 minutes



Single Station
Carbon Monoxide
Alarm conforms to
UL 2034 Std.

21009057 Rev EN01



6 62698 60361 3

Model: 263B-CO-OEM
FCC ID: QPY-263XCO-Z

For servicing, return to:
UTC – Climate,
Controls & Security
325 N Main St,
Pittsfield, ME 04967


The device complies with part 15 of the FCC Rules as well as Industry Canada Rules and Regulations license-exempt RSS standard(s). Operation is subject to the following two conditions:
(1) This device may not cause harmful interference, and
(2) this device must accept any interference received, including interference that may cause undesired operation.

WARNING USE ONLY BATTERIES SPECIFIED. USE OF A DIFFERENT BATTERY MAY HAVE DETRIMENTAL EFFECT ON ALARM OPERATION.

To replace batteries: Remove batteries and replace with 3 fresh AA batteries. Use only Duracell MN 1500 or MX 1500 or E91 Energizer from local hardware store.

Date of Mfg:

Alarm response time: 400
PPM within 4-15 minutes



Single Station
Carbon Monoxide
Alarm conforms to
UL 2034 Std.

21009057 Rev EN01

Shown for Reference
Scale 2:1

Notes:

1. All text on the label must be in "helvetica neueltstd-bd" font, per artwork provided.

<div>COPYRIGHT: CONFIDENTIAL</div> <div>COPYRIGHT © 2012 UTC FIRE & SECURITY, ALL RIGHTS RESERVED. UNAUTHORIZED ACCESS TO, COPYING, USE OF OR DISCLOSURE OF THIS ARTIFACT, OR ANY OF ITS FEATURES, IS STRICTLY PROHIBITED. YOUR ACCESS TO OR POSSESSION OF A COPY OF THIS ARTIFACT IS PURSUANT TO A LIMITED LICENSE; OWNERSHIP OF THE ARTIFACT AND ANY ASSOCIATED MEDIA REMAIN WITH UTC FIRE & SECURITY</div>			<div>UNLESS OTHERWISE SPECIFIED: MATERIAL TO BE COMPLIANT WITH RoHS DIRECTIVE 2002/95/EC DIMENSIONS ARE IN INCHES CAPACITANCE IS IN uF RESISTANCE IS IN OHMS TOLERANCES: .X = ±.03 .XX = ±.01 .XXX = ±.005 ANGLES = ±0.5° -- DO NOT SCALE DRAWING--</div>	THIRD ANGLE PROJECTION		<div>EDWARDS, A UTC FIRE & SECURITY COMPANY</div> <div>8985 TOWN CENTER PARKWAY BRADENTON, FL 34202-5129 (941) 739-4200</div>				
				DRAWN BY	SP	DATE	03/27/2012			
				CHECKER	-	DATE	-			
				MATERIAL	APPROVED	DATE	SIZE	CAGE CODE	DWG NO.	REV
	NEXT ASSY	USED ON			-	-	B	4SPQ6	21009057	EN01
	APPLICATION			TREATMENT OR FINISH	APPROVED	DATE	SCALE	FILE NAME	SHEET	
				-			1:1	21009057EN01.dft	1 OF 1	