

Carbon Monoxide Detector
Rating @ 4.5 Vdc

MODEL:

263A-CO-OEM-ATT01

FCC ID: QPY-CO915FFH

IC ID: 8303B-CO915FFH

This device complies with FCC rules Part 15. Operation is subject to the following two conditions: (1) This device may not cause harmful interference and (2) This device must accept any interference that may be received including interference that may cause undesired operation.

**⚠ WARNING! UNIT IS
NON-OPERATIONAL WITH
ANY BATTERY REMOVED.**

USE ONLY BATTERIES SPECIFIED IN MARKING.

USE OF A DIFFERENT BATTERY MAY HAVE A
DETRIMENTAL EFFECT ON PRODUCT OPERATION.

To replace batteries: Remove batteries and replace with 3 fresh AA batteries. Use only Duracell MN 1500 or Energizer E91. Replacement batteries are available where you purchased this alarm.

Refer to User Guide 2533-7222-00

Date of Mfg: YYYY,MM,DD

ISSUE NO. xxxxxxx

Alarm response time:

400 PPM within 4-15 minutes 2533-7193-01



SIGNALING



LISTED

E352828

GAS DETECTOR
conforms to the
sensitivity level of
UL 2034 Std.

Size:37x48mm

- 1.the UL logo should be print on that was printing in FHK inside.
- 2.the date code(YYYY, MMM, DD) should be printing in FHK inside.