

Hi Mark,

Attached, please find the revised "Installation Guide" for the ProSoft 6000-WA product. Rev. 1.02 provides the information required by Randy under the "Important Installation Instructions" section. Please note to Randy that paragraph G of the "Important Installation Instructions" cannot be placed on a label on the outside of the 6000-WA enclosure because there is physically no room for such a label. Also, please note to Randy that the SMA type antenna connectors used on our radio module are reverse polarity. These are non-standard SMA connectors and prevent any persons that are not authorized industrial radio system integrators from connecting equipment to our device.

Regards,

Ben Mathison
ProSoft Technology, Inc.
(661) 716-5217