

Date: 2025-01-15

**System Check\_Head\_13MHz****DUT: CLA13 - SN:1020**

Communication System: ; Frequency: 13.000

Medium: HSL. Medium parameters used:  $f=13.000$  MHz;  $\sigma=0.757$  S/m;  $\epsilon_r=53.7$ 

Ambient Temperature: 23.2°C; Liquid Temperature: 22.6°C

**DASY6 Configuration:**

- Probe: EX3DV4 - SN7706; ConvF(16.1, 16.1, 16.1); Calibrated: 2024-01-24
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1649; Calibrated: 2024-07-03
- Phantom: ELI V8.0 (20deg probe tilt); Serial: 2135
- Measurement Software: 16.4.0.5005

**Area Scan (40.0 mm x 90.0 mm):** Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.130 W/kg; SAR (10g) = 0.089 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm;

Graded Ratio:1.4

Power Drift = 0.05 dB

SAR (1g) = 0.143 W/kg; SAR (10g) = 0.090 W/kg;

Smallest distance from peaks to all points 3dB below is 15.7 mm

Ratio of SAR at M2 to SAR at M1 = 73.9 %

