


<p>MODEL: CONNECT-FLX</p> <p>WEEKLY TESTING IS REQUIRED TO ENSURE PROPER OPERATION OF THE SYSTEM. DO NOT CONNECT TO A RECEPTACLE CONTROLLED BY A SWITCH. NA PAS SE CONNECTER A UNE PRISE CONTRÔLÉE PAR UN INTERRUPTEUR.</p> <p>THIS UNIT IS TO BE CHECKED BY A QUALIFIED TECHNICIAN AT LEAST ONCE EVERY THREE YEARS. RECHARGEABLE BATTERY PACK TO BE REPLACED EVERY 6 YEARS UNDER NORMAL OPERATING CONDITIONS.</p> <p>REPLACEMENT RECHARGEABLE BATTERY: BUDC-2.3AH 19MM PART#: RED09</p> <p>POWER SUPPLY: 12VDC, 1A INPUT: 100-240VAC, 50/60 Hz PART#: RED12-06W</p> <p>Transmission Method: Packet Switched Data Networks (PSDN)</p> <p>Alula, 428 Minnesota Street, Suite 300, St. Paul, MN 55101</p> <p>MADE IN BULGARIA 48-10287-00 RevA</p>	<p>This equipment should be installed in accordance with Chapter 29 of the National Fire Alarm and Signaling Code, ANSI/NFPA 72, (National Fire Protection Association, Batterymarch Park, Quincy, MA 02269)</p> <p>PRINTED INFORMATION DESCRIBING PROPER INSTALLATION, OPERATION, TESTING, MAINTENANCE, EVACUATION PLANNING, AND REPAIR SERVICE IS TO BE PROVIDED WITH THIS EQUIPMENT. SEE USER'S GUIDE FOR COMPLETE OPERATION: 47-00041-00 RevA</p> <p>RESIDENTIAL FIRE AND SECURITY EQUIPMENT COMMERCIAL SECURITY EQUIPMENT CONFORMS TO UL STD 985 & 1023 & 2610 CERTIFIED TO ULC SUBJECT S545 & S304</p> <p>FCC ID: USX-CFLXRF; IC: 8310A-CFLXRF FCC ID: USX-CFLXZ; IC: 8310A-CFLXZ Contains FCC ID: R7ME310G1WW Contains IC: 5131A-ME310G1WW Contains FCC ID: 2AC72-ESP32WROOM32E Contains IC: 21098-ESPWROOM32E</p> <div> ETL 9013065</div>
--	--