



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0

Exhibit 12C: HAC RF Data Plots

PCS

Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0

CDMA 1900 Channel 25

Date: 05/02/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 1850 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 9/14/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 $\square\square\square$ 1 deg C, Liquid T = 22.0 $\square\square\square$ 1 deg C

PCS_25/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 42.2 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 53.2 V/m; Power Drift = -0.061 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
35.6 M4	42.2 M4	41.3 M4
Grid 4	Grid 5	Grid 6
35.5 M4	42.1 M4	41.3 M4
Grid 7	Grid 8	Grid 9
33.3 M4	36.6 M4	36.5 M4

PCS_25/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.111 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.103 A/m; Power Drift = -0.184 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.074 M4	0.077 M4	0.072 M4
Grid 4	Grid 5	Grid 6
0.101 M4	0.111 M4	0.108 M4
Grid 7	Grid 8	Grid 9
0.128 M4	0.137 M4	0.130 M4



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0

CDMA 1900 Channel 600

Date: 05/02/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 1880 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 9/14/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 $\square\square\square$ 1 deg C, Liquid T = 22.0 $\square\square\square$ 1 deg C

PCS_600/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 32.9 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 44.2 V/m; Power Drift = -0.039 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
26.9 M4	32.2 M4	31.8 M4
31.6 M4	32.9 M4	32.3 M4
32.8 M4	32.3 M4	30.3 M4

PCS_600/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.108 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.116 A/m; Power Drift = 0.072 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.082 M4	0.095 M4	0.092 M4
0.096 M4	0.108 M4	0.106 M4
0.124 M4	0.120 M4	0.116 M4



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0

CDMA 1900 Channel 1175

Date: 05/02/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 1910 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 9/14/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 $\square\square\square$ 1 deg C, Liquid T = 22.0 $\square\square\square$ 1 deg C

PCS_1175/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 32.8 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 36.8 V/m; Power Drift = 0.173 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
28.9 M4	30.5 M4	30.8 M4
Grid 4	Grid 5	Grid 6
32.5 M4	32.7 M4	33.1 M4
Grid 7	Grid 8	Grid 9
32.8 M4	32.1 M4	32.4 M4

PCS_1175/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.106 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.111 A/m; Power Drift = 0.116 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.084 M4	0.096 M4	0.092 M4
Grid 4	Grid 5	Grid 6
0.095 M4	0.106 M4	0.104 M4
Grid 7	Grid 8	Grid 9
0.122 M4	0.119 M4	0.116 M4



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0



Applicant:	Kyocera
FCC ID:	V65S1360
Report #:	CT- S1360-20RFC-0513-R0

CDMA 1900 Channel 25 (360) E roll
