



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

Exhibit 12C: HAC RF Data Plots

CELL-BC0

Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 835 Channel 1013

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 824.7 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

CELL_1013/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 47.0 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 60.4 V/m; Power Drift = -0.097 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
45.4 M4	46.1 M4	41.6 M4
Grid 4	Grid 5	Grid 6
46.4 M4	47.0 M4	43.0 M4

Grid 7	Grid 8	Grid 9
45.2 M4	46.1 M4	41.6 M4

CELL_1013/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.085 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.045 A/m; Power Drift = -0.014 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.113 M4	0.081 M4	0.051 M4
Grid 4	Grid 5	Grid 6
0.113 M4	0.082 M4	0.054 M4

Grid 7	Grid 8	Grid 9
0.116 M4	0.085 M4	0.056 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 835 Channel 384

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 836.52 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

 Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

CELL_384/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 48.9 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 63.4 V/m; Power Drift = -0.019 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
45.8 M4	47.3 M4	43.9 M4
Grid 4	Grid 5	Grid 6
47.0 M4	48.9 M4	46.1 M4

Grid 7	Grid 8	Grid 9
47.0 M4	48.4 M4	45.3 M4

CELL_384/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.078 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.062 A/m; Power Drift = 0.033 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.112 M4	0.078 M4	0.052 M4
Grid 4	Grid 5	Grid 6
0.107 M4	0.075 M4	0.050 M4

Grid 7	Grid 8	Grid 9
0.111 M4	0.078 M4	0.052 M4

Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0





Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 835 Channel 777

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 848.31 MHz, Duty Cycle: 1:1

Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

CELL_777/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 52.5 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 67.6 V/m; Power Drift = 0.086 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
48.5 M4	50.7 M4	49.2 M4
Grid 4	Grid 5	Grid 6
49.7 M4	52.5 M4	51.9 M4

Grid 7	Grid 8	Grid 9
49.2 M4	51.7 M4	50.6 M4

CELL_777/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.086 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.058 A/m; Power Drift = 0.045 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m


Grid 1	Grid 2	Grid 3
0.096 M4	0.066 M4	0.044 M4
Grid 4	Grid 5	Grid 6
0.105 M4	0.075 M4	0.048 M4

Grid 7	Grid 8	Grid 9
0.119 M4	0.086 M4	0.059 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



CDMA 835 Channel 777 (360) E roll




Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CELL-BC10

Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 835 Channel 476

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 817.9 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

 Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

CELL_476/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 38.1 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 47.8 V/m; Power Drift = -0.178 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
36.0 M4	36.2 M4	31.1 M4
Grid 4	Grid 5	Grid 6
37.9 M4	38.1 M4	32.8 M4

Grid 7	Grid 8	Grid 9
37.9 M4	38.1 M4	32.6 M4

CELL_476/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.062 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.051 A/m; Power Drift = -0.197 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.089 M4	0.058 M4	0.038 M4
Grid 4	Grid 5	Grid 6
0.088 M4	0.061 M4	0.038 M4

Grid 7	Grid 8	Grid 9
0.088 M4	0.062 M4	0.039 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 835 Channel 580

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 820.5 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

 Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

CELL_580/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 41.9 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 55.2 V/m; Power Drift = -0.191 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
40.3 M4	40.8 M4	35.7 M4
Grid 4	Grid 5	Grid 6
41.4 M4	41.9 M4	37.2 M4

Grid 7	Grid 8	Grid 9
40.9 M4	41.1 M4	36.3 M4

CELL_580/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.075 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.061 A/m; Power Drift = 0.034 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.104 M4	0.071 M4	0.047 M4
Grid 4	Grid 5	Grid 6
0.105 M4	0.073 M4	0.050 M4

Grid 7	Grid 8	Grid 9
0.109 M4	0.075 M4	0.051 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 835 Channel 684

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 823.1 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

 Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

CELL_684/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 43.7 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 55.3 V/m; Power Drift = -0.004 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
42.7 M4	43.1 M4	38.1 M4
Grid 4	Grid 5	Grid 6
43.3 M4	43.7 M4	39.0 M4

Grid 7	Grid 8	Grid 9
42.2 M4	42.6 M4	37.5 M4

CELL_684/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.080 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.064 A/m; Power Drift = 0.093 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m


Grid 1	Grid 2	Grid 3
0.107 M4	0.075 M4	0.049 M4
Grid 4	Grid 5	Grid 6
0.108 M4	0.078 M4	0.053 M4

Grid 7	Grid 8	Grid 9
0.110 M4	0.080 M4	0.055 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



CDMA 835 Channel 684 (360) E roll



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

PCS

Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 1900 Channel 25

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 1850 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

 Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

PCS_25/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 36.6 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 46.2 V/m; Power Drift = -0.087 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
26.5 M4	30.6 M4	29.7 M4
Grid 4	Grid 5	Grid 6
30.5 M4	36.6 M4	35.2 M4

Grid 7	Grid 8	Grid 9
30.6 M4	37.1 M4	35.6 M4

PCS_25/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.122 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.085 A/m; Power Drift = -0.027 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.122 M4	0.103 M4	0.071 M4
Grid 4	Grid 5	Grid 6
0.120 M4	0.101 M4	0.070 M4

Grid 7	Grid 8	Grid 9
0.117 M4	0.097 M4	0.063 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 1900 Channel 600

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 1880 MHz, Duty Cycle: 1:1

 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

PCS_600/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 28.9 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 32.0 V/m; Power Drift = -0.106 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
19.3 M4	21.6 M4	21.8 M4
Grid 4	Grid 5	Grid 6
23.8 M4	28.9 M4	28.7 M4

Grid 7	Grid 8	Grid 9
26.0 M4	30.4 M4	30.1 M4

PCS_600/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.081 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.029 A/m; Power Drift = -0.054 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.081 M4	0.081 M4	0.075 M4
Grid 4	Grid 5	Grid 6
0.080 M4	0.079 M4	0.071 M4

Grid 7	Grid 8	Grid 9
0.073 M4	0.066 M4	0.053 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0

CDMA 1900 Channel 1175

Date: 01/22/2013

Communication System: CDMA_Tri_BC0&10, Frequency: 1910 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1000 \text{ kg/m}^3$ Medium parameters used: $\sigma = 0 \text{ mho/m}$, $\epsilon_r = 1$; $\rho = 1 \text{ kg/m}^3$

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 9/14/2012 Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 ± 0.1 deg C, Liquid T = 22.0 ± 0.1 deg C

PCS_1175/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 20.4 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 25.8 V/m; Power Drift = -0.024 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
24.2 M4	23.9 M4	19.6 M4
Grid 4	Grid 5	Grid 6
16.8 M4	20.1 M4	20.0 M4

Grid 7	Grid 8	Grid 9
17.8 M4	20.4 M4	20.2 M4

PCS_1175/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.083 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.029 A/m; Power Drift = 0.033 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)


Peak H-field in A/m

Grid 1	Grid 2	Grid 3
0.104 M4	0.083 M4	0.061 M4
Grid 4	Grid 5	Grid 6
0.098 M4	0.082 M4	0.061 M4

Grid 7	Grid 8	Grid 9
0.083 M4	0.073 M4	0.054 M4



Applicant:	Kyocera
FCC ID:	V65S2151
Report #:	CT- S2151-20RFC-0113-R0



CDMA 1900 Channel 25 (360) E roll
