

## TEST REPORT

Report Number: 3191467MPK-001 Project Number: 3191467 Report Date: December 03, 2009

Testing performed on the
Advanced Control Pedal & Remote Control Master
for the WHITESTAR Signature<sup>TM</sup> system NGP680702
Model: Advanced Control Pedal & Remote Control Master 2.0
FCC ID: VGESIGREMM2
IC: 7228A-SIGREMM2

to

## FCC Part 15.247 and RSS-210 Annex 8 For

#### **Advanced Medical Optics**

Test Authorized by:

Test Performed by:

Intertek	Advanced Medical Optics	
1365 Adams Court	1700 E. Saint Andrew Place	
Menlo Park, CA 94025	Santa Ana, CA 92705 USA	
Prepared by: Krishna K Vemuri	<b>Date:</b> December 03, 2009	
Reviewed by: Ollie Moyrong	<b>Date:</b> December 03, 2009	

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This report must not be used to claim product endorsement by A2LA, NIST nor any other agency of the U.S. Government.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control

Master 2.0

File: 3191467MPK-001 Page 1 of 63



**Equipment Under Test**:

## Report No. 3191467MPK-001

Advanced Control Pedal & Remote Control

	Master for the WHITESTAR Signature <sup>TM</sup> system
	NGP680702
Trade Name:	Advanced Medical Optics
Model No.:	Advanced Control Pedal & Remote Control
	Master 2.0
FCC ID:	VGESIGREMM2
IC:	7228A-SIGREMM2
Applicant:	Advanced Medical Optics
Contact:	Mr. Dung Ma
Address:	1700 E. Saint Andrew Place
	Santa Ana, CA 92705
Country	USA
Tel. Number:	714-247-8579
Fax number:	714-247-8678
Applicable Regulation:	FCC Part 15, Subpart C
	RSS-210 Annex 8
Test Site Location:	ITS – Site 1
	1365 Adams Drive
	Menlo Park, CA 94025
Date of Test:	September 22 to October 22, 2009
We attest to the accuracy of this report:	
(2) shove	oll & X
Krishna K Vemuri	Ollie Moyrong
Test Engineer	Engineering Manager
Lingineer Engineering Wanager	

File: 3191467MPK-001 Page 2 of 63



## TABLE OF CONTENTS

1.0	Intro	oduction	4
	1.1	Summary of Tests	4
2.0	Gene	eral Description	5
	2.1	Product Description	
	2.2	Related Submittal(s) Grants	6
	2.3	Test Methodology	7
	2.4	Test Facility	7
3.0	Syste	em Test Configuration	8
	3.1	Support Equipment	
	3.2	Block Diagram of Test Setup	8
	3.4	Software Exercise Program	9
	3.5	Mode of Operation During Test	9
	3.6	Modifications Required for Compliance	9
4.0	Meas	surement Results	10
	4.1	Conducted Output Power at Antenna Terminals	10
	4.2	Hopping Channel 20-dB Bandwidth	14
	4.3	Carrier Frequency Separation	21
	4.4	Number of Hopping Channels	23
	4.5	Average Channel Occupancy Time	25
	4.6	Out-of Band-Conducted Emissions	28
	4.7	Transmitter Radiated Emissions in Restricted Bands	45
	4.8	Radiated Emissions from Digital Parts and Receiver	54
	4.9	AC Line Conducted Emission	57
5.0	RF E	Exposure evaluation	58
6.0	List	of test equipment	59
7.0	Docu	ıment History	60
8.0	Appe	endix A –Graphs for Duty cycle measurement	61

File: 3191467MPK-001 Page 3 of 63



## 1.0 Introduction

The Equipment under Test (EUT) is a device with one Bluetooth transceivers operating in the 2.4GHz frequency band.

This report is designed to show compliance of the 2.4 GHz transceiver with FCC Part 15.247 and RSS-210 requirements.

## 1.1 Summary of Tests

TEST	REFERENCE FCC 17.247	REFERENCE RSS-210	RESULTS
Output power	15.247(b)	A8.4(2)	Complies
20-dB Bandwidth	15.247(a)(1)	A8.1(a)	Complies
Channel Separation	15.247(a)(1)	A8.1(b)	Complies
Number of Hopping Channels	15.247(a)(1)	A8.1(d)	Complies
Average Channel Occupancy Time	15.47(a)(1)	A8.1(d)	Complies
Out-of-band Antenna Conducted Emission	15.247(c)	A8.5	Complies
Out-of-Band Radiated Emission (except emissions in Restricted Bands)	15.247(c)	A8.5	Complies
Radiated Emission in Restricted Bands	15.247(c), 15.205	2.2	Complies
RF exposure	15.247(i)	RSS-102	Complies
AC Conducted Emission	15.207	RSS-GEN	Not Applicable. The EUT does not have any direct connection to public power network. In normal use, EUT is installed inside the host unit and it is DC powered internally.
Radiated Emission from Digital Parts and receiver	15.109	ICES-003	Complies

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 4 of 63



## 2.0 General Description

#### 2.1 Product Description

The WHITESTAR Signature Advanced Control Pedal & Remote Control system consists of the Advanced Control Pedal (<sup>1</sup>RF module for a Foot Pedal control mounted in main system) and Remote Control Master 2.0 (<sup>2</sup>RF module for remote control of Monitor mounted in main system), Advanced Control Pedal Slave (<sup>3</sup>RF module for a Foot Pedal control mounted outside of main system) and Remote Control Slave 2.0 (<sup>4</sup>RF module for remote control of Monitor mounted outside of main system).

The <sup>1</sup>RF module for a Foot Pedal control mounted in main system and <sup>3</sup>RF module for a Foot Pedal control mounted outside of main system consists two National Semiconductor's LMX98XX series Bluetooth radios ICs (transceivers), operating in the 2.4 GHz frequency band. Only one transmitter can report the data to the host at any given time. This radio subsystem is used to communicate the footpedal control signal to the WHITESTAR Signature<sup>TM</sup> system for use in cataract surgery.

The <sup>2</sup>RF module for remote control of Monitor mounted in main system and <sup>4</sup>RF module for remote control of Monitor mounted outside of main system consists one National Semiconductor's LMX98XX series Bluetooth radios ICs (transceivers), operating in the 2.4 GHz frequency band. This radio subsystem is used to communicate the monitor control signal to the WHITESTAR Signature<sup>TM</sup> system for use in cataract surgery.

This report covers the <sup>2</sup>RF module for remote control of Monitor mounted in main system and the <sup>1</sup>RF module for a Foot Pedal control mounted in main system is covered in separate report #3184783MPK-001A.

<sup>3</sup>RF module for a Foot Pedal control mounted outside of main system and <sup>4</sup>RF module for remote control of Monitor mounted outside of main system are already FCC and Industry Canada certified.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 5 of 63



#### **Overview of the EUT (Master)**

Advanced Medical Optics	
1700 E. Saint Andrew Place	
Santa Ana, CA 92705 USA	
Advanced Medical Optics	
1700 E. Saint Andrew Place	
Santa Ana, CA 92705 USA	
Advanced Control Pedal & Remote Control Master 2.0	
VGESIGREMM2	
7228A-SIGREMM2	
WhiteStar Signature Remote Control system	
Spread Spectrum, Frequency Hopping	
0.123 mW	
2402-2480 MHz	
79	
GFSK	
1 Mbps	
On-board antenna, 4.1 dBi	

A pre-production version of the sample was received on September 22, 2009 in good condition. As declared by the Applicant, it is identical to production units.

Test start date September 22, 2009 Test end date: October 22, 2009

## 2.2 Related Submittal(s) Grants

None.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 6 of 63



## 2.3 Test Methodology

Radiated and AC Line conducted emissions measurements were performed according to the procedures in ANSI C63.4 (2003). Radiated tests were performed at an antenna to EUT distance of 3 meters, unless stated otherwise in the "**Data Sheet**" of this Application. All other measurements were made in accordance with the procedures described in DA 00-705.

## 2.4 Test Facility

Then radiated emission test site and conducted measurement facility used to collect the data is 10m semi-anechoic chamber located in Menlo Park, California. This test facility and site measurement data have been fully placed on file with the FCC.

File: 3191467MPK-001 Page 7 of 63




## 3.0 System Test Configuration

## 3.1 Support Equipment

Item #	Description	Model No.	Serial No.
1	LAMBDA power supply	Vega 650	2050820220
2	Laptop	Compaq Evo N610c	INTERTEK LAB PC#1

## 3.2 Block Diagram of Test Setup

The diagram shown below details the interconnection of the EUT and support equipment. For specific layout, refer to the test configuration photograph in the relevant section of this report.



S = Shielded	$\mathbf{F} = \mathbf{With} \ \mathbf{Ferrite}$
U = Unshielded	<b>m</b> = Length in Meters

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 8 of 63



#### 3.3 Justification

For radiated emission measurements the EUT is placed on a non-conductive table. The EUT is attached to peripherals and they are connected and operational (as typical as possible). The EUT is wired to transmit full power. During testing, all cables are manipulated to produce worst-case emissions.

In normal operation, EUT is installed inside the host unit and it is DC powered internally. For testing the EUT was attached to a test board, connected to a laptop, which provides the power to the EUT and control the radio by the test software.

#### 3.4 Software Exercise Program

The EUT exercise program used during radiated and conducted testing was provided by the Applicant.

#### 3.5 Mode of Operation During Test

The EUT was tested in two modes: hopping mode as in normal use and hopping disabled mode in which the EUT was transmitting at the lowest, middle, and highest channels (frequencies).

## 3.6 Modifications Required for Compliance

No modifications were installed by Intertek Testing Services during compliance testing in order to bring the product into compliance (Please note that this list does not include changes made specifically by Advanced Medical Optics prior to compliance testing).

File: 3191467MPK-001 Page 9 of 63



## 4.0 Measurement Results

4.1 Conducted Output Power at Antenna Terminals FCC 15.247(b)(1)

#### Requirements

For systems operating in the 2400-2483.5 MHz band employing at least 75 hopping channels, the maximum peak output power is 1 watt (30 dBm), for all other systems 0.125 W (21 dBm).

#### **Procedure**

The antenna port of the EUT was connected to the input of a spectrum analyzer. Power was read directly and cable loss correction was added to the reading to obtain the power at the EUT antenna terminal.

## **Test Results**

#### Transmitter 1 (Tx1)

Frequency	Output in dBm	Output in mW	Plot number
(MHz)			
2402	-9.1	0.123	1.1
2440	-9.7	0.107	1.2
2480	-9.4	0.115	1.3

Notes: 1. Hopping function was disabled during the test.


2. The EUT's antenna has less than 6 dBi gain.

File: 3191467MPK-001 Page 10 of 63





#### Plot 1. 1



Comment: Output power


12.OCT.2009 08:02:36 Date:

File: 3191467MPK-001 Page 11 of 63





Plot 1. 2



Comment: Output power


Date: 12.OCT.2009 08:04:27

File: 3191467MPK-001 Page 12 of 63





Plot 1. 3



Comment: Output power

Date: 12.OCT.2009 08:06:16

File: 3191467MPK-001 Page 13 of 63



# 4.2 Hopping Channel 20-dB Bandwidth FCC 15.247(a)

## **Procedure**

The antenna port of the EUT was connected to the input of a spectrum analyzer. The spectrum analyzer resolution bandwidth was set to approximately 1% of the 20-dB Bandwidth. The 20-dB Bandwidth was measured by using the DELTA MARKER function of the analyzer.

In addition, the occupied bandwidth (99%) was measured.

## **Test Results**


Frequency (MHz)	20-dB channel bandwidth	Plot
	(MHz)	
2402	1.016	2.1
2440	1.020	2.2
2480	1.024	2.3

Frequency (MHz)	Occupied bandwidth	Plot
	(MHz)	
2402	0.984	2.4
2440	0.984	2.5
2480	0.988	2.6

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 14 of 63






Comment: 20-dB Bandwidth

Date: 12.OCT.2009 09:16:13

File: 3191467MPK-001 Page 15 of 63








Comment: 20-dB Bandwidth

Date: 12.OCT.2009 09:57:26

File: 3191467MPK-001 Page 16 of 63








Comment: 20-dB Bandwidth

Date: 12.OCT.2009 10:06:40

File: 3191467MPK-001 Page 17 of 63







200 kHz/

Span 2 MHz

Comment: Occupied Bandwidth Date: 12.OCT.2009 10:09:17


Center 2.402024 GHz

File: 3191467MPK-001 Page 18 of 63










Comment: Occupied Bandwidth Date: 12.OCT.2009 10:10:13

File: 3191467MPK-001 Page 19 of 63





Plot 2. 6



Comment: Occupied Bandwidth Date: 12.OCT.2009 10:11:11

File: 3191467MPK-001 Page 20 of 63



# 4.3 Carrier Frequency Separation FCC Ref: 15.247(a)(1)

#### Requirement

Systems shall have hopping channel carrier frequencies that are separated by 25 kHz or two-thirds of the 20-dB bandwidth of the hopping channel, whichever is greater.

## **Procedure**


Using the DELTA MARKER function of the analyzer, the frequency separation between two adjacent channels was measured and compared against the limit.

## **Test Results**

Please refer to the attached spectrum analyzer plot # 3.1 for the test result. The channel separation is 1.002MHz.

File: 3191467MPK-001 Page 21 of 63





Comment: Carrier frequency separation Date: 12.OCT.2009 12:24:41

File: 3191467MPK-001 Page 22 of 63



# 4.4 Number of Hopping Channels FCC Ref: 15.247(a)(1)(iii)

## Requirement

Systems operating in the 2400-2483.5 MHz band shall use at least 15 hopping channels.

#### Procedure

With the analyzer set to MAX HOLD, readings were taken for 2 - 3 minutes The channel peaks so recorded and compared to the minimum number of channels required in the regulation.

## **Test Results**


Number of hopping channels	79

Refer to attached spectrum analyzer charts: Plots 4.1

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 23 of 63





Comment: Number of hopping channels Date: 12.OCT.2009 12:16:34

File: 3191467MPK-001 Page 24 of 63



## 4.5 Average Channel Occupancy Time FCC 15.247(a)(1)(ii)(iii)

#### Requirement

For systems operating in the 2400-2483.5 MHz band, the average time of occupancy on any channel shall not be greater than 0.4 second within a period of 0.4 second multiplied by the number of hopping channels employed.

#### **Procedure**

The spectrum analyzer center frequency was set to one of the known hopping channels, the SPAN was set to ZERO SPANS, and the TRIGGER was set to VIDEO. The time duration of the transmission so captured was measured with the MARKER DELTA function.

Since the radio is employed 79 hopping channels, the Occupancy Time was calculated for the period of 0.4 \* 79 = 31.6 sec.

#### **Test Results**

Occupancy Time (see plots 5.1 and 5.2)


0.00290\*13\*10 = 0.377 sec.

Refer to attached spectrum analyzer plots 5.1-5.2 for details.

File: 3191467MPK-001 Page 25 of 63







Comment: Dwell time

Date: 12.OCT.2009 12:33:46


File: 3191467MPK-001 Page 26 of 63





Plot 5. 2

RBW 300 kHz \*VBW 1 MHz



Comment: Dwell time

Date: 12.OCT.2009 13:41:04

File: 3191467MPK-001 Page 27 of 63



# 4.6 Out-of Band-Conducted Emissions FCC 15.247(c)

## Requirement

In any 100 kHz bandwidth outside the EUT pass-band, the RF power shall be at least 20 dB below that of the maximum in-band 100 kHz emission.

## **Procedure**

A spectrum analyzer was connected to the antenna port of the transmitter. Analyzer Resolution Bandwidth was set to 100 kHz. For each channel investigated, the in-band and out-of-band emission measurements were performed. The out-of-band emissions were measured from 30 MHz to 25 GHz.

## **Test Result**

Refer to the following plots for the test result:


Description	Comments	Plot number
In-band Emissions, F=2402 MHz		6.1
In-band Emissions, F=2441 MHz		6.5
In-band Emissions, F=2480 MHz		6.9
Emissions on the low band-edge frequency	Fixed channel, 2402 MHz	6.13
Emissions on the low band-edge frequency	Hopping mode	6.14
Emissions on the high band-edge frequency	Fixed channel, 2480 MHz	6.15
Emissions on the high band-edge frequency	Hopping mode	6.16
Out-of-band low Channel Emissions	Fixed channel, 2402 MHz	6.2 - 6.4
Out-of-band middle Channel Emissions	Fixed channel, 2441 MHz	6.6 - 6.8
Out-of-band high Channel Emissions	Fixed channel, 2480 MHz	6.10 - 6.12

The attenuation is more than 20 dB.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 28 of 63





 ${\tt Comment: In-band\ emissions,\ Freq\ 2402MHz}$ 


Date: 12.OCT.2009 10:23:14

File: 3191467MPK-001 Page 29 of 63





Plot 6. 2



Comment: Spurious emissions, Freq 2402MHz


Date: 12.OCT.2009 10:41:35

File: 3191467MPK-001 Page 30 of 63





Plot 6. 3



Comment: Spurious emissions, Freq 2402MHz


Date: 12.OCT.2009 10:43:52

File: 3191467MPK-001 Page 31 of 63





Plot 6. 4



Comment: Spurious emissions, Freq 2402MHz


Date: 12.OCT.2009 10:45:09

File: 3191467MPK-001 Page 32 of 63





Plot 6. 5



Comment: In-band emissions, Freq 2441MHz


Date: 12.OCT.2009 10:51:40

File: 3191467MPK-001 Page 33 of 63





Plot 6. 6



Comment: Spurious emissions, Freq 2441MHz


Date: 12.OCT.2009 10:53:58

File: 3191467MPK-001 Page 34 of 63





Plot 6. 7




Comment: Spurious emissions, Freq 2441MHz

Date: 12.OCT.2009 11:02:31

File: 3191467MPK-001 Page 35 of 63



Plot 6. 8




Comment: Spurious emissions, Freq 2441MHz

Date: 12.OCT.2009 11:03:23

File: 3191467MPK-001 Page 36 of 63



Plot 6. 9




Comment: In-band emissions, Freq 2480MHz

Date: 12.OCT.2009 11:05:58

File: 3191467MPK-001 Page 37 of 63



Plot 6. 10




Date: 12.OCT.2009 11:09:23

File: 3191467MPK-001 Page 38 of 63





Plot 6. 11




Date: 12.OCT.2009 11:10:26

File: 3191467MPK-001 Page 39 of 63



Plot 6. 12



Date: 12.OCT.2009 11:11:01

File: 3191467MPK-001 Page 40 of 63






#### Plot 6. 13



Stop 2.405 GHz



1.5 MHz/

Comment: Spurious emissions, Freq 2402MHz

Date: 12.OCT.2009 11:16:19


Start 2.39 GHz

File: 3191467MPK-001 Page 41 of 63





Plot 6. 14




Date: 12.OCT.2009 11:18:29

File: 3191467MPK-001 Page 42 of 63





Plot 6. 15




Date: 12.OCT.2009 11:21:01

File: 3191467MPK-001 Page 43 of 63





Plot 6. 16



Date: 12.OCT.2009 11:23:15

File: 3191467MPK-001 Page 44 of 63



# 4.7 Transmitter Radiated Emissions in Restricted Bands FCC 15.247 (c), 15.205

#### Procedure

Radiated emission measurements were performed from 30 MHz to 25,000 MHz. Spectrum Analyzer Resolution Bandwidth is 100 kHz or greater for frequencies 30 MHz to 1000 MHz, 1 MHz - for frequencies above 1000 MHz.

The EUT is placed on a non-conductive table. If the EUT attaches to peripherals, they are connected and operational (as typical as possible). During testing, all cables were manipulated to produce worst case emissions. The signal is maximized through rotation. The antenna height and polarization are varied during the search for maximum signal level. The antenna height is varied from 1 to 4 meters.

Radiated emissions are taken at three meters unless the signal level is too low for measurement at that distance. If necessary, a pre-amplifier is used and/or the test is conducted at a closer distance. All readings are extrapolated back to the equivalent three-meter reading using inverse scaling with distance.

Data is included of the worst case configuration (the configuration which resulted in the highest emission levels). A sample calculation, configuration photographs and data tables of the emissions are included.

#### Field Strength Calculation

The field strength is calculated by adding the Antenna Factor and Cable Factor, and subtracting the Amplifier Gain (if any) from the measured reading. The basic equation with a sample calculation is as follows:

```
\begin{split} FS &= RA + AF + CF - AG \\ Where \quad FS &= Field \; Strength \; in \; dB(\mu V/m) \\ RA &= Receiver \; Amplitude \; (including \; preamplifier) \; in \; dB(\mu V) \\ CF &= Cable \; Attenuation \; Factor \; in \; dB \\ AF &= Antenna \; Factor \; in \; dB \\ AG &= Amplifier \; Gain \; in \; dB \end{split}
```

Assume a receiver reading of  $52.0\,dB(\mu V)$  is obtained. The antennas factor of  $7.4\,dB(1/m)$  and cable factor of  $1.6\,dB$  is added. The amplifier gain of 29 dB is subtracted, giving field strength of  $32\,dB(\mu V/m)$ . This value in  $dB(\mu V/m)$  was converted to its corresponding level in  $\mu V/m$ .

```
RA = 52.0 \; dB(\mu V) AF = 7.4 \; dB(1/m) CF = 1.6 \; dB AG = 29.0 \; dB FS = 52.0 + 7.4 + 1.6 - 29.0 = 32 \; dB(\mu V/m) Level in \mu V/m = Common \; Antilogarithm \; [(32 \; dB\mu V/m)/20] = 39.8 \; \mu V/m
```

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 45 of 63



#### Result

The data on the following pages list the significant emission frequencies, the limit and the margin of compliance.

The radiated emissions in the restricted bands near the operating band are presented on the following Plots 7.1 - 7.6. On these plots antenna factor and cable loss are included in the OFFSET of the spectrum analyzer reading, therefore the readings are field strength.

The EUT passed the test by 4.1 dB.

File: 3191467MPK-001 Page 46 of 63



	Test Result
FCC Part 15.24	7 Radiated Emission in Restricted Bands
Temperature: 21C	Advanced Medical Optics
Humidity: 50%	Model: Advanced Control Pedal &
•	Remote Control Master 2.0
Test data of <sup>2</sup> RF module fo	or remote control of Monitor mounted in main system
Test distance = 3 m	
Test date: September 22, 2009	

Frequency	Detector	SA reading	Correction	Duty *	Ant. Factor	Field Strength	Limit	Margin	
MHz		dB(uV)	Factor dB	cycle dB	dB(1/m)	dB(uV/m)	dB(uV/m)	dB	
Tx at 2402 MHz									
4804.0	Peak	60.6	-25.8		33.0	67.8	74.0	-6.2	
12010.0	Peak	36.6	-20.8		39.2	55.0	74.0	-19.0	
4804.0	Aver	43.9	-25.8	2.3	33.0	48.8	54.0	-5.2	
12010.0	Aver	23.1	-20.8	2.3	39.2	39.2	54.0	-14.8	
Tx at 2441 N	ИНz								
4882.0	Peak	61.7	-25.2		33.2	69.7	74.0	-4.3	
7323.0	Peak	47.4	-22.6		36.1	60.9	74.0	-13.1	
12205.0	Peak	36.6	-21.0		39.0	54.6	74.0	-19.4	
4882.0	Aver	44.2	-25.2	2.3	33.2	49.9	54.0	-4.1	
7323.0	Aver	29.3	-22.6	2.3	36.1	40.5	54.0	-13.5	
12205.0	Aver	22.7	-21.0	2.3	39.0	38.4	54.0	-15.6	
Tx at 2480 N	ИHz								
4960.0	Peak	61.4	-24.9		33.4	69.9	74.0	-4.1	
7440.0	Peak	52.5	-22.6		36.4	66.3	74.0	-7.7	
12400.0	Peak	36.6	-21.3		38.7	54.0	74.0	-20.0	
4960.0	Aver	41.5	-25.4	2.3	33.4	47.2	54.0	-6.8	
7440.0	Aver	32.1	-22.6	2.3	36.6	43.8	54.0	-10.2	
12400.0	Aver	22.9	-21.3	2.3	38.7	38.0	54.0	-16.0	


<sup>\*</sup> See Appendix A for Duty cycle measurement.

- a) RBW = 1 MHz, VBW = 1 MHz for peak measurements RBW = 1MHz, VBW = 100 Hz for average measurements
- b) Correction Factor: Pre-amplifier gain + Cable loss + HP-Filter loss
- c) All other emissions are 20 dB below the limit.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 47 of 63






Comment: Emissions on band-edge frequency, peak, freq 2402 MHz Date: 21.SEP.2009 15:26:17

File: 3191467MPK-001 Page 48 of 63





Plot 7. 2



Comment: Emissions on band-edge frequency, peak, freq 2402 MHz


Date: 21.SEP.2009 15:32:04

File: 3191467MPK-001 Page 49 of 63





Plot 7. 3



 ${\tt Comment: Emissions \ on \ band-edge \ frequency, \ average, \ freq \ 2402 \ MHz}$ 


Date: 21.SEP.2009 15:34:16

File: 3191467MPK-001 Page 50 of 63



8

Plot 7. 4



 ${\tt Comment: Emissions \ on \ band-edge \ frequency, \ average, \ freq \ 2480 \ MHz}$ 

Date: 21.SEP.2009 15:41:01

File: 3191467MPK-001 Page 51 of 63






-20-

-10

-0

-10

Start 2.475 GHz



2.5 MHz/

Stop 2.5 GHz

Plot 7. 5


Comment: Emissions on band-edge frequency, peak, freq 2480 MHz Date: 21.SEP.2009 15:42:37

F1

File: 3191467MPK-001 Page 52 of 63







 ${\tt Comment: Emissions \ on \ band-edge \ frequency, \ peak, \ freq \ 2480 \ MHz}$ 

Date: 21.SEP.2009 15:43:58

File: 3191467MPK-001 Page 53 of 63



# 4.8 Radiated Emissions from Digital Parts and Receiver FCC Ref: 15.109

#### **Test Limit**

Limits for Electromagnetic Radiated Emissions, FCC Section 15.109(b) and ICES 003 \*

Frequency (MHz)	Class A at 10m dB(μV/m)	Class B at 3m dB(µV/m)
30-88	39	40.0
88-216	43.5	43.5
216-960	46.4	46.0
Above 960	49.5	54.0

<sup>\*</sup> According to FCC Part 15.109(g) an alternative to the radiated emission limits shown above, digital devices may be shown to comply with the limit of CISPR Pub. 22

#### Test Procedure

Measurements are conducted with a quasi-peak detector instrument in the frequency range of 30 MHz to 1000 MHz and with the average detector instrument in the frequency range above 1000 MHz. The measuring receiver meets the requirements of Section One of CISPR 16 and the measuring antenna correlates to a balanced dipole.

Measurements of the radiated field are made with the antenna located at a distance of 10 meters from the EUT. If the field-strength measurements at 10m cannot be made because of high ambient noise level or for other reasons, measurements of Class B equipment may be made at a closer distance, for example 3m. An inverse proportionality factor of 20 dB per decade should be used to normalize the measured data to the specified distance for determining compliance.

The antenna is adjusted between 1m and 4m in height above the ground plane for maximum meter reading at each test frequency.

The antenna-to-EUT azimuth is varied during the measurement to find the maximum field-strength readings.

The antenna-to-EUT polarization (horizontal and vertical) is varied during the measurements to find the maximum field-strength readings.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 54 of 63



The EUT, where intended for tabletop use, is placed on a table whose top is 0.8m above the ground plane. The table is constructed of non-conductive materials. Its dimensions are 1m by 1.5m, but may be extended for a larger EUT.

Floor standing EUTs are placed on a horizontal metal ground plane and isolated from the ground plane by 3 to 12 mm of insulating material.

Equipment setup for radiated disturbance tests followed the guidelines of ANSI C63.4 (2003).

#### **Example Field Strength Calculation**

The field strength is calculated by adding the Antenna Factor and Cable Factor to from the measured reading, followed by subtracting the Amplifier Gain (if any) and Distance Correction Factor (if any). The basic equation with a sample calculation is as follows:

FS = RA + AF + CF - PA - DCF

Where  $FS = Field Strength in dB (\mu V/m)$ 

 $RA = Receiver Amplitude (including preamplifier) in dB (<math>\mu V$ )

CF = Cable Attenuation Factor in dB AF = Antenna Factor in dB (1/m) AG = Amplifier Gain in dB

DCF=Distance Correction Factor in dB

(Formula:  $DCF = 20log_{10}$  (measurement distance/specification distance)

Assume a receiver reading of 52.0 dB ( $\mu$ V) is obtained. The antenna factor of 7.4 dB and cable factor of 1.6 dB is added. The amplifier gain of 29 dB and DCF of 10.5 dB (DCF in this example:  $20\log_{10}{(10/3)}$ ) is subtracted, giving field strength of 21.5 dB ( $\mu$ V/m).

RA = 52.0 dB ( $\mu$ V) AF = 7.4 dB (1/m) CF = 1.6 dB AG = 29.0 dB DCF=10.5 dB ES = RE +  $\Delta$ E + CE =  $\Delta$ 

FS = RF + AF + CF - AG - DCFFS = 52.0 + 7.4 + 1.6 - 29.0 - 10.5

 $FS = 21.5 \text{ dB } (\mu V/m)$ 

#### **Test Results**

Radiated emission measurements were performed from 30 MHz to  $1000\,\mathrm{MHz}$ . Spectrum Analyzer Resolution Bandwidth is  $100\,\mathrm{kHz}$  or greater below  $1000\,\mathrm{MHz}$  and  $1\,\mathrm{MHz}$  - above  $1000\,\mathrm{MHz}$ .

The EUT passed by 5.1 dB for Class B.

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control Master 2.0

File: 3191467MPK-001 Page 55 of 63



## Test data of <sup>2</sup>RF module for remote control of Monitor mounted in main system Intertek Testing Services

#### The item 200 Miles 1000 M

# Radiated Emissions 30 MHz - 1000 MHz FCC Part 15 Class B (Pk-Vertical)

Operator: KK Model: Advanced Control Pedal & Remote Control Master 2.0

October 06, 2009 Company: Advanced Medical Optics

Frequency	Peak FS	Limit@3m	Margin	RA	CF	AG	DCF	AF
(MHz)	dB(uV/m)	dB(uV/m)	dB	dB(uV)	dB	dB	dB	dB(1/m)
147.491	38.4	43.5	-5.1	45.4	1.3	31.9	10.5	13.2
300.428	40.0	46.0	-6.0	45.2	1.8	31.9	10.5	14.4
310.492	41.8	46.0	-4.2	46.6	1.8	31.9	10.5	14.7
314.008	38.1	46.0	-7.9	42.9	1.9	31.9	10.5	14.8
315.18	38.2	46.0	-7.8	42.9	1.9	31.9	10.5	14.9
318.979	37.9	46.0	-8.1	42.0	1.9	31.9	10.5	15.4
397.63	39.3	46.0	-6.7	42.2	2.1	32.0	10.5	16.5
463.913	40.5	46.0	-5.5	41.8	2.3	32.1	10.5	18.1
768.13	38.8	46.0	-7.2	34.8	3.0	32.2	10.5	22.7
797.876	39.7	46.0	-6.3	35.7	3.0	32.0	10.5	22.5
816.104	40.9	46.0	-5.1	36.5	3.1	32.0	10.5	22.8
864.16	38.0	46.0	-8.0	32.9	3.1	31.7	10.5	23.1
940.87	37.9	46.0	-8.1	31.8	3.3	31.1	10.5	23.5
960.19	39.0	54.0	-15.0	32.5	3.3	31.0	10.5	23.6

Test Mode: Rx mode

Temperature: 20 C Humidity: 50 %

# Intertek Testing Services Radiated Emissions 30 MHz - 1000 MHz FCC Part 15 Class B (Pk-Horizontal)

Operator: KK Model: Advanced Control Pedal & Remote Control Master 2.0

October 06, 2009 Company: Advanced Medical Optics

Frequency	Peak FS	Limit@3m	Margin	RA	CF	AG	DCF	AF
(MHz)	dB(uV/m)	dB(uV/m)	dB	dB(uV)	dB	dB	dB	dB(1/m)
147.491	33.3	43.5	-10.2	40.4	1.3	31.9	10.5	13.1
315.059	33.0	46.0	-13.0	38.7	1.9	31.9	10.5	13.9
397.67	33.9	46.0	-12.1	36.9	2.1	32.0	10.5	16.3
466.177	33.1	46.0	-12.9	34.4	2.3	32.1	10.5	18.0
528.095	32.8	46.0	-13.2	33.2	2.4	32.2	10.5	18.8
744.567	33.2	46.0	-12.8	30.3	2.9	32.2	10.5	21.7
768.089	33.1	46.0	-12.9	29.9	3.0	32.2	10.5	21.9
801.837	36.4	46.0	-9.6	33.2	3.0	32.0	10.5	21.7
816.145	35.5	46.0	-10.5	32.0	3.1	32.0	10.5	21.9
864.16	34.6	46.0	-11.4	29.8	3.1	31.7	10.5	22.8

Test Mode: Rx mode

Temperature: 20 C Humidity: 50 %

EMC Report for Advanced Medical Optics on the model: Advanced Control Pedal & Remote Control

Master 2.0

File: 3191467MPK-001 Page 56 of 63



4.9 AC Line Conducted Emission FCC 15.207:

Not Applicable. The EUT does not have any direct connection to public power network. In normal use, EUT is installed inside the host unit and it is DC powered internally.

File: 3191467MPK-001 Page 57 of 63



#### 5.0 RF Exposure evaluation

The EUT is a Bluetooth device used in mobile application, at least 20 cm from any body part of the user or near by persons.

The maximum conducted power is 0.123 mW; antenna is fix-mounted, 4.1 dBi gain. Therefore, to comply with RF Exposure Requirement, the MPE is calculated.

The maximum Peak EIRP calculated is -5.0 dBm or 0.32 mW.

The Power Density can be calculated using the formula

 $S = EIRP/4\pi D^2$ 

Where: S is Power Density in  $W/m^2$ 

D is the distance from the antenna.

It is considered that 20cm is the minimum distance that user can go closer to the EUT (Advanced Control Pedal & Remote Control Master 2.0) which is installed inside the Console of WhiteStar Signature Remote Control system.

At 0.2 m,  $S = 0.00064 \text{ W/m}^2$ , which is below the MPE Limit of 10 W/m<sup>2</sup>

File: 3191467MPK-001 Page 58 of 63



### 6.0 List of test equipment

Measurement equipment used for emission compliance testing utilized the equipment on the following list:

		1 0	1 1		0
Equipment	Manufacturer	Model/Type	Serial #	Cal Int	Cal Due
Spectrum Analyzer	Rohde&Schwarz	FSP40	036612004	12	10/16/10
BI-Log Antenna	EMCO	3143	9509	12	11/07/09
Pre-Amplifier	Sonoma	310N	185634	12	11/10/09
Pre-Amplifier	Miteq	AMF-4D-001180-24-10P	799159	12	07/29/10
Spectrum Analyzer	Rohde&Schwarz	FSU26	200482	12	02/27/10
Vector Signal Generator	Rohde&Schwarz	SMU200A	102499	12	04/01/10
Horn Antenna	EMCO	3115	9107-3712	12	11/03/10

File: 3191467MPK-001 Page 59 of 63




## 7.0 Document History

Revision/ Job Number	Writer Initials	Date	Change
1.0 / 3191467	KK	December 03, 2009	Original document

File: 3191467MPK-001 Page 60 of 63



#### 8.0 Appendix A – Graphs for Duty cycle measurement




Comment: Duty cycle, freq 2441MHz Date: 12.OCT.2009 13:00:02

Duty Cycle Calculation =  $20 \log (2.90/3.8) = -2.3 dB$ 

File: 3191467MPK-001 Page 61 of 63



Graph A2




Comment: Duty cycle, freq 2402MHz Date: 12.OCT.2009 13:02:13

Duty Cycle Calculation =  $20 \log (2.9/3.8) = -2.3 dB$ 

File: 3191467MPK-001 Page 62 of 63



Graph A3



Comment: Duty cycle, freq 2480MHz Date: 12.OCT.2009 13:16:15

Duty Cycle Calculation =  $20 \log (2.92/3.8) = -2.3 dB$ 

File: 3191467MPK-001 Page 63 of 63