RF Exposure requirements

Product name	Digital Blood Pressure Monitor						
Model number	SE-9400BLE						
FCC ID	WSX- SE-9400BLE						
Radio specification	2.4 GHz						
Antenna	Internal PCB antenna						
Power source	DC 6 V (AA alkaline 1.5 V x 4) or (AC Adapter)						

According to the KDB 447498, the following standalone SAR test exclusion was considered to qualify for the SAR test exclusion.

Tx frequency range	2402 MHz - 2480 MHz				
Device category	Mobile device				
Maximum conducted output power	0.58 mW (-2.36 dBm) @ 2480 MHz				
Limit	10 mW (distance = 5 mm)				

RF power output (measured):

unit: mW

	Operating frequency						
Data rate	2402 MHz	2440 MHz	2480 MHz				
1 Mbps(Bluetooth LE)	0.57	0.53	0.58				

SAR test exclusion thresholds:

[(max. power of channel, mW) / (min. separation distance, mm] \cdot Vf_(GHz) \leq 3.0 for 1-g SAR and \leq 7.5 for 10-g extremity SAR

MHz	5	10	15	20	25	29	30	35	40	45	50	test separation distance (mm)
2450	10	19	29	38	48	56	57	67	77	86	96	SAR test exclusion threshold (mW)

The source-based time-averaged maximum conducted output power of the RF channel is less than 10 mW, and the minimum separation distance of 5 mm can be achieved. Therefore the transmitter complies with the RF exposure requirements and the SAR is not required.