

ISED CABid: ES1909

Test report No:
NIE: 66554RRF.004

Test report

USA FCC Part 15.209
CANADA RSS-Gen, RSS-210

(*) Identification of item tested	WOE46L
(*) Trademark	GN Hearing A/S, GN Audio A/S, ReSound, Beltone, Interton, Audigy, Jabra
(*) Model and /or type reference	WOE46L
Other identification of the product	HW version: PCBA,WOLVERINE, LEFT, V2.B, C6.0 SW version: Dooku2 (M.1.5.6) FCC ID: X26WOE46L IC: 6941C-WOE46L
(*) Features	Audio amplification, Bluetooth 5.0 and 10.667 MHz wireless magnetic induction functionality
Applicant	GN Hearing Lautrupbjerg 7, 2750 Ballerup Denmark
Test method requested, standard	USA FCC Part 15.209 (10–1–19 Edition): Radiated emission limits, general requirements. CANADA RSS-Gen Issue 5 (March 2019) Amendment 1. General Requirements for Compliance of Radio Apparatus. CANADA RSS-210 Issue 10 (December 2019). Licence-Exempt Radio Apparatus: Category I Equipment ANSI C63.10-2013: American National Standard for Testing Unlicensed Wireless Devices.
Summary	IN COMPLIANCE
Approved by (name / position & signature)	Rafael López EMC Consumer & RF Lab. Manager
Date of issue	2021-07-19
Report template No	FDT08_23 (*) "Data provided by the client"

Index

Competences and guarantees	3
General conditions	3
Uncertainty	3
Data provided by the client.....	3
Usage of samples	4
Test sample description	5
Identification of the client.....	6
Testing period and place.....	6
Document history	6
Environmental conditions	6
Remarks and comments	7
Testing verdicts.....	8
Summary	8
Appendix A: Test results	9

Competences and guarantees

DEKRA Testing and Certification S.A.U. is a testing laboratory accredited by the National Accreditation Body (ENAC -Entidad Nacional de Acreditación), to perform the tests indicated in the Certificate No. 51/LE 147.

DEKRA Testing and Certification S.A.U. is an FCC-recognized accredited testing laboratory with the appropriate scope of accreditation that covers the performed test in this report.

DEKRA Testing and Certification S.A.U. is an ISED-recognized accredited testing laboratory, CABid: ES1909, with the appropriate scope of accreditation that covers the performed tests in this report.

In order to assure the traceability to other national and international laboratories, DEKRA Testing and Certification S.A.U. has a calibration and maintenance program for its measurement equipment.

DEKRA Testing and Certification S.A.U. guarantees the reliability of the data presented in this report, which is the result of the measurements and the tests performed to the item under test on the date and under the conditions stated on the report and, it is based on the knowledge and technical facilities available at DEKRA Testing and Certification S.A.U. at the time of performance of the test.

DEKRA Testing and Certification S.A.U. is liable to the client for the maintenance of the confidentiality of all information related to the item under test and the results of the test.

The results presented in this Test Report apply only to the particular item under test established in this document.

IMPORTANT: No parts of this report may be reproduced or quoted out of context, in any form or by any means, except in full, without the previous written permission of DEKRA Testing and Certification S.A.U.

General conditions

1. This report is only referred to the item that has undergone the test.
2. This report does not constitute or imply on its own an approval of the product by the Certification Bodies or competent Authorities.
3. This document is only valid if complete; no partial reproduction can be made without previous written permission of DEKRA Testing and Certification S.A.U.
4. This test report cannot be used partially or in full for publicity and/or promotional purposes without previous written permission of DEKRA Testing and Certification S.A.U. and the Accreditation Bodies.

Uncertainty

Uncertainty (factor $k=2$) was calculated according to the DEKRA Testing and Certification S.A.U. internal document PODT000.

Data provided by the client

The following data has been provided by the client:

1. Information relating to the description of the sample ("Identification of the item tested", "Trademark", "Model and/or type reference tested").
2. The sample of the model WOE46L is a wireless, rechargeable hearing aid.

DEKRA Testing and Certification S.A.U. declines any responsibility with respect to the information provided by the client and that may affect the validity of result.

Usage of samples

Samples undergoing test have been selected by: The client.

- Sample S/01 is composed of the following elements:

Control Nº	Description	Model	Serial Nº	Date of reception
66554C/030	Rechargeable hearing aid	WOE46L	2100803161	2021/05/25

Sample S/01 has undergone the test(s): All radiated tests indicated in Appendix A.

- Sample S/02 is composed of the following elements:

Control Nº	Description	Model	Serial Nº	Date of reception
66554C/086	Rechargeable hearing aid	WOE46L	---	2021/05/25

Sample S/02 has undergone the test(s): All conducted tests indicated in Appendix A.

Test sample description

Ports.....:	Port name and description	Cable				
		Specified max length [m]	Attached during test	Shielded	Coupled to patient ⁽³⁾	
--	--		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Supplementary information to the ports.....:	--					
Rated power supply	Voltage and Frequency	Reference poles				
		<input type="checkbox"/>	DC:	L1	L2	L3
Rated Power	3.8 V					
Clock frequencies.....:	2.48 GHz and 10.667 MHZ					
Other parameters	--					
Software version	Dooku2 (M.1.5.6)					
Hardware version	PCBA,WOLVERINE,LEFT,V2.B,C6.0					
Dimensions in cm (W x H x D):	--					
	<input checked="" type="checkbox"/> Other: Placed behind the ear					
Modules/parts.....:	Module/parts of test item	Type			Manufacturer	
	--					
Accessories (not part of the test item)	Description	Type			Manufacturer	
	Computer	Certified according to IEC 60950-1, IEC 62368-1 or equivalent standard				
Documents as provided by the applicant	Description	File name			Issue date	
	Radio test plan	0422600rA_WOE46L_Radio_Test_Plan.docx			2021.03.25	

⁽³⁾ Only for Medical Equipment

Identification of the client

GN Hearing
Lautrupbjerg 7, 2750 Ballerup
Denmark

Testing period and place

Test Location	DEKRA Testing and Certification S.A.U.
Date (start)	2020-06-03
Date (finish)	2020-06-21

Document history

Report number	Date	Description
66554RRF.004	2021-02-02	First release

Environmental conditions

In the control chamber, the following limits were not exceeded during the test:

Temperature	Min. = 15 °C Max. = 35 °C
Relative humidity	Min. = 20 % Max. = 75 %

In the semianechoic chamber, the following limits were not exceeded during the test.

Temperature	Min. = 15 °C Max. = 35 °C
Relative humidity	Min. = 20 % Max. = 75 %

In the chamber for conducted measurements, the following limits were not exceeded during the test:

Temperature	Min. = 15 °C Max. = 35 °C
Relative humidity	Min. = 20 % Max. = 75 %

Remarks and comments

The tests have been performed by the technical personnel: Verónica García and Pablo Redondo.

Used instrumentation:

Conducted Measurements:

		Last Calibration	Due Calibration
1.	Shielded Room ETS LINDGREN S101	N.A.	N.A.
2.	Signal and Spectrum Analyzer ROHDE AND SCHWARZ FSV 40	2019/09	2021/09
3.	DC Power Supply 40V/40A ROHDE AND SCHWARZ NGPE 40/40	N.A.	N.A.
4.	Digital Multimeter FLUKE 179	2020/10	2021/10

Radiated Measurements:

		Last Calibration	Due Calibration
1.	Semianechoic Absorber Lined Chamber ETS LINDGREN FACT 3 200 STP	N.A.	N.A.
2.	Shielded Room ETS LINDGREN S101	N.A.	N.A.
3.	Active Loop antenna 9 kHz-30 MHz HEWLETT PACKARD 11966A	2020/07	2022/07
4.	EMI Test Receiver 9kHz-7GHz ROHDE AND SCHWARZ ESR7	2020/12	2022/12
5.	Biconical/Log Antenna 30 MHz - 6 GHz ETS LINDGREN 3142E	2020/04	2023/04
6.	RF Pre-amplifier, 40 dB ,10MHz-6 GHz BONN ELEKTRONIK BLMA 0160-01N	2021/03	2022/03

Testing verdicts

Not applicable:	N/A
Pass:	P
Fail:	F
Not measured:	N/M

Summary

MI 10.66 MHz.

FCC PART 15.209 / RSS-Gen, RSS-210 PARAGRAPH		Verdict	Remark
Requirement – Test case			
Occupied bandwidth		P	
FCC 15.209 (a) / RSS-Gen 8.9.,RSS-210 7.2. : General field strength and Trasmitter emission limits.		P	
<u>Supplementary information and remarks:</u> None.			

Appendix A: Test results

INDEX

TEST CONDITIONS.....	11
Occupied Bandwidth.....	13
15.209 (a) / RSS-Gen 8.9., RSS-210 7.2. General field strength and Transmitter emission limits	14

TEST CONDITIONS

POWER SUPPLY (V):


Vnominal:	1.8 Vdc
Type of Power Supply:	DC voltage from external power supply and battery.
Type of Antenna:	Internal antenna.

TEST FREQUENCIES:

Nominal Operating Frequency: 10.66 MHz

CONDUCTED MEASUREMENTS

The equipment under test EUT was set up in a shielded room and it is connected to the spectrum analyzer through a RF cable and a coupling device.



RADIATED MEASUREMENTS


All radiated tests were performed in a semi-anechoic chamber. The measurement antenna (Loop antenna for the range between 9 kHz to 30 MHz) is situated at a distance of 3 m.

For radiated emissions in the range 9 kHz to 30 MHz that is performed at a distance closer than the specified distance, an inverse proportionality factor of 40 dB per decade is used to normalize the measured data for determining compliance.


The equipment under test was set up on a non-conductive platform above the ground plane and the situation and orientation was varied to find the maximum radiated emission.

In the range between 9 kHz and 30 MHz the measurements were made in the three different orientation planes of the loop antenna to determine the maximum received field. Measurements above 30 MHz up to 200 MHz were made in both horizontal and vertical planes of polarization.

Radiated measurements setup $f < 30$ MHz:




Radiated measurements setup $f > 30$ MHz:



Occupied Bandwidth

RESULTS:

99% Bandwidth (MHz)	2.9300
Measurement uncertainty (kHz)	<±12.12



15.209 (a) / RSS-Gen 8.9., RSS-210 7.2. General field strength and Transmitter emission limits

SPECIFICATION:

Except as provided elsewhere in this subpart, the emissions from an intentional radiator shall not exceed the field strength levels specified in the following table:

Frequency Range (MHz)	Field strength (μ V/m)	Field strength ($\text{dB}\mu$ V/m)	Magnetic field strength (H-Field) (μ A/m)	Measurement distance (m)
0.009-0.490	2400/F(kHz)	-	6.37/ F(kHz)	300
0.490-1.705	24000/F(kHz)	-	63.7/ F(kHz)	30
1.705 - 30.0	30	29.54	0.08	30
30 - 88	100	40	-	3
88 - 216	150	43.5	-	3
216 - 960	200	46	-	3
Above 960	500	54	-	3

Additionally, the level of any transmitter unwanted emission shall not exceed the level of the transmitter's fundamental emission.

RESULTS:

All tests were performed in a semi-anechoic chamber at a distance of 3 m, except for the measurement of the fundamental emission that was performed at a distance of 1 m due to its extremely low emission level. The maximum peak value of the fundamental emission was measured as the worst case.

The spectrum was inspected from 9 kHz to 200 MHz searching for spurious signals.

The field strength is calculated by adding correction factor to the measured level from the spectrum analyser. This correction factor includes antenna factor and cable loss.

Fundamental emission:

Measured E($\text{dB}\mu$ V/m) at 1m (Peak value)	32.67
E($\text{dB}\mu$ V/m) extrapolated to 30 m (40 dB/decade)	-26.41
Equivalent level ($\text{dB}\mu$ A/m) at 30 m	-77.91
Measurement uncertainty (dB)	<±3.04

Verdict: PASS

Frequency range 9 kHz - 30 MHz:

No spurious frequencies detected at less than 20 dB below the limit.

Measurement uncertainty (dB)	<±3.04
------------------------------	--------

Verdict: PASS


Frequency range 9 kHz - 30 MHz:

No spurious frequencies detected at less than 20 dB below the limit.


Measurement uncertainty (dB)	<±5.07
------------------------------	--------

Verdict: PASS

FUNDAMENTAL EMISSION:



FREQUENCY RANGE 9 kHz - 30 MHz:



Resolution bandwidth:


200 Hz for $9 \text{ kHz} \leq f \leq 150 \text{ kHz}$

9 kHz for $150 \text{ kHz} \leq f \leq 30 \text{ MHz}$

Note: The scan is performed with a peak detector.

The limits shown in the above plot are extrapolated to 3 meters.

FREQUENCY RANGE 30 - 200 MHz:



Note: The scan is performed with a peak detector.