




Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX f max
Operator Bertezolo 141169129
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Subranges: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX f max
Operator Bertezolo 14116930
Test Spec
Vert




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Subranges: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition TX
Operator Bertezolo 14116945
Test Spec
Loop




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Subranges: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition TX Fmax
Operator Bertezolo 14116960
Test Spec
Vert




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition TX Fmax
Operator Bertezolo 14116961
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX Fmax
Operator Bertezolo 14116962
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX Fmax
Operator Bertezolo 14116963
Test Spec
Vert




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition TX Fmed
Operator Bertezolo 14116964
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition TX Fmed
Operator Bertezolo 14116965
Test Spec
Vert




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX Fmed
Operator Bertezolo 14116966
Test Spec
Vert




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX Fmed
Operator Bertezolo 14116967
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition In TX Fmin
Operator Bertezolo 14116968
Test Spec
Vert




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Subranges: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition In TX Fmin
Operator Bertezolo 14116969
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Subranges: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX Fmin
Operator Bertezolo 14116970
Test Spec
Horiz




Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0



Meas Type Emission
Equipment under Test
Manufacturer
OP Condition RX Fmin
Operator Bertezolo 14116971
Test Spec
Vert



Final Measurement

Meas Time: 1 s
Margin: 6 dB
Peaks: 0

Result: The requirements are met



11.4 20 dB bandwidth

Test set-up and execution

- FCC Rules and Regulation; Titles 47 Part 15.247
- RSS 210 Annex 8
- Internal procedure PM001
- See clause 4 of this test report

Test configuration

Test site:
Semi-anechoic chamber

Auxiliary equipment:
See clause 4 of this test report

EUT exercising

See clause 4 of this test report

Test equipment used

CMC S108, CMC S136, CMC S206
Measurement uncertainty: See clause 7 of this test report

Test specification


See FCC Part 15.247

Environmental conditions

Temperature (°C)	Atmospheric pressure (kPa)	Relative humidity (%)
21	99	50



Setup




Result


Frequency (MHz)	Graphs	20 dB bandwidth (kHz)	Results
906	G14116980	1080,00	Complies
916	G14116981	1060,00	Complies
924	G14116982	1072,00	Complies




Graphs



Bertezzolo 14116980 Tx Fmin



Bertezzo 14116981 Tx Fmed



Bertezzo 14116982 Tx Fmax

Result: The requirements are met



11.5 DTS bandwidth

Test set-up and execution

- FCC Rules and Regulation; Titles 47 Part 15.247
- KDB 558074 D01 DTS Meas Guidance v03r02 cl. 8.1
- RSS 210 Annex 8
- Internal procedure PM001
- See clause 4 of this test report

Test configuration

Test site:
Semi-anechoic chamber

Auxiliary equipment:
See clause 4 of this test report

EUT exercising

See clause 4 of this test report

Test equipment used

CMC S108, CMC S136, CMC S206
Measurement uncertainty: See clause 7 of this test report

Test specification


Systems using digital modulation techniques may operate in the 902–928 MHz, 2400–2483.5 MHz, and 5725–5850 MHz bands. The minimum 6 dB bandwidth shall be at least 500 kHz

Environmental conditions

Temperature (°C)	Atmospheric pressure (kPa)	Relative humidity (%)
21	99	50



Setup




Result


Frequency (MHz)	Graphs	6 dB bandwidth (kHz)	Limits (kHz)	Results
906	G141169A01	908,00	At least 500	Complies
916	G141169A02	924,00	At least 500	Complies
924	G141169A03	948,00	At least 500	Complies




Graphs



Bertezzolo 141169A01 Tx Fmin



Bertezzo 141169A02 Tx Fmed



Bertezzo 141169A03 Tx Fmax

Result: The requirements are met



11.6 Occupied bandwidth (99% BW)

Test set-up and execution

- RSS 210 Annex 8
- Internal procedure PM001
- See clause 4 of this test report

Test configuration

Test site:
Semi-anechoic chamber

Auxiliary equipment:
See clause 4 of this test report

EUT exercising

See clause 4 of this test report

Test equipment used

CMC S108, CMC S136, CMC S206
Measurement uncertainty: See clause 7 of this test report

Test specification


RSS 210 Annex 8

Environmental conditions

Temperature (°C)	Atmospheric pressure (kPa)	Relative humidity (%)
22	99	51



Setup




Result


Frequency (MHz)	Graphs	99% bandwidth (kHz)	Results
906	G14116986	972,00	Complies
916	G14116987	976,00	Complies
924	G14116988	980,00	Complies




Graphs



Bertezzolo 14116986 Tx Fmin



Bertezzo 14116987 Tx Fmed



Bertezzo 14116988 Tx Fmax

Result: The requirements are met