



Accredited by the Swiss Accreditation Service (SAS)  
The Swiss Accreditation Service is one of the signatories to the EA  
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 108**

Client **Sporton-TW (Auden)**

Certificate No: **CD1880V3-1038\_Jun12**

## CALIBRATION CERTIFICATE

Object **CD1880V3 - SN: 1038**

Calibration procedure(s) **QA CAL-20.v6  
Calibration procedure for dipoles in air**

Calibration date: **June 14, 2012**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).  
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature  $(22 \pm 3)^{\circ}\text{C}$  and humidity  $< 70\%$ .

Calibration Equipment used (M&TE critical for calibration)

| Primary Standards     | ID #       | Cal Date (Certificate No.)     | Scheduled Calibration |
|-----------------------|------------|--------------------------------|-----------------------|
| Power meter EPM-442A  | GB37480704 | 05-Oct-11 (No. 217-01451)      | Oct-12                |
| Power sensor HP 8481A | US37292783 | 05-Oct-11 (No. 217-01451)      | Oct-12                |
| Probe ER3DV6          | SN: 2336   | 29-Dec-11 (No. ER3-2336_Dec11) | Dec-12                |
| Probe H3DV6           | SN: 6065   | 29-Dec-11 (No. H3-6065_Dec11)  | Dec-12                |
| DAE4                  | SN: 781    | 29-May-12 (No. DAE4-781_May12) | May-13                |

| Secondary Standards       | ID #           | Check Date (in house)             | Scheduled Check        |
|---------------------------|----------------|-----------------------------------|------------------------|
| Power meter Agilent 4419B | SN: GB42420191 | 09-Oct-09 (in house check Oct-11) | In house check: Oct-12 |
| Power sensor HP 8482H     | SN: 3318A09450 | 09-Oct-09 (in house check Oct-11) | In house check: Oct-12 |
| Power sensor HP 8482A     | SN: US37295597 | 09-Oct-09 (in house check Oct-11) | In house check: Oct-12 |
| Network Analyzer HP 8753E | US37390585     | 18-Oct-01 (in house check Oct-11) | In house check: Oct-12 |
| RF generator E4433B       | MY 41000675    | 03-Nov-04 (in house check Oct-11) | In house check: Oct-13 |

Calibrated by: **Claudio Leubler**      Name: **Claudio Leubler**      Function: **Laboratory Technician**

Approved by: **Katja Pokovic**      Name: **Katja Pokovic**      Function: **Technical Manager**

Signature

Issued: June 18, 2012

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)  
The Swiss Accreditation Service is one of the signatories to the EA  
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 108**

## References

- [1] ANSI-C63.19-2007  
American National Standard for Methods of Measurement of Compatibility between Wireless Communications Devices and Hearing Aids.
- [2] ANSI-C63.19-2011  
American National Standard, Methods of Measurement of Compatibility between Wireless Communications Devices and Hearing Aids.

## Methods Applied and Interpretation of Parameters:

- *Coordinate System:* y-axis is in the direction of the dipole arms. z-axis is from the basis of the antenna (mounted on the table) towards its feed point between the two dipole arms. x-axis is normal to the other axes. In coincidence with the standards [1], the measurement planes (probe sensor center) are selected to be at a distance of 10 mm (15 mm for [2]) above the top metal edge of the dipole arms.
- *Measurement Conditions:* Further details are available from the hardcopies at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated. The forward power to the dipole connector is set with a calibrated power meter connected and monitored with an auxiliary power meter connected to a directional coupler. While the dipole under test is connected, the forward power is adjusted to the same level.
- *Antenna Positioning:* The dipole is mounted on a HAC Test Arch phantom using the matching dipole positioner with the arms horizontal and the feeding cable coming from the floor. The measurements are performed in a shielded room with absorbers around the setup to reduce the reflections. It is verified before the mounting of the dipole under the Test Arch phantom, that its arms are perfectly in a line. It is installed on the HAC dipole positioner with its arms parallel below the dielectric reference wire and able to move elastically in vertical direction without changing its relative position to the top center of the Test Arch phantom. The vertical distance to the probe is adjusted after dipole mounting with a DASY5 Surface Check job. Before the measurement, the distance between phantom surface and probe tip is verified. The proper measurement distance is selected by choosing the matching section of the HAC Test Arch phantom with the proper device reference point (upper surface of the dipole) and the matching grid reference point (tip of the probe) considering the probe sensor offset. The vertical distance to the probe is essential for the accuracy.
- *Feed Point Impedance and Return Loss:* These parameters are measured using a HP 8753E Vector Network Analyzer. The impedance is specified at the SMA connector of the dipole. The influence of reflections was eliminating by applying the averaging function while moving the dipole in the air, at least 70cm away from any obstacles.
- *E-field distribution:* E field is measured in the x-y-plane with an isotropic ER3D-field probe with 100 mW forward power to the antenna feed point. In accordance with [1] and [2], the scan area is 20mm wide, its length exceeds the dipole arm length (180 or 90mm). The sensor center is 10 mm (15 mm for [2]) (in z) above the metal top of the dipole arms. Two 3D maxima are available near the end of the dipole arms. Assuming the dipole arms are perfectly in one line, the average of these two maxima (in subgrid 2 and subgrid 8) is determined to compensate for any non-parallelity to the measurement plane as well as the sensor displacement. The E-field value stated as calibration value represents the maximum of the interpolated 3D-E-field, in the plane above the dipole surface.
- *H-field distribution:* H-field is measured with an isotropic H-field probe with 100mW forward power to the antenna feed point, in the x-y-plane. The scan area and sensor distance is equivalent to the E-field scan. The maximum of the field is available at the center (subgrid 5) above the feed point. The H-field value stated as calibration value represents the maximum of the interpolated H-field, 10mm above the dipole surface at the feed point.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor  $k=2$ , which for a normal distribution corresponds to a coverage probability of approximately 95%.

## Measurement Conditions

DASY system configuration, as far as not given on page 1.

|                                           |                        |         |
|-------------------------------------------|------------------------|---------|
| <b>DASY Version</b>                       | DASY5                  | V52.8.1 |
| <b>Extrapolation</b>                      | Advanced Extrapolation |         |
| <b>Phantom</b>                            | HAC Test Arch          |         |
| <b>Distance Dipole Top - Probe Center</b> | 10mm<br>15mm           |         |
| <b>Scan resolution</b>                    | dx, dy = 5 mm          |         |
| <b>Frequency</b>                          | 1880 MHz $\pm$ 1 MHz   |         |
| <b>Input power drift</b>                  | < 0.05 dB              |         |

## Maximum Field values at 1880 MHz

| <b>H-field 10 mm above dipole surface</b> | condition          | <b>interpolated maximum</b>                     |
|-------------------------------------------|--------------------|-------------------------------------------------|
| Maximum measured                          | 100 mW input power | <b>0.463 A / m <math>\pm</math> 8.2 % (k=2)</b> |

| <b>E-field 10 mm above dipole surface</b> | condition          | <b>Interpolated maximum</b>                      |
|-------------------------------------------|--------------------|--------------------------------------------------|
| Maximum measured above high end           | 100 mW input power | 139.9 V / m                                      |
| Maximum measured above low end            | 100 mW input power | 138.1 V / m                                      |
| Averaged maximum above arm                | 100 mW input power | <b>139.0 V / m <math>\pm</math> 12.8 % (k=2)</b> |

| <b>E-field 15 mm above dipole surface</b> | condition          | <b>Interpolated maximum</b>                     |
|-------------------------------------------|--------------------|-------------------------------------------------|
| Maximum measured above high end           | 100 mW input power | 90.4 V / m                                      |
| Maximum measured above low end            | 100 mW input power | 88.0 V / m                                      |
| Averaged maximum above arm                | 100 mW input power | <b>89.2 V / m <math>\pm</math> 12.8 % (k=2)</b> |

## Appendix

### Antenna Parameters

| Frequency | Return Loss | Impedance                   |
|-----------|-------------|-----------------------------|
| 1730 MHz  | 21.5 dB     | $50.7 \Omega + 8.4 j\Omega$ |
| 1880 MHz  | 22.5 dB     | $53.3 \Omega + 7.0 j\Omega$ |
| 1900 MHz  | 22.2 dB     | $55.4 \Omega + 6.2 j\Omega$ |
| 1950 MHz  | 25.2 dB     | $53.9 \Omega - 4.1 j\Omega$ |
| 2000 MHz  | 20.0 dB     | $40.9 \Omega + 0.1 j\Omega$ |

### 3.2 Antenna Design and Handling


The calibration dipole has a symmetric geometry with a built-in two stub matching network, which leads to the enhanced bandwidth.

The dipole is built of standard semirigid coaxial cable. The internal matching line is open ended. The antenna is therefore open for DC signals.

Do not apply force to dipole arms, as they are liable to bend. The soldered connections near the feedpoint may be damaged. After excessive mechanical stress or overheating, check the impedance characteristics to ensure that the internal matching network is not affected.

After long term use with 40W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

# Impedance Measurement Plot



## DASY4 H-field Result

Date: 14.06.2012

Test Laboratory: SPEAG Lab2

**DUT: HAC Dipole 1880 MHz; Type: CD1880V3; Serial: CD1880V3 - SN: 1038**

Communication System: CW; Frequency: 1880 MHz

Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Phantom section: RF Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY52 Configuration:

- Probe: H3DV6 - SN6065; ; Calibrated: 29.12.2011
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn781; Calibrated: 29.05.2012
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA; Serial: 1070
- DASY52 52.8.1(838); SEMCAD X 14.6.5(6469)

**Dipole H-Field measurement @ 1880MHz/H-Scan - 1880MHz d=10mm/Hearing Aid Compatibility Test (41x181x1):**

Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.4900 A/m; Power Drift = 0.01 dB


PMR not calibrated. PMF = 1.000 is applied.

H-field emissions = 0.4633 A/m

**Near-field category: M2 (AWF 0 dB)**

PMF scaled H-field

|           |           |           |
|-----------|-----------|-----------|
| Grid 1 M2 | Grid 2 M2 | Grid 3 M2 |
| 0.409 A/m | 0.420 A/m | 0.394 A/m |
| Grid 4 M2 | Grid 5 M2 | Grid 6 M2 |
| 0.451 A/m | 0.463 A/m | 0.432 A/m |
| Grid 7 M2 | Grid 8 M2 | Grid 9 M2 |
| 0.415 A/m | 0.427 A/m | 0.393 A/m |



0 dB = 0.4633 A/m = -6.68 dB A/m

## DASY4 E-field Result

Date: 14.06.2012

Test Laboratory: SPEAG Lab2

**DUT: HAC Dipole 1880 MHz; Type: CD1880V3; Serial: CD1880V3 - SN: 1038**

Communication System: CW; Frequency: 1880 MHz

Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: RF Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY52 Configuration:

- Probe: ER3DV6 - SN2336; ConvF(1, 1, 1); Calibrated: 29.12.2011
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn781; Calibrated: 29.05.2012
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA; Serial: 1070
- DASY52 52.8.1(838); SEMCAD X 14.6.5(6469)

**Dipole E-Field measurement @ 1880MHz/E-Scan - 1880MHz d=10mm/Hearing Aid Compatibility Test (41x181x1):**

Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 157.8 V/m; Power Drift = -0.00 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 139.9 V/m

**Near-field category: M2 (AWF 0 dB)**

PMF scaled E-field

|                  |                  |                  |
|------------------|------------------|------------------|
| Grid 1 <b>M2</b> | Grid 2 <b>M2</b> | Grid 3 <b>M2</b> |
| 134.4 V/m        | 138.1 V/m        | 133.2 V/m        |
| Grid 4 <b>M3</b> | Grid 5 <b>M3</b> | Grid 6 <b>M3</b> |
| 89.96 V/m        | 91.35 V/m        | 86.69 V/m        |
| Grid 7 <b>M2</b> | Grid 8 <b>M2</b> | Grid 9 <b>M2</b> |
| 136.5 V/m        | 139.9 V/m        | 132.2 V/m        |

**Dipole E-Field measurement @ 1880MHz/E-Scan - 1880MHz d=15mm/Hearing Aid Compatibility Test (41x181x1):**

Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 157.7 V/m; Power Drift = 0.02 dB


PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 87.97 V/m

Near-field category: M3 (AWF 0 dB)

PMF scaled E-field

|           |           |           |
|-----------|-----------|-----------|
| Grid 1 M3 | Grid 2 M3 | Grid 3 M3 |
| 89.00 V/m | 90.38 V/m | 88.77 V/m |
| Grid 4 M3 | Grid 5 M3 | Grid 6 M3 |
| 69.82 V/m | 70.24 V/m | 68.73 V/m |
| Grid 7 M3 | Grid 8 M3 | Grid 9 M3 |
| 87.06 V/m | 87.97 V/m | 85.67 V/m |



$0\text{ dB} = 139.9\text{ V/m} = 42.92\text{ dB V/m}$



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 108**

The Swiss Accreditation Service is one of the signatories to the EA  
Multilateral Agreement for the recognition of calibration certificates

Client **Sporton (Auden)**

Certificate No: **DAE4-1279\_May12**

## CALIBRATION CERTIFICATE

Object **DAE4 - SD 000 D04 BJ - SN: 1279**

Calibration procedure(s) **QA CAL-06.v24**  
**Calibration procedure for the data acquisition electronics (DAE)**

Calibration date: **May 03, 2012**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).  
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature ( $22 \pm 3$ )°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

| Primary Standards             | ID #               | Cal Date (Certificate No.) | Scheduled Calibration  |
|-------------------------------|--------------------|----------------------------|------------------------|
| Keithley Multimeter Type 2001 | SN: 0810278        | 28-Sep-11 (No:11450)       | Sep-12                 |
| Secondary Standards           | ID #               | Check Date (in house)      | Scheduled Check        |
| Calibrator Box V2.1           | SE UWS 053 AA 1001 | 05-Jan-12 (in house check) | In house check: Jan-13 |

|                |                   |            |           |
|----------------|-------------------|------------|-----------|
| Calibrated by: | Name              | Function   | Signature |
|                | Dominique Steffen | Technician |           |

|              |              |              |
|--------------|--------------|--------------|
| Approved by: | Name         | Function     |
|              | Fin Bornholt | R&D Director |

Issued: May 3, 2012

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA  
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 108**

## Glossary

|                 |                                                                                         |
|-----------------|-----------------------------------------------------------------------------------------|
| DAE             | data acquisition electronics                                                            |
| Connector angle | information used in DASY system to align probe sensor X to the robot coordinate system. |

## Methods Applied and Interpretation of Parameters

- *DC Voltage Measurement:* Calibration Factor assessed for use in DASY system by comparison with a calibrated instrument traceable to national standards. The figure given corresponds to the full scale range of the voltmeter in the respective range.
- *Connector angle:* The angle of the connector is assessed measuring the angle mechanically by a tool inserted. Uncertainty is not required.
- The following parameters as documented in the Appendix contain technical information as a result from the performance test and require no uncertainty.
  - *DC Voltage Measurement Linearity:* Verification of the Linearity at +10% and -10% of the nominal calibration voltage. Influence of offset voltage is included in this measurement.
  - *Common mode sensitivity:* Influence of a positive or negative common mode voltage on the differential measurement.
  - *Channel separation:* Influence of a voltage on the neighbor channels not subject to an input voltage.
  - *AD Converter Values with inputs shorted:* Values on the internal AD converter corresponding to zero input voltage
  - *Input Offset Measurement:* Output voltage and statistical results over a large number of zero voltage measurements.
  - *Input Offset Current:* Typical value for information; Maximum channel input offset current, not considering the input resistance.
  - *Input resistance:* Typical value for information: DAE input resistance at the connector, during internal auto-zeroing and during measurement.
  - *Low Battery Alarm Voltage:* Typical value for information. Below this voltage, a battery alarm signal is generated.
  - *Power consumption:* Typical value for information. Supply currents in various operating modes.

## DC Voltage Measurement

A/D - Converter Resolution nominal

High Range: 1LSB = 6.1 $\mu$ V , full range = -100...+300 mV

Low Range: 1LSB = 61nV , full range = -1.....+3mV

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

| Calibration Factors | X                        | Y                        | Z                        |
|---------------------|--------------------------|--------------------------|--------------------------|
| High Range          | 405.179 $\pm$ 0.1% (k=2) | 404.974 $\pm$ 0.1% (k=2) | 404.316 $\pm$ 0.1% (k=2) |
| Low Range           | 3.98658 $\pm$ 0.7% (k=2) | 3.98731 $\pm$ 0.7% (k=2) | 3.99734 $\pm$ 0.7% (k=2) |

## Connector Angle

|                                           |                   |
|-------------------------------------------|-------------------|
| Connector Angle to be used in DASY system | 117.0 ° $\pm$ 1 ° |
|-------------------------------------------|-------------------|

## Appendix

### 1. DC Voltage Linearity

| High Range |         | Reading ( $\mu\text{V}$ ) | Difference ( $\mu\text{V}$ ) | Error (%) |
|------------|---------|---------------------------|------------------------------|-----------|
| Channel X  | + Input | 199991.33                 | -3.98                        | -0.00     |
| Channel X  | + Input | 20000.42                  | 1.05                         | 0.01      |
| Channel X  | - Input | -20000.99                 | 0.62                         | -0.00     |
| Channel Y  | + Input | 199992.57                 | -2.48                        | -0.00     |
| Channel Y  | + Input | 20000.37                  | 1.13                         | 0.01      |
| Channel Y  | - Input | -20001.77                 | -0.06                        | 0.00      |
| Channel Z  | + Input | 199995.61                 | 0.39                         | 0.00      |
| Channel Z  | + Input | 19999.27                  | 0.00                         | 0.00      |
| Channel Z  | - Input | -20002.85                 | -1.22                        | 0.01      |

| Low Range |         | Reading ( $\mu\text{V}$ ) | Difference ( $\mu\text{V}$ ) | Error (%) |
|-----------|---------|---------------------------|------------------------------|-----------|
| Channel X | + Input | 1999.48                   | -0.32                        | -0.02     |
| Channel X | + Input | 200.41                    | 0.23                         | 0.11      |
| Channel X | - Input | -199.28                   | 0.50                         | -0.25     |
| Channel Y | + Input | 2000.24                   | 0.55                         | 0.03      |
| Channel Y | + Input | 200.58                    | 0.44                         | 0.22      |
| Channel Y | - Input | -199.75                   | -0.01                        | 0.00      |
| Channel Z | + Input | 1998.83                   | -0.82                        | -0.04     |
| Channel Z | + Input | 198.55                    | -1.51                        | -0.75     |
| Channel Z | - Input | -201.15                   | -1.30                        | 0.65      |

### 2. Common mode sensitivity

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

|           | Common mode Input Voltage (mV) | High Range Average Reading ( $\mu\text{V}$ ) | Low Range Average Reading ( $\mu\text{V}$ ) |
|-----------|--------------------------------|----------------------------------------------|---------------------------------------------|
| Channel X | 200                            | 17.08                                        | 15.93                                       |
|           | - 200                          | -15.69                                       | -16.88                                      |
| Channel Y | 200                            | 8.48                                         | 8.38                                        |
|           | - 200                          | -9.22                                        | -9.58                                       |
| Channel Z | 200                            | -0.67                                        | -0.84                                       |
|           | - 200                          | -0.62                                        | -0.65                                       |

### 3. Channel separation

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

|           | Input Voltage (mV) | Channel X ( $\mu\text{V}$ ) | Channel Y ( $\mu\text{V}$ ) | Channel Z ( $\mu\text{V}$ ) |
|-----------|--------------------|-----------------------------|-----------------------------|-----------------------------|
| Channel X | 200                | -                           | 3.17                        | -3.15                       |
| Channel Y | 200                | 7.76                        | -                           | 3.57                        |
| Channel Z | 200                | 8.98                        | 6.44                        | -                           |

#### 4. AD-Converter Values with inputs shorted

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

|           | High Range (LSB) | Low Range (LSB) |
|-----------|------------------|-----------------|
| Channel X | 15658            | 14778           |
| Channel Y | 16426            | 15731           |
| Channel Z | 15918            | 15544           |

#### 5. Input Offset Measurement

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

Input 10M $\Omega$

|           | Average ( $\mu$ V) | min. Offset ( $\mu$ V) | max. Offset ( $\mu$ V) | Std. Deviation ( $\mu$ V) |
|-----------|--------------------|------------------------|------------------------|---------------------------|
| Channel X | 0.78               | -0.61                  | 2.27                   | 0.58                      |
| Channel Y | 0.16               | -1.45                  | 2.45                   | 0.76                      |
| Channel Z | -0.63              | -2.21                  | 0.54                   | 0.54                      |

#### 6. Input Offset Current

Nominal Input circuitry offset current on all channels: <25fA

#### 7. Input Resistance (Typical values for information)

|           | Zeroing (kOhm) | Measuring (MOhm) |
|-----------|----------------|------------------|
| Channel X | 200            | 200              |
| Channel Y | 200            | 200              |
| Channel Z | 200            | 200              |

#### 8. Low Battery Alarm Voltage (Typical values for information)

| Typical values | Alarm Level (VDC) |
|----------------|-------------------|
| Supply (+ Vcc) | +7.9              |
| Supply (- Vcc) | -7.6              |

#### 9. Power Consumption (Typical values for information)

| Typical values | Switched off (mA) | Stand by (mA) | Transmitting (mA) |
|----------------|-------------------|---------------|-------------------|
| Supply (+ Vcc) | +0.01             | +6            | +14               |
| Supply (- Vcc) | -0.01             | -8            | -9                |



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 108**

The Swiss Accreditation Service is one of the signatories to the EA  
 Multilateral Agreement for the recognition of calibration certificates

Client **Sporton-TW (Auden)**

Certificate No: **ER3-2358\_Jun12**

## CALIBRATION CERTIFICATE

Object **ER3DV6 - SN:2358**

Calibration procedure(s) **QA CAL-02.v6, QA CAL-25.v4**  
 Calibration procedure for E-field probes optimized for close near field  
 evaluations in air

Calibration date: **June 21, 2012**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).  
 The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature  $(22 \pm 3)^{\circ}\text{C}$  and humidity  $< 70\%$ .

Calibration Equipment used (M&TE critical for calibration)

| Primary Standards          | ID              | Cal Date (Certificate No.)        | Scheduled Calibration  |
|----------------------------|-----------------|-----------------------------------|------------------------|
| Power meter E4419B         | GB41293874      | 29-Mar-12 (No. 217-01508)         | Apr-13                 |
| Power sensor E4412A        | MY41498087      | 29-Mar-12 (No. 217-01508)         | Apr-13                 |
| Reference 3 dB Attenuator  | SN: S5054 (3c)  | 27-Mar-12 (No. 217-01531)         | Apr-13                 |
| Reference 20 dB Attenuator | SN: S5086 (20b) | 27-Mar-12 (No. 217-01529)         | Apr-13                 |
| Reference 30 dB Attenuator | SN: S5129 (30b) | 27-Mar-12 (No. 217-01532)         | Apr-13                 |
| Reference Probe ER3DV6     | SN: 2328        | 11-Oct-11 (No. ER3-2328_Oct11)    | Oct-12                 |
| DAE4                       | SN: 789         | 30-Jan-12 (No. DAE4-789_Jan12)    | Jan-13                 |
| Secondary Standards        | ID              | Check Date (in house)             | Scheduled Check        |
| RF generator HP 8648C      | US3642U01700    | 4-Aug-99 (in house check Apr-11)  | In house check: Apr-13 |
| Network Analyzer HP 8753E  | US37390585      | 18-Oct-01 (in house check Oct-11) | In house check: Oct-12 |

|                                                                                                                 | Name            | Function              | Signature |
|-----------------------------------------------------------------------------------------------------------------|-----------------|-----------------------|-----------|
| Calibrated by:                                                                                                  | Claudio Leubler | Laboratory Technician |           |
| Approved by:                                                                                                    | Katja Pokovic   | Technical Manager     |           |
| Issued: June 21, 2012                                                                                           |                 |                       |           |
| This calibration certificate shall not be reproduced except in full without written approval of the laboratory. |                 |                       |           |



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 108**

The Swiss Accreditation Service is one of the signatories to the EA  
Multilateral Agreement for the recognition of calibration certificates

### Glossary:

|                          |                                                                                                                                                         |
|--------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|
| NORM <sub>x,y,z</sub>    | sensitivity in free space                                                                                                                               |
| DCP                      | diode compression point                                                                                                                                 |
| CF                       | crest factor (1/duty_cycle) of the RF signal                                                                                                            |
| A, B, C                  | modulation dependent linearization parameters                                                                                                           |
| Polarization $\varphi$   | $\varphi$ rotation around probe axis                                                                                                                    |
| Polarization $\vartheta$ | $\vartheta$ rotation around an axis that is in the plane normal to probe axis (at measurement center),<br>i.e., $\vartheta = 0$ is normal to probe axis |
| Connector Angle          | information used in DASY system to align probe sensor X to the robot coordinate system                                                                  |

### Calibration is Performed According to the Following Standards:

- IEEE Std 1309-2005, "IEEE Standard for calibration of electromagnetic field sensors and probes, excluding antennas, from 9 kHz to 40 GHz", December 2005
- CTIA Test Plan for Hearing Aid Compatibility, April 2010.

### Methods Applied and Interpretation of Parameters:

- NORM<sub>x,y,z</sub>**: Assessed for E-field polarization  $\vartheta = 0$  for XY sensors and  $\vartheta = 90$  for Z sensor ( $f \leq 900$  MHz in TEM-cell;  $f > 1800$  MHz: R22 waveguide).
- NORM(f)<sub>x,y,z</sub>** = NORM<sub>x,y,z</sub> \* frequency\_response (see Frequency Response Chart).
- DCP<sub>x,y,z</sub>**: DCP are numerical linearization parameters assessed based on the data of power sweep with CW signal (no uncertainty required). DCP does not depend on frequency nor media.
- PAR**: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics
- A<sub>x,y,z</sub>; B<sub>x,y,z</sub>; C<sub>x,y,z</sub>; VR<sub>x,y,z</sub>**: A, B, C are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- Spherical isotropy (3D deviation from isotropy)**: in a locally homogeneous field realized using an open waveguide setup.
- Sensor Offset**: The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- Connector Angle**: The angle is assessed using the information gained by determining the NORM<sub>x</sub> (no uncertainty required).

# Probe ER3DV6

## SN:2358

Manufactured: July 7, 2005  
Calibrated: June 21, 2012

Calibrated for DASY/EASY Systems  
(Note: non-compatible with DASY2 system!)

## DASY/EASY - Parameters of Probe: ER3DV6 - SN:2358

### Basic Calibration Parameters

|                                              | Sensor X | Sensor Y | Sensor Z | Unc (k=2)     |
|----------------------------------------------|----------|----------|----------|---------------|
| Norm ( $\mu\text{V}/(\text{V}/\text{m})^2$ ) | 1.70     | 1.55     | 1.57     | $\pm 10.1 \%$ |
| DCP (mV) <sup>B</sup>                        | 98.8     | 99.0     | 102.3    |               |

### Modulation Calibration Parameters

| UID   | Communication System Name                           | PAR   |   | A<br>dB | B<br>dB | C<br>dB | VR<br>mV | Unc <sup>E</sup><br>(k=2) |
|-------|-----------------------------------------------------|-------|---|---------|---------|---------|----------|---------------------------|
| 0     | CW                                                  | 0.00  | X | 0.00    | 0.00    | 1.00    | 204.2    | $\pm 3.8 \%$              |
|       |                                                     |       | Y | 0.00    | 0.00    | 1.00    | 201.7    |                           |
|       |                                                     |       | Z | 0.00    | 0.00    | 1.00    | 188.3    |                           |
| 10011 | UMTS-FDD (WCDMA)                                    | 3.40  | X | 3.49    | 65.8    | 18.4    | 120.1    | $\pm 0.5 \%$              |
|       |                                                     |       | Y | 3.47    | 65.8    | 18.4    | 120.4    |                           |
|       |                                                     |       | Z | 3.31    | 65.1    | 17.9    | 110.1    |                           |
| 10021 | GSM-FDD (TDMA, GMSK)                                | 9.40  | X | 19.88   | 99.9    | 28.7    | 121.6    | $\pm 1.9 \%$              |
|       |                                                     |       | Y | 20.54   | 100.0   | 28.7    | 125.4    |                           |
|       |                                                     |       | Z | 17.30   | 94.8    | 26.8    | 121.8    |                           |
| 10039 | CDMA2000 (1xRTT, RC1)                               | 4.57  | X | 4.72    | 66.3    | 19.1    | 119.0    | $\pm 0.9 \%$              |
|       |                                                     |       | Y | 4.69    | 66.2    | 18.9    | 120.7    |                           |
|       |                                                     |       | Z | 4.75    | 67.2    | 19.4    | 147.6    |                           |
| 10042 | IS-54 / IS-136 FDD (TDMA/FDM, PI/4-DQPSK, Halfrate) | 7.78  | X | 28.22   | 95.6    | 24.2    | 102.8    | $\pm 2.5 \%$              |
|       |                                                     |       | Y | 11.67   | 82.8    | 20.0    | 104.6    |                           |
|       |                                                     |       | Z | 13.01   | 83.3    | 20.2    | 98.4     |                           |
| 10056 | UMTS-TDD (TD-SCDMA, 1.28 Mcps)                      | 11.01 | X | 13.97   | 98.8    | 37.5    | 141.8    | $\pm 3.5 \%$              |
|       |                                                     |       | Y | 14.17   | 98.9    | 37.4    | 144.4    |                           |
|       |                                                     |       | Z | 15.22   | 98.9    | 36.6    | 135.8    |                           |
| 10081 | CDMA2000 (1xRTT, RC3)                               | 3.96  | X | 3.83    | 65.3    | 18.4    | 118.3    | $\pm 0.7 \%$              |
|       |                                                     |       | Y | 3.82    | 65.5    | 18.4    | 119.4    |                           |
|       |                                                     |       | Z | 3.99    | 67.0    | 19.2    | 147.7    |                           |
| 10082 | IS-54 / IS-136 FDD (TDMA/FDM, PI/4-DQPSK, Fullrate) | 4.77  | X | 45.52   | 99.5    | 22.7    | 117.8    | $\pm 2.7 \%$              |
|       |                                                     |       | Y | 56.03   | 99.6    | 22.2    | 119.8    |                           |
|       |                                                     |       | Z | 50.02   | 99.8    | 22.6    | 109.6    |                           |
| 10100 | LTE-FDD (SC-FDMA, 100% RB, 20 MHz, QPSK)            | 5.66  | X | 6.65    | 68.5    | 20.6    | 134.6    | $\pm 2.2 \%$              |
|       |                                                     |       | Y | 6.62    | 68.5    | 20.6    | 136.4    |                           |
|       |                                                     |       | Z | 6.25    | 67.1    | 19.7    | 119.9    |                           |
| 10101 | LTE-FDD (SC-FDMA, 100% RB, 20 MHz, 16-QAM)          | 6.41  | X | 7.82    | 69.0    | 21.2    | 146.1    | $\pm 3.0 \%$              |
|       |                                                     |       | Y | 7.78    | 69.0    | 21.2    | 147.3    |                           |
|       |                                                     |       | Z | 7.37    | 67.6    | 20.2    | 129.8    |                           |
| 10108 | LTE-FDD (SC-FDMA, 100% RB, 10 MHz, QPSK)            | 5.79  | X | 6.49    | 67.9    | 20.4    | 133.5    | $\pm 2.2 \%$              |
|       |                                                     |       | Y | 6.51    | 68.1    | 20.5    | 134.9    |                           |
|       |                                                     |       | Z | 6.07    | 66.6    | 19.5    | 119.0    |                           |
| 10109 | LTE-FDD (SC-FDMA, 100% RB, 10 MHz, 16-QAM)          | 6.42  | X | 7.56    | 68.7    | 21.1    | 142.7    | $\pm 2.7 \%$              |
|       |                                                     |       | Y | 7.53    | 68.6    | 21.0    | 143.0    |                           |
|       |                                                     |       | Z | 7.10    | 67.3    | 20.1    | 126.7    |                           |

|       |                                             |      |   |      |      |      |       |        |
|-------|---------------------------------------------|------|---|------|------|------|-------|--------|
| 10110 | LTE-FDD (SC-FDMA, 100% RB, 5 MHz, QPSK)     | 5.75 | X | 6.20 | 67.5 | 20.3 | 131.4 | ±1.9 % |
|       |                                             |      | Y | 6.13 | 67.2 | 20.1 | 131.1 |        |
|       |                                             |      | Z | 5.77 | 66.1 | 19.3 | 116.7 |        |
| 10111 | LTE-FDD (SC-FDMA, 100% RB, 5 MHz, 16-QAM)   | 6.44 | X | 7.26 | 68.2 | 20.9 | 138.5 | ±2.7 % |
|       |                                             |      | Y | 7.24 | 68.2 | 20.9 | 139.0 |        |
|       |                                             |      | Z | 6.83 | 67.1 | 20.0 | 123.0 |        |
| 10139 | LTE-FDD (SC-FDMA, 100% RB, 15 MHz, QPSK)    | 6.14 | X | 7.30 | 69.0 | 21.1 | 140.1 | ±2.7 % |
|       |                                             |      | Y | 7.27 | 68.9 | 21.1 | 140.4 |        |
|       |                                             |      | Z | 6.81 | 67.3 | 20.0 | 124.7 |        |
| 10140 | LTE-FDD (SC-FDMA, 100% RB, 15 MHz, 16-QAM)  | 6.49 | X | 8.03 | 69.2 | 21.4 | 148.3 | ±3.3 % |
|       |                                             |      | Y | 7.99 | 69.1 | 21.3 | 148.7 |        |
|       |                                             |      | Z | 7.56 | 67.8 | 20.4 | 132.2 |        |
| 10142 | LTE-FDD (SC-FDMA, 100% RB, 3 MHz, QPSK)     | 5.73 | X | 6.00 | 67.1 | 20.0 | 128.3 | ±1.7 % |
|       |                                             |      | Y | 5.99 | 67.1 | 20.1 | 129.3 |        |
|       |                                             |      | Z | 5.58 | 65.8 | 19.2 | 114.2 |        |
| 10143 | LTE-FDD (SC-FDMA, 100% RB, 3 MHz, 16-QAM)   | 6.35 | X | 7.02 | 68.1 | 20.8 | 135.3 | ±2.7 % |
|       |                                             |      | Y | 7.00 | 68.0 | 20.8 | 136.5 |        |
|       |                                             |      | Z | 6.56 | 66.9 | 19.9 | 119.4 |        |
| 10145 | LTE-FDD (SC-FDMA, 100% RB, 1.4 MHz, QPSK)   | 5.76 | X | 5.74 | 66.7 | 19.9 | 124.5 | ±1.7 % |
|       |                                             |      | Y | 5.70 | 66.6 | 19.8 | 126.2 |        |
|       |                                             |      | Z | 5.38 | 65.8 | 19.2 | 110.7 |        |
| 10146 | LTE-FDD (SC-FDMA, 100% RB, 1.4 MHz, 16-QAM) | 6.42 | X | 6.76 | 68.0 | 20.8 | 129.3 | ±2.5 % |
|       |                                             |      | Y | 6.72 | 67.9 | 20.7 | 131.3 |        |
|       |                                             |      | Z | 6.31 | 66.9 | 20.0 | 113.6 |        |
| 10148 | LTE-FDD (SC-FDMA, 50% RB, 20 MHz, QPSK)     | 5.83 | X | 6.59 | 68.1 | 20.6 | 133.8 | ±2.2 % |
|       |                                             |      | Y | 6.61 | 68.2 | 20.6 | 135.5 |        |
|       |                                             |      | Z | 6.15 | 66.6 | 19.6 | 119.0 |        |
| 10149 | LTE-FDD (SC-FDMA, 50% RB, 20 MHz, 16-QAM)   | 6.42 | X | 7.58 | 68.8 | 21.2 | 141.8 | ±3.0 % |
|       |                                             |      | Y | 7.49 | 68.5 | 21.0 | 143.7 |        |
|       |                                             |      | Z | 7.09 | 67.3 | 20.1 | 125.4 |        |
| 10154 | LTE-FDD (SC-FDMA, 50% RB, 10 MHz, QPSK)     | 5.76 | X | 6.20 | 67.4 | 20.3 | 130.1 | ±1.9 % |
|       |                                             |      | Y | 6.19 | 67.4 | 20.2 | 131.5 |        |
|       |                                             |      | Z | 5.75 | 66.0 | 19.3 | 115.4 |        |
| 10155 | LTE-FDD (SC-FDMA, 50% RB, 10 MHz, 16-QAM)   | 6.43 | X | 7.28 | 68.3 | 21.0 | 138.5 | ±2.7 % |
|       |                                             |      | Y | 7.25 | 68.2 | 20.9 | 139.0 |        |
|       |                                             |      | Z | 6.79 | 66.9 | 20.0 | 122.1 |        |
| 10156 | LTE-FDD (SC-FDMA, 50% RB, 5 MHz, QPSK)      | 5.79 | X | 5.98 | 67.1 | 20.2 | 127.4 | ±1.9 % |
|       |                                             |      | Y | 5.94 | 66.9 | 20.0 | 127.7 |        |
|       |                                             |      | Z | 5.56 | 65.8 | 19.3 | 112.8 |        |
| 10157 | LTE-FDD (SC-FDMA, 50% RB, 5 MHz, 16-QAM)    | 6.49 | X | 7.06 | 68.2 | 21.0 | 134.2 | ±2.7 % |
|       |                                             |      | Y | 7.01 | 68.1 | 20.9 | 133.4 |        |
|       |                                             |      | Z | 6.54 | 66.8 | 19.9 | 117.2 |        |
| 10160 | LTE-FDD (SC-FDMA, 50% RB, 15 MHz, QPSK)     | 5.81 | X | 6.64 | 68.0 | 20.4 | 135.9 | ±2.2 % |
|       |                                             |      | Y | 6.61 | 67.9 | 20.4 | 135.1 |        |
|       |                                             |      | Z | 6.20 | 66.6 | 19.5 | 121.1 |        |

|       |                                            |      |   |      |      |      |       |        |
|-------|--------------------------------------------|------|---|------|------|------|-------|--------|
| 10161 | LTE-FDD (SC-FDMA, 50% RB, 15 MHz, 16-QAM)  | 6.42 | X | 7.61 | 68.7 | 21.1 | 143.4 | ±3.0 % |
|       |                                            |      | Y | 7.57 | 68.6 | 21.0 | 141.9 |        |
|       |                                            |      | Z | 7.14 | 67.4 | 20.1 | 127.4 |        |
| 10163 | LTE-FDD (SC-FDMA, 50% RB, 3 MHz, QPSK)     | 5.68 | X | 5.81 | 67.0 | 20.0 | 125.7 | ±1.7 % |
|       |                                            |      | Y | 5.74 | 66.7 | 19.8 | 125.4 |        |
|       |                                            |      | Z | 5.41 | 65.8 | 19.2 | 112.7 |        |
| 10164 | LTE-FDD (SC-FDMA, 50% RB, 3 MHz, 16-QAM)   | 6.44 | X | 6.90 | 68.1 | 20.9 | 130.8 | ±2.5 % |
|       |                                            |      | Y | 6.87 | 68.0 | 20.8 | 130.7 |        |
|       |                                            |      | Z | 6.41 | 66.9 | 20.0 | 115.8 |        |
| 10166 | LTE-FDD (SC-FDMA, 50% RB, 1.4 MHz, QPSK)   | 5.45 | X | 5.08 | 66.0 | 19.4 | 118.9 | ±1.4 % |
|       |                                            |      | Y | 5.10 | 66.2 | 19.5 | 119.3 |        |
|       |                                            |      | Z | 5.23 | 67.3 | 20.1 | 149.7 |        |
| 10167 | LTE-FDD (SC-FDMA, 50% RB, 1.4 MHz, 16-QAM) | 6.21 | X | 6.19 | 67.8 | 20.7 | 121.9 | ±2.2 % |
|       |                                            |      | Y | 6.13 | 67.6 | 20.5 | 123.4 |        |
|       |                                            |      | Z | 5.77 | 66.6 | 19.7 | 109.5 |        |


The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor  $k=2$ , which for a normal distribution corresponds to a coverage probability of approximately 95%.

<sup>B</sup> Numerical linearization parameter: uncertainty not required.

<sup>E</sup> Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

## Frequency Response of E-Field


(TEM-Cell:ifi110 EXX, Waveguide: R22)




Uncertainty of Frequency Response of E-field:  $\pm 6.3\%$  ( $k=2$ )

## Receiving Pattern ( $\phi$ ), $\vartheta = 0^\circ$

$f=600\text{ MHz, TEM, }0^\circ$




$f=2500\text{ MHz, R22, }0^\circ$




## Receiving Pattern ( $\phi$ ), $\vartheta = 90^\circ$


$f=600\text{ MHz, TEM, }90^\circ$



$f=2500\text{ MHz, R22, }90^\circ$




## Receiving Pattern ( $\phi$ ), $\vartheta = 0^\circ$



Uncertainty of Axial Isotropy Assessment:  $\pm 0.5\%$  ( $k=2$ )



## Receiving Pattern ( $\phi$ ), $\vartheta = 90^\circ$



Uncertainty of Axial Isotropy Assessment:  $\pm 0.5\%$  ( $k=2$ )

## Dynamic Range f(E-field)


(TEM cell , f = 900 MHz)



Uncertainty of Linearity Assessment:  $\pm 0.6\%$  (k=2)

## Deviation from Isotropy in Air

Error ( $\phi$ ,  $\theta$ ),  $f = 900$  MHz



Uncertainty of Spherical Isotropy Assessment:  $\pm 2.6\%$  ( $k=2$ )

## DASY/EASY - Parameters of Probe: ER3DV6 - SN:2358

### Other Probe Parameters

|                                         |             |
|-----------------------------------------|-------------|
| Sensor Arrangement                      | Rectangular |
| Connector Angle (°)                     | -63.2       |
| Mechanical Surface Detection Mode       | enabled     |
| Optical Surface Detection Mode          | disabled    |
| Probe Overall Length                    | 337 mm      |
| Probe Body Diameter                     | 10 mm       |
| Tip Length                              | 10 mm       |
| Tip Diameter                            | 8 mm        |
| Probe Tip to Sensor X Calibration Point | 2.5 mm      |
| Probe Tip to Sensor Y Calibration Point | 2.5 mm      |
| Probe Tip to Sensor Z Calibration Point | 2.5 mm      |



Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA  
 Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 108**

Client **Sporton (Auden)**

Certificate No: **H3-6184\_Jan12**

## CALIBRATION CERTIFICATE

Object **H3DV6 - SN:6184**

Calibration procedure(s) **QA CAL-03.v6, QA CAL-25.v4**  
 Calibration procedure for H-field probes optimized for close near field  
 evaluations in air

Calibration date: **January 26, 2012**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).  
 The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature  $(22 \pm 3)^{\circ}\text{C}$  and humidity  $< 70\%$ .

Calibration Equipment used (M&TE critical for calibration)

| Primary Standards          | ID              | Cal Date (Certificate No.)        | Scheduled Calibration  |
|----------------------------|-----------------|-----------------------------------|------------------------|
| Power meter E4419B         | GB41293874      | 31-Mar-11 (No. 217-01372)         | Apr-12                 |
| Power sensor E4412A        | MY41498087      | 31-Mar-11 (No. 217-01372)         | Apr-12                 |
| Reference 3 dB Attenuator  | SN: S5054 (3c)  | 29-Mar-11 (No. 217-01369)         | Apr-12                 |
| Reference 20 dB Attenuator | SN: S5086 (20b) | 29-Mar-11 (No. 217-01367)         | Apr-12                 |
| Reference 30 dB Attenuator | SN: S5129 (30b) | 29-Mar-11 (No. 217-01370)         | Apr-12                 |
| Reference Probe H3DV6      | SN: 6182        | 11-Oct-11 (No. H3-6182_Oct11)     | Oct-12                 |
| DAE4                       | SN: 789         | 6-Apr-11 (No. DAE4-789_Apr11)     | Apr-12                 |
|                            |                 |                                   |                        |
| Secondary Standards        | ID              | Check Date (in house)             | Scheduled Check        |
| RF generator HP 8648C      | US3642U01700    | 4-Aug-99 (in house check Apr-11)  | In house check: Apr-13 |
| Network Analyzer HP 8753E  | US37390585      | 18-Oct-01 (in house check Oct-11) | In house check: Oct-12 |

|                                                                                                                 | Name           | Function              | Signature |
|-----------------------------------------------------------------------------------------------------------------|----------------|-----------------------|-----------|
| Calibrated by:                                                                                                  | Jeton Kastrati | Laboratory Technician |           |
| Approved by:                                                                                                    | Katja Pokovic  | Technical Manager     |           |
|                                                                                                                 |                |                       |           |
| Issued: January 27, 2012                                                                                        |                |                       |           |
| This calibration certificate shall not be reproduced except in full without written approval of the laboratory. |                |                       |           |



Accredited by the Swiss Accreditation Service (SAS)

Accreditation No.: **SCS 108**

The Swiss Accreditation Service is one of the signatories to the EA  
 Multilateral Agreement for the recognition of calibration certificates

### Glossary:

|                          |                                                                                                                                                         |
|--------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|
| NORM <sub>x,y,z</sub>    | sensitivity in free space                                                                                                                               |
| DCP                      | diode compression point                                                                                                                                 |
| CF                       | crest factor (1/duty_cycle) of the RF signal                                                                                                            |
| A, B, C                  | modulation dependent linearization parameters                                                                                                           |
| Polarization $\phi$      | $\phi$ rotation around probe axis                                                                                                                       |
| Polarization $\vartheta$ | $\vartheta$ rotation around an axis that is in the plane normal to probe axis (at measurement center),<br>i.e., $\vartheta = 0$ is normal to probe axis |
| Connector Angle          | information used in DASY system to align probe sensor X to the robot coordinate system                                                                  |

### Calibration is Performed According to the Following Standards:

- IEEE Std 1309-2005, "IEEE Standard for calibration of electromagnetic field sensors and probes, excluding antennas, from 9 kHz to 40 GHz", December 2005.

### Methods Applied and Interpretation of Parameters:

- NORM<sub>x,y,z</sub>**: Assessed for E-field polarization  $\vartheta = 0$  for XY sensors and  $\vartheta = 90$  for Z sensor ( $f \leq 900$  MHz in TEM-cell;  $f > 1800$  MHz: R22 waveguide).
- X, Y, Z(f)**:  $X, Y, Z_{a0a1a2} = X, Y, Z_{a0a1a2} \cdot \text{frequency\_response}$  (see Frequency Response Chart).
- DCP<sub>x,y,z</sub>**: DCP are numerical linearization parameters assessed based on the data of power sweep with CW signal (no uncertainty required). DCP does not depend on frequency nor media.
- PAR**: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics
- A<sub>x,y,z</sub>; B<sub>x,y,z</sub>; C<sub>x,y,z</sub>; VR<sub>x,y,z</sub>**: A, B, C are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- Spherical isotropy (3D deviation from isotropy)**: in a locally homogeneous field realized using an open waveguide setup.
- Sensor Offset**: The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- Connector Angle**: The angle is assessed using the information gained by determining the  $X_{a0a1a2}$  (no uncertainty required).

# Probe H3DV6

## SN:6184

Manufactured: June 8, 2004  
Calibrated: January 26, 2012

**Calibrated for DASY/EASY Systems**  
(Note: non-compatible with DASY2 system!)

## DASY/EASY - Parameters of Probe: H3DV6 - SN:6184

### Basic Calibration Parameters

|                             |    | Sensor X  | Sensor Y   | Sensor Z   | Unc (k=2)    |
|-----------------------------|----|-----------|------------|------------|--------------|
| Norm (A/m / $\sqrt{(mV)}$ ) | a0 | 2.49E-003 | 2.55E-003  | 2.96E-003  | $\pm 5.1 \%$ |
| Norm (A/m / $\sqrt{(mV)}$ ) | a1 | 8.55E-006 | -6.85E-005 | -7.97E-005 | $\pm 5.1 \%$ |
| Norm (A/m / $\sqrt{(mV)}$ ) | a2 | 1.06E-005 | 3.23E-007  | 6.05E-005  | $\pm 5.1 \%$ |
| DCP (mV) <sup>B</sup>       |    | 90.9      | 91.8       | 90.9       |              |

### Modulation Calibration Parameters

| UID   | Communication System Name | PAR  |   | A<br>dB | B<br>dB | C<br>dB | VR<br>mV | Unc <sup>E</sup><br>(k=2) |
|-------|---------------------------|------|---|---------|---------|---------|----------|---------------------------|
| 10000 | CW                        | 0.00 | X | 0.00    | 0.00    | 1.00    | 103.1    | $\pm 1.9 \%$              |
|       |                           |      | Y | 0.00    | 0.00    | 1.00    | 103.9    |                           |
|       |                           |      | Z | 0.00    | 0.00    | 1.00    | 96.8     |                           |


The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

<sup>B</sup> Numerical linearization parameter: uncertainty not required.




<sup>E</sup> Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

## Frequency Response of H-Field


(TEM-Cell:ifi110 EXX, Waveguide: R22)



Uncertainty of Frequency Response of H-field:  $\pm 6.3\%$  ( $k=2$ )


**Receiving Pattern ( $\phi$ ),  $\vartheta = 0^\circ$** **f=600 MHz, TEM,  $0^\circ$** **f=2500 MHz, R22,  $0^\circ$** **Receiving Pattern ( $\phi$ ),  $\vartheta = 90^\circ$** **f=600 MHz, TEM,  $90^\circ$** **f=2500 MHz, R22,  $90^\circ$** 

## Receiving Pattern ( $\phi$ ), $\vartheta = 0^\circ$



Uncertainty of Axial Isotropy Assessment:  $\pm 0.5\%$  ( $k=2$ )



## Receiving Pattern ( $\phi$ ), $\vartheta = 90^\circ$



Uncertainty of Axial Isotropy Assessment:  $\pm 0.5\%$  ( $k=2$ )

## Dynamic Range f(H-field)


(TEM cell,  $f = 900$  MHz)



Uncertainty of Linearity Assessment:  $\pm 0.6\%$  ( $k=2$ )

## Deviation from Isotropy in Air

Error ( $\phi$ ,  $\vartheta$ ),  $f = 900$  MHz



Uncertainty of Spherical Isotropy Assessment:  $\pm 2.6\%$  ( $k=2$ )

## DASY/EASY - Parameters of Probe: H3DV6 - SN:6184

### Other Probe Parameters

|                                         |             |
|-----------------------------------------|-------------|
| Sensor Arrangement                      | Rectangular |
| Connector Angle (°)                     | -64.5       |
| Mechanical Surface Detection Mode       | enabled     |
| Optical Surface Detection Mode          | disabled    |
| Probe Overall Length                    | 337 mm      |
| Probe Body Diameter                     | 10 mm       |
| Tip Length                              | 20 mm       |
| Tip Diameter                            | 6 mm        |
| Probe Tip to Sensor X Calibration Point | 3 mm        |
| Probe Tip to Sensor Y Calibration Point | 3 mm        |
| Probe Tip to Sensor Z Calibration Point | 3 mm        |